

SUEZ Water New York Inc. - Putnam County

PFAS and 1,4-Dioxane Sample Results

Sample ID	Analyte	Sample Date	Final	Units	MRL	MCL
Mahopac Well 1	1,4-Dioxane	10/8/2020	0	ppb	0.07	1
Mahopac Well 1	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/8/2020	0	ppt	2	NA
Mahopac Well 1	N-methyl Perfluorooctanesulfonamidoacetic acid	10/8/2020	0	ppt	2	NA
Mahopac Well 1	Perfluorobutanesulfonic acid	10/8/2020	3.9	ppt	2	NA
Mahopac Well 1	Perfluorodecanoic acid	10/8/2020	0	ppt	2	NA
Mahopac Well 1	Perfluorododecanoic acid	10/8/2020	0	ppt	2	NA
Mahopac Well 1	Perfluoroheptanoic acid	10/8/2020	5.9	ppt	2	NA
Mahopac Well 1	Perfluorohexanesulfonic acid	10/8/2020	2.3	ppt	2	NA
Mahopac Well 1	Perfluorohexanoic acid	10/8/2020	7.4	ppt	2	NA
Mahopac Well 1	Perfluorononanoic acid	10/8/2020	2.4	ppt	2	NA
Mahopac Well 1	Perfluorooctanesulfonic acid	10/8/2020	20	ppt	2	10
Mahopac Well 1	Perfluorooctanoic acid	10/8/2020	22	ppt	2	10
Mahopac Well 1	Perfluorotetradecanoic acid	10/8/2020	0	ppt	2	NA
Mahopac Well 1	Perfluorotridecanoic acid	10/8/2020	0	ppt	2	NA
Mahopac Well 1	Perfluoroundecanoic acid	10/8/2020	0	ppt	2	NA
Mahopac Well 1	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/26/2020	0	ppt	2	NA
Mahopac Well 1	N-methyl Perfluorooctanesulfonamidoacetic acid	10/26/2020	0	ppt	2	NA
Mahopac Well 1	Perfluorobutanesulfonic acid	10/26/2020	4	ppt	2	NA
Mahopac Well 1	Perfluorodecanoic acid	10/26/2020	0	ppt	2	NA
Mahopac Well 1	Perfluorododecanoic acid	10/26/2020	0	ppt	2	NA
Mahopac Well 1	Perfluoroheptanoic acid	10/26/2020	4.8	ppt	2	NA
Mahopac Well 1	Perfluorohexanesulfonic acid	10/26/2020	2.4	ppt	2	NA
Mahopac Well 1	Perfluorohexanoic acid	10/26/2020	7.1	ppt	2	NA
Mahopac Well 1	Perfluorononanoic acid	10/26/2020	0	ppt	2	NA
Mahopac Well 1	Perfluorooctanesulfonic acid	10/26/2020	11	ppt	2	10
Mahopac Well 1	Perfluorooctanoic acid	10/26/2020	13	ppt	2	10
Mahopac Well 1	Perfluorotetradecanoic acid	10/26/2020	0	ppt	2	NA
Mahopac Well 1	Perfluorotridecanoic acid	10/26/2020	0	ppt	2	NA
Mahopac Well 1	Perfluoroundecanoic acid	10/26/2020	0	ppt	2	NA
Mahopac Well 1	1,4-Dioxane	1/28/2021	0	ppb	0.07	1
Mahopac Well 1	N-ethyl Perfluorooctanesulfonamidoacetic acid	1/28/2021	0	ppt	2	NA
Mahopac Well 1	N-methyl Perfluorooctanesulfonamidoacetic acid	1/28/2021	0	ppt	2	NA
Mahopac Well 1	Perfluorobutanesulfonic acid	1/28/2021	4	ppt	2	NA
Mahopac Well 1	Perfluorodecanoic acid	1/28/2021	0	ppt	2	NA
Mahopac Well 1	Perfluorododecanoic acid	1/28/2021	0	ppt	2	NA
Mahopac Well 1	Perfluoroheptanoic acid	1/28/2021	3.2	ppt	2	NA
Mahopac Well 1	Perfluorohexanesulfonic acid	1/28/2021	2.2	ppt	2	NA
Mahopac Well 1	Perfluorohexanoic acid	1/28/2021	5.2	ppt	2	NA
Mahopac Well 1	Perfluorononanoic acid	1/28/2021	0	ppt	2	NA
Mahopac Well 1	Perfluorooctanesulfonic acid	1/28/2021	0	ppt	2	10
Mahopac Well 1	Perfluorooctanoic acid	1/28/2021	10	ppt	2	10
Mahopac Well 1	Perfluorotetradecanoic acid	1/28/2021	0	ppt	2	NA
Mahopac Well 1	Perfluorotridecanoic acid	1/28/2021	0	ppt	2	NA
Mahopac Well 1	Perfluoroundecanoic acid	1/28/2021	0	ppt	2	NA

SUEZ Water New York Inc. - Putnam County

PFAS and 1,4-Dioxane Sample Results

Sample ID	Analyte	Sample Date	Final	Units	MRL	MCL
Mahopac Well 1	1,4-Dioxane	4/19/2021	0	ppb	0.07	1
Mahopac Well 1	1,4-Dioxane	4/19/2021	0	ppb	0.07	1
Mahopac Well 1	N-ethyl Perfluorooctanesulfonamidoacetic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 1	N-ethyl Perfluorooctanesulfonamidoacetic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 1	N-methyl Perfluorooctanesulfonamidoacetic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 1	N-methyl Perfluorooctanesulfonamidoacetic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 1	Perfluorobutanesulfonic acid	4/19/2021	4.3	ppt	2	NA
Mahopac Well 1	Perfluorobutanesulfonic acid	4/19/2021	4.3	ppt	2	NA
Mahopac Well 1	Perfluorodecanoic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 1	Perfluorodecanoic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 1	Perfluorododecanoic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 1	Perfluorododecanoic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 1	Perfluoroheptanoic acid	4/19/2021	3.5	ppt	2	NA
Mahopac Well 1	Perfluoroheptanoic acid	4/19/2021	3.5	ppt	2	NA
Mahopac Well 1	Perfluorohexanesulfonic acid	4/19/2021	2.1	ppt	2	NA
Mahopac Well 1	Perfluorohexanesulfonic acid	4/19/2021	2.1	ppt	2	NA
Mahopac Well 1	Perfluorohexanoic acid	4/19/2021	5.2	ppt	2	NA
Mahopac Well 1	Perfluorohexanoic acid	4/19/2021	5.2	ppt	2	NA
Mahopac Well 1	Perfluorononanoic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 1	Perfluorononanoic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 1	Perfluorooctanesulfonic acid	4/19/2021	10	ppt	2	10
Mahopac Well 1	Perfluorooctanoic acid	4/19/2021	11	ppt	2	10
Mahopac Well 1	Perfluorotetradecanoic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 1	Perfluorotetradecanoic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 1	Perfluorotridecanoic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 1	Perfluorotridecanoic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 1	Perfluoroundecanoic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 1	Perfluoroundecanoic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 1	1,4-Dioxane	7/21/2021	0	ppb	0.07	1
Mahopac Well 1	N-ethyl Perfluorooctanesulfonamidoacetic acid	7/21/2021	0	ppt	2	NA
Mahopac Well 1	N-methyl Perfluorooctanesulfonamidoacetic acid	7/21/2021	0	ppt	2	NA
Mahopac Well 1	Perfluorobutanesulfonic acid	7/21/2021	3.8	ppt	2	NA
Mahopac Well 1	Perfluorodecanoic acid	7/21/2021	0	ppt	2	NA
Mahopac Well 1	Perfluorododecanoic acid	7/21/2021	0	ppt	2	NA
Mahopac Well 1	Perfluoroheptanoic acid	7/21/2021	3.6	ppt	2	NA
Mahopac Well 1	Perfluorohexanesulfonic acid	7/21/2021	2.3	ppt	2	NA
Mahopac Well 1	Perfluorohexanoic acid	7/21/2021	4.8	ppt	2	NA
Mahopac Well 1	Perfluorononanoic acid	7/21/2021	0	ppt	2	NA
Mahopac Well 1	Perfluorooctanesulfonic acid	7/21/2021	8.3	ppt	2	10
Mahopac Well 1	Perfluorooctanoic acid	7/21/2021	10	ppt	2	10
Mahopac Well 1	Perfluorotetradecanoic acid	7/21/2021	0	ppt	2	NA
Mahopac Well 1	Perfluorotridecanoic acid	7/21/2021	0	ppt	2	NA
Mahopac Well 1	Perfluoroundecanoic acid	7/21/2021	0	ppt	2	NA
Mahopac Well 1	1,4-Dioxane	10/20/2021	0	ppb	0.07	1

SUEZ Water New York Inc. - Putnam County

PFAS and 1,4-Dioxane Sample Results

Sample ID	Analyte	Sample Date	Final	Units	MRL	MCL
Mahopac Well 1	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/20/2021	0	ppt	2	NA
Mahopac Well 1	N-methyl Perfluorooctanesulfonamidoacetic acid	10/20/2021	0	ppt	2	NA
Mahopac Well 1	Perfluorobutanesulfonic acid	10/20/2021	4.4	ppt	2	NA
Mahopac Well 1	Perfluorodecanoic acid	10/20/2021	0	ppt	2	NA
Mahopac Well 1	Perfluorododecanoic acid	10/20/2021	0	ppt	2	NA
Mahopac Well 1	Perfluoroheptanoic acid	10/20/2021	3.3	ppt	2	NA
Mahopac Well 1	Perfluorohexanesulfonic acid	10/20/2021	2.1	ppt	2	NA
Mahopac Well 1	Perfluorohexanoic acid	10/20/2021	4.7	ppt	2	NA
Mahopac Well 1	Perfluorononanoic acid	10/20/2021	0	ppt	2	NA
Mahopac Well 1	Perfluorooctanesulfonic acid	10/20/2021	9.2	ppt	2	10
Mahopac Well 1	Perfluorooctanoic acid	10/20/2021	10	ppt	2	10
Mahopac Well 1	Perfluorotetradecanoic acid	10/20/2021	0	ppt	2	NA
Mahopac Well 1	Perfluorotridecanoic acid	10/20/2021	0	ppt	2	NA
Mahopac Well 1	Perfluoroundecanoic acid	10/20/2021	0	ppt	2	NA
Mahopac Well 2	1,4-Dioxane	10/8/2020	0	ppb	0.07	1
Mahopac Well 2	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/8/2020	0	ppt	2	NA
Mahopac Well 2	N-methyl Perfluorooctanesulfonamidoacetic acid	10/8/2020	0	ppt	2	NA
Mahopac Well 2	Perfluorobutanesulfonic acid	10/8/2020	6.2	ppt	2	NA
Mahopac Well 2	Perfluorodecanoic acid	10/8/2020	0	ppt	2	NA
Mahopac Well 2	Perfluorododecanoic acid	10/8/2020	0	ppt	2	NA
Mahopac Well 2	Perfluoroheptanoic acid	10/8/2020	3.6	ppt	2	NA
Mahopac Well 2	Perfluorohexanesulfonic acid	10/8/2020	3.3	ppt	2	NA
Mahopac Well 2	Perfluorohexanoic acid	10/8/2020	5	ppt	2	NA
Mahopac Well 2	Perfluorononanoic acid	10/8/2020	0	ppt	2	NA
Mahopac Well 2	Perfluorooctanesulfonic acid	10/8/2020	8.7	ppt	2	10
Mahopac Well 2	Perfluorooctanoic acid	10/8/2020	13	ppt	2	10
Mahopac Well 2	Perfluorotetradecanoic acid	10/8/2020	0	ppt	2	NA
Mahopac Well 2	Perfluorotridecanoic acid	10/8/2020	0	ppt	2	NA
Mahopac Well 2	Perfluoroundecanoic acid	10/8/2020	0	ppt	2	NA
Mahopac Well 2	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/26/2020	0	ppt	2	NA
Mahopac Well 2	N-methyl Perfluorooctanesulfonamidoacetic acid	10/26/2020	0	ppt	2	NA
Mahopac Well 2	Perfluorobutanesulfonic acid	10/26/2020	4.7	ppt	2	NA
Mahopac Well 2	Perfluorodecanoic acid	10/26/2020	0	ppt	2	NA
Mahopac Well 2	Perfluorododecanoic acid	10/26/2020	0	ppt	2	NA
Mahopac Well 2	Perfluoroheptanoic acid	10/26/2020	3.3	ppt	2	NA
Mahopac Well 2	Perfluorohexanesulfonic acid	10/26/2020	2.8	ppt	2	NA
Mahopac Well 2	Perfluorohexanoic acid	10/26/2020	4.8	ppt	2	NA
Mahopac Well 2	Perfluorononanoic acid	10/26/2020	0	ppt	2	NA
Mahopac Well 2	Perfluorooctanesulfonic acid	10/26/2020	9.5	ppt	2	10
Mahopac Well 2	Perfluorooctanoic acid	10/26/2020	12	ppt	2	10
Mahopac Well 2	Perfluorotetradecanoic acid	10/26/2020	0	ppt	2	NA
Mahopac Well 2	Perfluorotridecanoic acid	10/26/2020	0	ppt	2	NA
Mahopac Well 2	Perfluoroundecanoic acid	10/26/2020	0	ppt	2	NA
Mahopac Well 2	1,4-Dioxane	1/28/2021	0	ppb	0.07	1

SUEZ Water New York Inc. - Putnam County

PFAS and 1,4-Dioxane Sample Results

Sample ID	Analyte	Sample Date	Final	Units	MRL	MCL
Mahopac Well 2	N-ethyl Perfluorooctanesulfonamidoacetic acid	1/28/2021	0	ppt	2	NA
Mahopac Well 2	N-methyl Perfluorooctanesulfonamidoacetic acid	1/28/2021	0	ppt	2	NA
Mahopac Well 2	Perfluorobutanesulfonic acid	1/28/2021	4.2	ppt	2	NA
Mahopac Well 2	Perfluorodecanoic acid	1/28/2021	0	ppt	2	NA
Mahopac Well 2	Perfluorododecanoic acid	1/28/2021	0	ppt	2	NA
Mahopac Well 2	Perfluoroheptanoic acid	1/28/2021	2.5	ppt	2	NA
Mahopac Well 2	Perfluorohexanesulfonic acid	1/28/2021	2.5	ppt	2	NA
Mahopac Well 2	Perfluorohexanoic acid	1/28/2021	3.9	ppt	2	NA
Mahopac Well 2	Perfluorononanoic acid	1/28/2021	0	ppt	2	NA
Mahopac Well 2	Perfluorooctanesulfonic acid	1/28/2021	8.7	ppt	2	10
Mahopac Well 2	Perfluorooctanoic acid	1/28/2021	10	ppt	2	10
Mahopac Well 2	Perfluorotetradecanoic acid	1/28/2021	0	ppt	2	NA
Mahopac Well 2	Perfluorotridecanoic acid	1/28/2021	0	ppt	2	NA
Mahopac Well 2	Perfluoroundecanoic acid	1/28/2021	0	ppt	2	NA
Mahopac Well 2	1,4-Dioxane	4/19/2021	0	ppb	0.07	1
Mahopac Well 2	N-ethyl Perfluorooctanesulfonamidoacetic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 2	N-methyl Perfluorooctanesulfonamidoacetic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 2	Perfluorobutanesulfonic acid	4/19/2021	6.4	ppt	2	NA
Mahopac Well 2	Perfluorodecanoic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 2	Perfluorododecanoic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 2	Perfluoroheptanoic acid	4/19/2021	2.7	ppt	2	NA
Mahopac Well 2	Perfluorohexanesulfonic acid	4/19/2021	3.4	ppt	2	NA
Mahopac Well 2	Perfluorohexanoic acid	4/19/2021	3.2	ppt	2	NA
Mahopac Well 2	Perfluorononanoic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 2	Perfluorooctanesulfonic acid	4/19/2021	9.1	ppt	2	10
Mahopac Well 2	Perfluorooctanoic acid	4/19/2021	12	ppt	2	10
Mahopac Well 2	Perfluorotetradecanoic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 2	Perfluorotridecanoic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 2	Perfluoroundecanoic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 2	1,4-Dioxane	7/21/2021	0	ppb	0.07	1
Mahopac Well 2	N-ethyl Perfluorooctanesulfonamidoacetic acid	7/21/2021	0	ppt	2	NA
Mahopac Well 2	N-methyl Perfluorooctanesulfonamidoacetic acid	7/21/2021	0	ppt	2	NA
Mahopac Well 2	Perfluorobutanesulfonic acid	7/21/2021	4.3	ppt	2	NA
Mahopac Well 2	Perfluorodecanoic acid	7/21/2021	0	ppt	2	NA
Mahopac Well 2	Perfluorododecanoic acid	7/21/2021	0	ppt	2	NA
Mahopac Well 2	Perfluoroheptanoic acid	7/21/2021	2.8	ppt	2	NA
Mahopac Well 2	Perfluorohexanesulfonic acid	7/21/2021	2.6	ppt	2	NA
Mahopac Well 2	Perfluorohexanoic acid	7/21/2021	3.6	ppt	2	NA
Mahopac Well 2	Perfluorononanoic acid	7/21/2021	0	ppt	2	NA
Mahopac Well 2	Perfluorooctanesulfonic acid	7/21/2021	8.3	ppt	2	10
Mahopac Well 2	Perfluorooctanoic acid	7/21/2021	10	ppt	2	10
Mahopac Well 2	Perfluorotetradecanoic acid	7/21/2021	0	ppt	2	NA
Mahopac Well 2	Perfluorotridecanoic acid	7/21/2021	0	ppt	2	NA
Mahopac Well 2	1,4-Dioxane	10/20/2021	0	ppb	0.07	1

SUEZ Water New York Inc. - Putnam County

PFAS and 1,4-Dioxane Sample Results

Sample ID	Analyte	Sample Date	Final	Units	MRL	MCL
Mahopac Well 2	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/20/2021	0	ppt	2	NA
Mahopac Well 2	N-methyl Perfluorooctanesulfonamidoacetic acid	10/20/2021	0	ppt	2	NA
Mahopac Well 2	Perfluorobutanesulfonic acid	10/20/2021	4.8	ppt	2	NA
Mahopac Well 2	Perfluorodecanoic acid	10/20/2021	0	ppt	2	NA
Mahopac Well 2	Perfluorododecanoic acid	10/20/2021	0	ppt	2	NA
Mahopac Well 2	Perfluoroheptanoic acid	10/20/2021	2.9	ppt	2	NA
Mahopac Well 2	Perfluorohexanesulfonic acid	10/20/2021	2.4	ppt	2	NA
Mahopac Well 2	Perfluorohexanoic acid	10/20/2021	4.2	ppt	2	NA
Mahopac Well 2	Perfluorononanoic acid	10/20/2021	0	ppt	2	NA
Mahopac Well 2	Perfluorooctanesulfonic acid	10/20/2021	8.3	ppt	2	10
Mahopac Well 2	Perfluorooctanoic acid	10/20/2021	11	ppt	2	10
Mahopac Well 2	Perfluorotetradecanoic acid	10/20/2021	0	ppt	2	NA
Mahopac Well 2	Perfluorotridecanoic acid	10/20/2021	0	ppt	2	NA
Mahopac Well 2	Perfluoroundecanoic acid	10/20/2021	0	ppt	2	NA
Mahopac Well 3	1,4-Dioxane	10/8/2020	0	ppb	0.07	1
Mahopac Well 3	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/8/2020	0	ppt	2	NA
Mahopac Well 3	N-methyl Perfluorooctanesulfonamidoacetic acid	10/8/2020	0	ppt	2	NA
Mahopac Well 3	Perfluorobutanesulfonic acid	10/8/2020	6.4	ppt	2	NA
Mahopac Well 3	Perfluorodecanoic acid	10/8/2020	0	ppt	2	NA
Mahopac Well 3	Perfluorododecanoic acid	10/8/2020	0	ppt	2	NA
Mahopac Well 3	Perfluoroheptanoic acid	10/8/2020	4.8	ppt	2	NA
Mahopac Well 3	Perfluorohexanesulfonic acid	10/8/2020	2.8	ppt	2	NA
Mahopac Well 3	Perfluorohexanoic acid	10/8/2020	7	ppt	2	NA
Mahopac Well 3	Perfluorononanoic acid	10/8/2020	0	ppt	2	NA
Mahopac Well 3	Perfluorooctanesulfonic acid	10/8/2020	11	ppt	2	10
Mahopac Well 3	Perfluorooctanoic acid	10/8/2020	15	ppt	2	10
Mahopac Well 3	Perfluorotetradecanoic acid	10/8/2020	0	ppt	2	NA
Mahopac Well 3	Perfluorotridecanoic acid	10/8/2020	0	ppt	2	NA
Mahopac Well 3	Perfluoroundecanoic acid	10/8/2020	0	ppt	2	NA
Mahopac Well 3	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/26/2020	0	ppt	2	NA
Mahopac Well 3	N-methyl Perfluorooctanesulfonamidoacetic acid	10/26/2020	0	ppt	2	NA
Mahopac Well 3	Perfluorobutanesulfonic acid	10/26/2020	5.5	ppt	2	NA
Mahopac Well 3	Perfluorodecanoic acid	10/26/2020	0	ppt	2	NA
Mahopac Well 3	Perfluorododecanoic acid	10/26/2020	0	ppt	2	NA
Mahopac Well 3	Perfluoroheptanoic acid	10/26/2020	4.5	ppt	2	NA
Mahopac Well 3	Perfluorohexanesulfonic acid	10/26/2020	2.5	ppt	2	NA
Mahopac Well 3	Perfluorohexanoic acid	10/26/2020	6.5	ppt	2	NA
Mahopac Well 3	Perfluorononanoic acid	10/26/2020	0	ppt	2	NA
Mahopac Well 3	Perfluorooctanesulfonic acid	10/26/2020	11	ppt	2	10
Mahopac Well 3	Perfluorooctanoic acid	10/26/2020	14	ppt	2	10
Mahopac Well 3	Perfluorotetradecanoic acid	10/26/2020	0	ppt	2	NA
Mahopac Well 3	Perfluorotridecanoic acid	10/26/2020	0	ppt	2	NA
Mahopac Well 3	Perfluoroundecanoic acid	10/26/2020	0	ppt	2	NA
Mahopac Well 3	1,4-Dioxane	1/28/2021	0	ppb	0.07	1

SUEZ Water New York Inc. - Putnam County

PFAS and 1,4-Dioxane Sample Results

Sample ID	Analyte	Sample Date	Final	Units	MRL	MCL
Mahopac Well 3	N-ethyl Perfluorooctanesulfonamidoacetic acid	1/28/2021	0	ppt	2	NA
Mahopac Well 3	N-methyl Perfluorooctanesulfonamidoacetic acid	1/28/2021	0	ppt	2	NA
Mahopac Well 3	Perfluorobutanesulfonic acid	1/28/2021	5.6	ppt	2	NA
Mahopac Well 3	Perfluorodecanoic acid	1/28/2021	0	ppt	2	NA
Mahopac Well 3	Perfluorododecanoic acid	1/28/2021	0	ppt	2	NA
Mahopac Well 3	Perfluoroheptanoic acid	1/28/2021	3.9	ppt	2	NA
Mahopac Well 3	Perfluorohexanesulfonic acid	1/28/2021	2.1	ppt	2	NA
Mahopac Well 3	Perfluorohexanoic acid	1/28/2021	5.5	ppt	2	NA
Mahopac Well 3	Perfluorononanoic acid	1/28/2021	0	ppt	2	NA
Mahopac Well 3	Perfluorooctanesulfonic acid	1/28/2021	0	ppt	2	10
Mahopac Well 3	Perfluorooctanoic acid	1/28/2021	13	ppt	2	10
Mahopac Well 3	Perfluorotetradecanoic acid	1/28/2021	0	ppt	2	NA
Mahopac Well 3	Perfluorotridecanoic acid	1/28/2021	0	ppt	2	NA
Mahopac Well 3	Perfluoroundecanoic acid	1/28/2021	0	ppt	2	NA
Mahopac Well 3	1,4-Dioxane	4/19/2021	0	ppb	0.07	1
Mahopac Well 3	N-ethyl Perfluorooctanesulfonamidoacetic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 3	N-methyl Perfluorooctanesulfonamidoacetic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 3	Perfluorobutanesulfonic acid	4/19/2021	6.2	ppt	2	NA
Mahopac Well 3	Perfluorodecanoic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 3	Perfluorododecanoic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 3	Perfluoroheptanoic acid	4/19/2021	3.8	ppt	2	NA
Mahopac Well 3	Perfluorohexanesulfonic acid	4/19/2021	2.3	ppt	2	NA
Mahopac Well 3	Perfluorohexanoic acid	4/19/2021	5.3	ppt	2	NA
Mahopac Well 3	Perfluorononanoic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 3	Perfluorooctanesulfonic acid	4/19/2021	10	ppt	2	10
Mahopac Well 3	Perfluorooctanoic acid	4/19/2021	14	ppt	2	10
Mahopac Well 3	Perfluorotetradecanoic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 3	Perfluorotridecanoic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 3	Perfluoroundecanoic acid	4/19/2021	0	ppt	2	NA
Mahopac Well 3	1,4-Dioxane	7/21/2021	0	ppb	0.07	1
Mahopac Well 3	N-ethyl Perfluorooctanesulfonamidoacetic acid	7/21/2021	0	ppt	2	NA
Mahopac Well 3	N-methyl Perfluorooctanesulfonamidoacetic acid	7/21/2021	0	ppt	2	NA
Mahopac Well 3	Perfluorobutanesulfonic acid	7/21/2021	5.3	ppt	2	NA
Mahopac Well 3	Perfluorodecanoic acid	7/21/2021	0	ppt	2	NA
Mahopac Well 3	Perfluorododecanoic acid	7/21/2021	0	ppt	2	NA
Mahopac Well 3	Perfluoroheptanoic acid	7/21/2021	3.7	ppt	2	NA
Mahopac Well 3	Perfluorohexanesulfonic acid	7/21/2021	2	ppt	2	NA
Mahopac Well 3	Perfluorohexanoic acid	7/21/2021	5.1	ppt	2	NA
Mahopac Well 3	Perfluorononanoic acid	7/21/2021	0	ppt	2	NA
Mahopac Well 3	Perfluorooctanesulfonic acid	7/21/2021	8.9	ppt	2	10
Mahopac Well 3	Perfluorooctanoic acid	7/21/2021	12	ppt	2	10
Mahopac Well 3	Perfluorotetradecanoic acid	7/21/2021	0	ppt	2	NA
Mahopac Well 3	Perfluorotridecanoic acid	7/21/2021	0	ppt	2	NA
Mahopac Well 3	Perfluoroundecanoic acid	7/21/2021	0	ppt	2	NA

SUEZ Water New York Inc. - Putnam County

PFAS and 1,4-Dioxane Sample Results

Sample ID	Analyte	Sample Date	Final	Units	MRL	MCL
Mahopac Well 3	1,4-Dioxane	10/20/2021	0	ppb	0.07	1
Mahopac Well 3	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/20/2021	0	ppt	2	NA
Mahopac Well 3	N-methyl Perfluorooctanesulfonamidoacetic acid	10/20/2021	0	ppt	2	NA
Mahopac Well 3	Perfluorobutanesulfonic acid	10/20/2021	6.6	ppt	2	NA
Mahopac Well 3	Perfluorodecanoic acid	10/20/2021	0	ppt	2	NA
Mahopac Well 3	Perfluorododecanoic acid	10/20/2021	0	ppt	2	NA
Mahopac Well 3	Perfluoroheptanoic acid	10/20/2021	4.1	ppt	2	NA
Mahopac Well 3	Perfluorohexanesulfonic acid	10/20/2021	2.3	ppt	2	NA
Mahopac Well 3	Perfluorohexanoic acid	10/20/2021	6	ppt	2	NA
Mahopac Well 3	Perfluorononanoic acid	10/20/2021	0	ppt	2	NA
Mahopac Well 3	Perfluorooctanesulfonic acid	10/20/2021	10	ppt	2	10
Mahopac Well 3	Perfluorooctanoic acid	10/20/2021	14	ppt	2	10
Mahopac Well 3	Perfluorotetradecanoic acid	10/20/2021	0	ppt	2	NA
Mahopac Well 3	Perfluorotridecanoic acid	10/20/2021	0	ppt	2	NA
Mahopac Well 3	Perfluoroundecanoic acid	10/20/2021	0	ppt	2	NA
Mahopac Well 1	1,4-Dioxane	1/20/2022	0	ppb	0.07	1
Mahopac Well 1	N-ethyl Perfluorooctanesulfonamidoacetic acid	1/20/2022	0	ppt	2	NA
Mahopac Well 1	N-methyl Perfluorooctanesulfonamidoacetic acid	1/20/2022	0	ppt	2	NA
Mahopac Well 1	Perfluorobutanesulfonic acid	1/20/2022	4.2	ppt	2	NA
Mahopac Well 1	Perfluorodecanoic acid	1/20/2022	0	ppt	2	NA
Mahopac Well 1	Perfluorododecanoic acid	1/20/2022	0	ppt	2	NA
Mahopac Well 1	Perfluoroheptanoic acid	1/20/2022	3.3	ppt	2	NA
Mahopac Well 1	Perfluorohexanesulfonic acid	1/20/2022	2	ppt	2	NA
Mahopac Well 1	Perfluorohexanoic acid	1/20/2022	5	ppt	2	NA
Mahopac Well 1	Perfluorononanoic acid	1/20/2022	0	ppt	2	NA
Mahopac Well 1	Perfluorooctanesulfonic acid	1/20/2022	9.6	ppt	2	10
Mahopac Well 1	Perfluorooctanoic acid	1/20/2022	9.6	ppt	2	10
Mahopac Well 1	Perfluorotetradecanoic acid	1/20/2022	0	ppt	2	NA
Mahopac Well 1	Perfluorotridecanoic acid	1/20/2022	0	ppt	2	NA
Mahopac Well 1	Perfluoroundecanoic acid	1/20/2022	0	ppt	2	NA
Mahopac Well 2	1,4-Dioxane	1/20/2022	0	ppb	0.07	1
Mahopac Well 2	N-ethyl Perfluorooctanesulfonamidoacetic acid	1/20/2022	0	ppt	2	NA
Mahopac Well 2	N-methyl Perfluorooctanesulfonamidoacetic acid	1/20/2022	0	ppt	2	NA
Mahopac Well 2	Perfluorobutanesulfonic acid	1/20/2022	4.4	ppt	2	NA
Mahopac Well 2	Perfluorodecanoic acid	1/20/2022	0	ppt	2	NA
Mahopac Well 2	Perfluorododecanoic acid	1/20/2022	0	ppt	2	NA
Mahopac Well 2	Perfluoroheptanoic acid	1/20/2022	2.9	ppt	2	NA
Mahopac Well 2	Perfluorohexanesulfonic acid	1/20/2022	2.4	ppt	2	NA
Mahopac Well 2	Perfluorohexanoic acid	1/20/2022	3.9	ppt	2	NA
Mahopac Well 2	Perfluorononanoic acid	1/20/2022	0	ppt	2	NA
Mahopac Well 2	Perfluorooctanesulfonic acid	1/20/2022	8.1	ppt	2	10
Mahopac Well 2	Perfluorooctanoic acid	1/20/2022	9.7	ppt	2	10
Mahopac Well 2	Perfluorotetradecanoic acid	1/20/2022	0	ppt	2	NA
Mahopac Well 2	Perfluorotridecanoic acid	1/20/2022	0	ppt	2	NA

SUEZ Water New York Inc. - Putnam County

PFAS and 1,4-Dioxane Sample Results

Sample ID	Analyte	Sample Date	Final	Units	MRL	MCL
Mahopac Well 2	Perfluoroundecanoic acid	1/20/2022	0	ppt	2	NA
Mahopac Well 3	1,4-Dioxane	1/20/2022	0	ppb	0.07	1
Mahopac Well 3	N-ethyl Perfluorooctanesulfonamidoacetic acid	1/20/2022	0	ppt	2	NA
Mahopac Well 3	N-methyl Perfluorooctanesulfonamidoacetic acid	1/20/2022	0	ppt	2	NA
Mahopac Well 3	Perfluorobutanesulfonic acid	1/20/2022	6	ppt	2	NA
Mahopac Well 3	Perfluorodecanoic acid	1/20/2022	0	ppt	2	NA
Mahopac Well 3	Perfluorododecanoic acid	1/20/2022	0	ppt	2	NA
Mahopac Well 3	Perfluoroheptanoic acid	1/20/2022	4.3	ppt	2	NA
Mahopac Well 3	Perfluorohexanesulfonic acid	1/20/2022	2.2	ppt	2	NA
Mahopac Well 3	Perfluorohexanoic acid	1/20/2022	6.1	ppt	2	NA
Mahopac Well 3	Perfluorononanoic acid	1/20/2022	0	ppt	2	NA
Mahopac Well 3	Perfluorooctanesulfonic acid	1/20/2022	9.8	ppt	2	10
Mahopac Well 3	Perfluorooctanoic acid	1/20/2022	14	ppt	2	10
Mahopac Well 3	Perfluorotetradecanoic acid	1/20/2022	0	ppt	2	NA
Mahopac Well 3	Perfluorotridecanoic acid	1/20/2022	0	ppt	2	NA
Mahopac Well 3	Perfluoroundecanoic acid	1/20/2022	0	ppt	2	NA

List of Abbreviations:

MRL = Method Reporting Limit, the lowest level the laboratory analysis method can reliably detect

MCL = Maximum Contaminant Level, the regulatory limit set by the State

NA = Not applicable

ND = Not detected

ppt = parts per trillion

ppb = parts per billion