

VWNY - Supplemental Sample Test Results - Chateau Ridge Q3 2022

Sample ID	Method	Analyte	Sample Date	Final	Units	MRL	MCL
Chateau Well 3	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/7/2020		0 ppt		2 NA
Chateau Well 3	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/7/2020		0 ppt		2 NA
Chateau Well 3	EPA 537	Perfluorobutanesulfonic acid	10/7/2020		5.8 ppt		2 NA
Chateau Well 3	EPA 537	Perfluorodecanoic acid	10/7/2020		0 ppt		2 NA
Chateau Well 3	EPA 537	Perfluorododecanoic acid	10/7/2020		0 ppt		2 NA
Chateau Well 3	EPA 537	Perfluoroheptanoic acid	10/7/2020		3.1 ppt		2 NA
Chateau Well 3	EPA 537	Perfluorohexanesulfonic acid	10/7/2020		2.2 ppt		2 NA
Chateau Well 3	EPA 537	Perfluorohexanoic acid	10/7/2020		7.1 ppt		2 NA
Chateau Well 3	EPA 537	Perfluorononanoic acid	10/7/2020		0 ppt		2 NA
Chateau Well 3	EPA 537	Perfluorooctanesulfonic acid	10/7/2020		7 ppt		2 10
Chateau Well 3	EPA 537	Perfluorooctanoic acid	10/7/2020		12 ppt		2 10
Chateau Well 3	EPA 537	Perfluorotetradecanoic acid	10/7/2020		0 ppt		2 NA
Chateau Well 3	EPA 537	Perfluorotridecanoic acid	10/7/2020		0 ppt		2 NA
Chateau Well 3	EPA 537	Perfluoroundecanoic acid	10/7/2020		0 ppt		2 NA
Chateau Well 1	EPA 522	1,4-Dioxane	10/8/2020		0 ppb	0.07	1
Chateau Well 1	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/8/2020		0 ppt		2 NA
Chateau Well 1	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/8/2020		0 ppt		2 NA
Chateau Well 1	EPA 537	Perfluorobutanesulfonic acid	10/8/2020		5.1 ppt		2 NA
Chateau Well 1	EPA 537	Perfluorodecanoic acid	10/8/2020		0 ppt		2 NA
Chateau Well 1	EPA 537	Perfluorododecanoic acid	10/8/2020		0 ppt		2 NA
Chateau Well 1	EPA 537	Perfluoroheptanoic acid	10/8/2020		4.2 ppt		2 NA
Chateau Well 1	EPA 537	Perfluorohexanesulfonic acid	10/8/2020		2.8 ppt		2 NA
Chateau Well 1	EPA 537	Perfluorohexanoic acid	10/8/2020		7.7 ppt		2 NA
Chateau Well 1	EPA 537	Perfluorononanoic acid	10/8/2020		0 ppt		2 NA
Chateau Well 1	EPA 537	Perfluorooctanesulfonic acid	10/8/2020		12 ppt		2 10
Chateau Well 1	EPA 537	Perfluorooctanoic acid	10/8/2020		14 ppt		2 10
Chateau Well 1	EPA 537	Perfluorotetradecanoic acid	10/8/2020		0 ppt		2 NA
Chateau Well 1	EPA 537	Perfluorotridecanoic acid	10/8/2020		0 ppt		2 NA
Chateau Well 1	EPA 537	Perfluoroundecanoic acid	10/8/2020		0 ppt		2 NA
Chateau Well 2	EPA 522	1,4-Dioxane	10/8/2020		0.085 ppb	0.07	1
Chateau Well 2	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/8/2020		0 ppt		2 NA
Chateau Well 2	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/8/2020		0 ppt		2 NA
Chateau Well 2	EPA 537	Perfluorobutanesulfonic acid	10/8/2020		4 ppt		2 NA
Chateau Well 2	EPA 537	Perfluorodecanoic acid	10/8/2020		0 ppt		2 NA
Chateau Well 2	EPA 537	Perfluorododecanoic acid	10/8/2020		0 ppt		2 NA
Chateau Well 2	EPA 537	Perfluoroheptanoic acid	10/8/2020		2 ppt		2 NA
Chateau Well 2	EPA 537	Perfluorohexanesulfonic acid	10/8/2020		2 ppt		2 NA
Chateau Well 2	EPA 537	Perfluorohexanoic acid	10/8/2020		2.9 ppt		2 NA
Chateau Well 2	EPA 537	Perfluorononanoic acid	10/8/2020		0 ppt		2 NA
Chateau Well 2	EPA 537	Perfluorooctanesulfonic acid	10/8/2020		6.9 ppt		2 10
Chateau Well 2	EPA 537	Perfluorooctanoic acid	10/8/2020		8.2 ppt		2 10
Chateau Well 2	EPA 537	Perfluorotetradecanoic acid	10/8/2020		0 ppt		2 NA
Chateau Well 2	EPA 537	Perfluorotridecanoic acid	10/8/2020		0 ppt		2 NA
Chateau Well 2	EPA 537	Perfluoroundecanoic acid	10/8/2020		0 ppt		2 NA
Chateau Well 1	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/26/2020		0 ppt		2 NA
Chateau Well 1	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/26/2020		0 ppt		2 NA
Chateau Well 1	EPA 537	Perfluorobutanesulfonic acid	10/26/2020		5.1 ppt		2 NA
Chateau Well 1	EPA 537	Perfluorodecanoic acid	10/26/2020		0 ppt		2 NA
Chateau Well 1	EPA 537	Perfluorododecanoic acid	10/26/2020		0 ppt		2 NA
Chateau Well 1	EPA 537	Perfluoroheptanoic acid	10/26/2020		3.9 ppt		2 NA
Chateau Well 1	EPA 537	Perfluorohexanesulfonic acid	10/26/2020		2.8 ppt		2 NA
Chateau Well 1	EPA 537	Perfluorohexanoic acid	10/26/2020		7.1 ppt		2 NA
Chateau Well 1	EPA 537	Perfluorononanoic acid	10/26/2020		0 ppt		2 NA
Chateau Well 1	EPA 537	Perfluorooctanesulfonic acid	10/26/2020		15 ppt		2 10
Chateau Well 1	EPA 537	Perfluorooctanoic acid	10/26/2020		14 ppt		2 10
Chateau Well 1	EPA 537	Perfluorotetradecanoic acid	10/26/2020		0 ppt		2 NA
Chateau Well 1	EPA 537	Perfluorotridecanoic acid	10/26/2020		0 ppt		2 NA
Chateau Well 1	EPA 537	Perfluoroundecanoic acid	10/26/2020		0 ppt		2 NA
Chateau Well 3	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/29/2020		0 ppt		2 NA
Chateau Well 3	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/29/2020		0 ppt		2 NA
Chateau Well 3	EPA 537	Perfluorobutanesulfonic acid	10/29/2020		4.1 ppt		2 NA
Chateau Well 3	EPA 537	Perfluorodecanoic acid	10/29/2020		0 ppt		2 NA
Chateau Well 3	EPA 537	Perfluorododecanoic acid	10/29/2020		0 ppt		2 NA
Chateau Well 3	EPA 537	Perfluoroheptanoic acid	10/29/2020		2 ppt		2 NA
Chateau Well 3	EPA 537	Perfluorohexanesulfonic acid	10/29/2020		0 ppt		2 NA
Chateau Well 3	EPA 537	Perfluorohexanoic acid	10/29/2020		3.1 ppt		2 NA
Chateau Well 3	EPA 537	Perfluorononanoic acid	10/29/2020		0 ppt		2 NA
Chateau Well 3	EPA 537	Perfluorooctanesulfonic acid	10/29/2020		4.9 ppt		2 10
Chateau Well 3	EPA 537	Perfluorooctanoic acid	10/29/2020		7.6 ppt		2 10
Chateau Well 3	EPA 537	Perfluorotetradecanoic acid	10/29/2020		0 ppt		2 NA
Chateau Well 3	EPA 537	Perfluorotridecanoic acid	10/29/2020		0 ppt		2 NA
Chateau Well 3	EPA 537	Perfluoroundecanoic acid	10/29/2020		0 ppt		2 NA
Chateau Well 1	EPA 522	1,4-Dioxane	1/28/2021		0 ppb	0.07	1
Chateau Well 1	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	1/28/2021		0 ppt		2 NA
Chateau Well 1	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	1/28/2021		0 ppt		2 NA

VWNY - Supplemental Sample Test Results - Chateau Ridge Q3 2022

Chateau Well 1	EPA 537	Perfluorobutanesulfonic acid	1/28/2021	5.2 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorodecanoic acid	1/28/2021	0 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorododecanoic acid	1/28/2021	0 ppt	2	NA
Chateau Well 1	EPA 537	Perfluoroheptanoic acid	1/28/2021	2.9 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorohexanesulfonic acid	1/28/2021	2.3 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorohexanoic acid	1/28/2021	5.6 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorononanoic acid	1/28/2021	0 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorooctanesulfonic acid	1/28/2021	9.6 ppt	2	10
Chateau Well 1	EPA 537	Perfluorooctanoic acid	1/28/2021	11 ppt	2	10
Chateau Well 1	EPA 537	Perfluorotetradecanoic acid	1/28/2021	0 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorotridecanoic acid	1/28/2021	0 ppt	2	NA
Chateau Well 1	EPA 537	Perfluoroundecanoic acid	1/28/2021	0 ppt	2	NA
Chateau Well 2	EPA 522	1,4-Dioxane	1/28/2021	0 ppb	0.07	1
Chateau Well 2	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	1/28/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	1/28/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorobutanesulfonic acid	1/28/2021	3.8 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorodecanoic acid	1/28/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorododecanoic acid	1/28/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluoroheptanoic acid	1/28/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorohexanesulfonic acid	1/28/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorohexanoic acid	1/28/2021	2.4 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorononanoic acid	1/28/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorooctanesulfonic acid	1/28/2021	6.4 ppt	2	10
Chateau Well 2	EPA 537	Perfluorooctanoic acid	1/28/2021	7.1 ppt	2	10
Chateau Well 2	EPA 537	Perfluorotetradecanoic acid	1/28/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorotridecanoic acid	1/28/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluoroundecanoic acid	1/28/2021	0 ppt	2	NA
Chateau Well 3	EPA 522	1,4-Dioxane	1/28/2021	0 ppb	0.07	1
Chateau Well 1	EPA 522	1,4-Dioxane	4/19/2021	0 ppb	0.07	1
Chateau Well 1	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	4/19/2021	0 ppt	2	NA
Chateau Well 1	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	4/19/2021	0 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorobutanesulfonic acid	4/19/2021	5.9 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorodecanoic acid	4/19/2021	0 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorododecanoic acid	4/19/2021	0 ppt	2	NA
Chateau Well 1	EPA 537	Perfluoroheptanoic acid	4/19/2021	3.2 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorohexanesulfonic acid	4/19/2021	2.6 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorohexanoic acid	4/19/2021	7.1 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorononanoic acid	4/19/2021	0 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorooctanesulfonic acid	4/19/2021	9.9 ppt	2	10
Chateau Well 1	EPA 537	Perfluorooctanoic acid	4/19/2021	12 ppt	2	10
Chateau Well 1	EPA 537	Perfluorotetradecanoic acid	4/19/2021	0 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorotridecanoic acid	4/19/2021	0 ppt	2	NA
Chateau Well 1	EPA 537	Perfluoroundecanoic acid	4/19/2021	0 ppt	2	NA
Chateau Well 2	EPA 522	1,4-Dioxane	4/19/2021	0 ppb	0.07	1
Chateau Well 2	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	4/19/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	4/19/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorobutanesulfonic acid	4/19/2021	4.3 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorodecanoic acid	4/19/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorododecanoic acid	4/19/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluoroheptanoic acid	4/19/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorohexanesulfonic acid	4/19/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorohexanoic acid	4/19/2021	3.1 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorononanoic acid	4/19/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorooctanesulfonic acid	4/19/2021	7.2 ppt	2	10
Chateau Well 2	EPA 537	Perfluorooctanoic acid	4/19/2021	7.7 ppt	2	10
Chateau Well 2	EPA 537	Perfluorotetradecanoic acid	4/19/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorotridecanoic acid	4/19/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluoroundecanoic acid	4/19/2021	0 ppt	2	NA
Chateau Well 3	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	4/21/2021	0 ppt	2	NA
Chateau Well 3	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	4/21/2021	0 ppt	2	NA
Chateau Well 3	EPA 537	Perfluorobutanesulfonic acid	4/21/2021	6.1 ppt	2	NA
Chateau Well 3	EPA 537	Perfluorodecanoic acid	4/21/2021	0 ppt	2	NA
Chateau Well 3	EPA 537	Perfluorododecanoic acid	4/21/2021	0 ppt	2	NA
Chateau Well 3	EPA 537	Perfluoroheptanoic acid	4/21/2021	3.2 ppt	2	NA
Chateau Well 3	EPA 537	Perfluorohexanesulfonic acid	4/21/2021	2.7 ppt	2	NA
Chateau Well 3	EPA 537	Perfluorohexanoic acid	4/21/2021	5.5 ppt	2	NA
Chateau Well 3	EPA 537	Perfluorononanoic acid	4/21/2021	0 ppt	2	NA
Chateau Well 3	EPA 537	Perfluorooctanesulfonic acid	4/21/2021	10 ppt	2	10
Chateau Well 3	EPA 537	Perfluorooctanoic acid	4/21/2021	12 ppt	2	10
Chateau Well 3	EPA 537	Perfluorotetradecanoic acid	4/21/2021	0 ppt	2	NA
Chateau Well 3	EPA 537	Perfluorotridecanoic acid	4/21/2021	0 ppt	2	NA
Chateau Well 3	EPA 537	Perfluoroundecanoic acid	4/21/2021	0 ppt	2	NA
Chateau Well 3	EPA522	1,4-Dioxane	4/21/2021	0 ppb	0.07	1
Chateau Well 1	EPA 522	1,4-Dioxane	7/21/2021	0 ppb	0.07	1
Chateau Well 1	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	7/21/2021	0 ppt	2	NA
Chateau Well 1	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	7/21/2021	0 ppt	2	NA

VWNY - Supplemental Sample Test Results - Chateau Ridge Q3 2022

Chateau Well 1	EPA 537	Perfluorobutanesulfonic acid	7/21/2021	5.4 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorodecanoic acid	7/21/2021	0 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorododecanoic acid	7/21/2021	0 ppt	2	NA
Chateau Well 1	EPA 537	Perfluoroheptanoic acid	7/21/2021	3.4 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorohexanesulfonic acid	7/21/2021	2.2 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorohexanoic acid	7/21/2021	7.7 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorononanoic acid	7/21/2021	0 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorooctanesulfonic acid	7/21/2021	9.8 ppt	2	10
Chateau Well 1	EPA 537	Perfluorooctanoic acid	7/21/2021	11 ppt	2	10
Chateau Well 1	EPA 537	Perfluorotetradecanoic acid	7/21/2021	0 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorotridecanoic acid	7/21/2021	0 ppt	2	NA
Chateau Well 1	EPA 537	Perfluoroundecanoic acid	7/21/2021	0 ppt	2	NA
Chateau Well 2	EPA 522	1,4-Dioxane	7/21/2021	0 ppb	0.07	1
Chateau Well 2	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	7/21/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	7/21/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorobutanesulfonic acid	7/21/2021	4.1 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorodecanoic acid	7/21/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorododecanoic acid	7/21/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluoroheptanoic acid	7/21/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorohexanesulfonic acid	7/21/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorohexanoic acid	7/21/2021	2.8 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorononanoic acid	7/21/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorooctanesulfonic acid	7/21/2021	6.7 ppt	2	10
Chateau Well 2	EPA 537	Perfluorooctanoic acid	7/21/2021	7.6 ppt	2	10
Chateau Well 2	EPA 537	Perfluorotetradecanoic acid	7/21/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorotridecanoic acid	7/21/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluoroundecanoic acid	7/21/2021	0 ppt	2	NA
Chateau Well 1	EPA 522	1,4-Dioxane	10/20/2021	0 ppb	0.07	1
Chateau Well 1	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/20/2021	0 ppt	2	NA
Chateau Well 1	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/20/2021	0 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorobutanesulfonic acid	10/20/2021	6.2 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorodecanoic acid	10/20/2021	0 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorododecanoic acid	10/20/2021	0 ppt	2	NA
Chateau Well 1	EPA 537	Perfluoroheptanoic acid	10/20/2021	4 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorohexanesulfonic acid	10/20/2021	2.4 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorohexanoic acid	10/20/2021	8 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorononanoic acid	10/20/2021	0 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorooctanesulfonic acid	10/20/2021	11 ppt	2	10
Chateau Well 1	EPA 537	Perfluorooctanoic acid	10/20/2021	13 ppt	2	10
Chateau Well 1	EPA 537	Perfluorotetradecanoic acid	10/20/2021	0 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorotridecanoic acid	10/20/2021	0 ppt	2	NA
Chateau Well 1	EPA 537	Perfluoroundecanoic acid	10/20/2021	0 ppt	2	NA
Chateau Well 2	EPA 522	1,4-Dioxane	10/20/2021	0 ppb	0.07	1
Chateau Well 2	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	10/20/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	10/20/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorobutanesulfonic acid	10/20/2021	4.7 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorodecanoic acid	10/20/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorododecanoic acid	10/20/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluoroheptanoic acid	10/20/2021	2.2 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorohexanesulfonic acid	10/20/2021	2 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorohexanoic acid	10/20/2021	3.5 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorononanoic acid	10/20/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorooctanesulfonic acid	10/20/2021	8.2 ppt	2	10
Chateau Well 2	EPA 537	Perfluorooctanoic acid	10/20/2021	8.3 ppt	2	10
Chateau Well 2	EPA 537	Perfluorotetradecanoic acid	10/20/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorotridecanoic acid	10/20/2021	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluoroundecanoic acid	10/20/2021	0 ppt	2	NA
Chateau Well 1	EPA 522	1,4-Dioxane	1/20/2022	0 ppb	0.07	1
Chateau Well 1	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	1/20/2022	0 ppt	2	NA
Chateau Well 1	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	1/20/2022	0 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorobutanesulfonic acid	1/20/2022	5.9 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorodecanoic acid	1/20/2022	0 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorododecanoic acid	1/20/2022	0 ppt	2	NA
Chateau Well 1	EPA 537	Perfluoroheptanoic acid	1/20/2022	3.7 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorohexanesulfonic acid	1/20/2022	2.3 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorohexanoic acid	1/20/2022	7.6 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorononanoic acid	1/20/2022	0 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorooctanesulfonic acid	1/20/2022	11 ppt	2	10
Chateau Well 1	EPA 537	Perfluorooctanoic acid	1/20/2022	11 ppt	2	10
Chateau Well 1	EPA 537	Perfluorotetradecanoic acid	1/20/2022	0 ppt	2	NA
Chateau Well 1	EPA 537	Perfluorotridecanoic acid	1/20/2022	0 ppt	2	NA
Chateau Well 1	EPA 537	Perfluoroundecanoic acid	1/20/2022	0 ppt	2	NA
Chateau Well 2	EPA 522	1,4-Dioxane	1/20/2022	0 ppb	0.07	1
Chateau Well 2	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	1/20/2022	0 ppt	2	NA
Chateau Well 2	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	1/20/2022	0 ppt	2	NA
Chateau Well 2	EPA 537	Perfluorobutanesulfonic acid	1/20/2022	4.7 ppt	2	NA

VWNY - Supplemental Sample Test Results - Chateau Ridge Q3 2022

Chateau Well 2	EPA 537	Perfluorodecanoic acid	1/20/2022	0 ppt	2 NA
Chateau Well 2	EPA 537	Perfluorododecanoic acid	1/20/2022	0 ppt	2 NA
Chateau Well 2	EPA 537	Perfluoroheptanoic acid	1/20/2022	2.8 ppt	2 NA
Chateau Well 2	EPA 537	Perfluorohexanesulfonic acid	1/20/2022	2.1 ppt	2 NA
Chateau Well 2	EPA 537	Perfluorohexanoic acid	1/20/2022	4.8 ppt	2 NA
Chateau Well 2	EPA 537	Perfluorononanoic acid	1/20/2022	0 ppt	2 NA
Chateau Well 2	EPA 537	Perfluorooctanesulfonic acid	1/20/2022	9.7 ppt	2 10
Chateau Well 2	EPA 537	Perfluorooctanoic acid	1/20/2022	9.6 ppt	2 10
Chateau Well 2	EPA 537	Perfluorotetradecanoic acid	1/20/2022	0 ppt	2 NA
Chateau Well 2	EPA 537	Perfluorotridecanoic acid	1/20/2022	0 ppt	2 NA
Chateau Well 2	EPA 537	Perfluoroundecanoic acid	1/20/2022	0 ppt	2 NA
Chateau Well 1	EPA 522	1,4-Dioxane	4/21/2022	0 ppb	0.07 1
Chateau Well 1	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	4/21/2022	0 ppt	2 NA
Chateau Well 1	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	4/21/2022	0 ppt	2 NA
Chateau Well 1	EPA 537	Perfluorobutanesulfonic acid	4/21/2022	6.8 ppt	2 NA
Chateau Well 1	EPA 537	Perfluorodecanoic acid	4/21/2022	0 ppt	2 NA
Chateau Well 1	EPA 537	Perfluorododecanoic acid	4/21/2022	0 ppt	2 NA
Chateau Well 1	EPA 537	Perfluoroheptanoic acid	4/21/2022	3.6 ppt	2 NA
Chateau Well 1	EPA 537	Perfluorohexanesulfonic acid	4/21/2022	2 ppt	2 NA
Chateau Well 1	EPA 537	Perfluorohexanoic acid	4/21/2022	8.5 ppt	2 NA
Chateau Well 1	EPA 537	Perfluorononanoic acid	4/21/2022	0 ppt	2 NA
Chateau Well 1	EPA 537	Perfluorooctanesulfonic acid	4/21/2022	10 ppt	2 10
Chateau Well 1	EPA 537	Perfluorooctanoic acid	4/21/2022	12 ppt	2 10
Chateau Well 1	EPA 537	Perfluorotetradecanoic acid	4/21/2022	0 ppt	2 NA
Chateau Well 1	EPA 537	Perfluorotridecanoic acid	4/21/2022	0 ppt	2 NA
Chateau Well 1	EPA 537	Perfluoroundecanoic acid	4/21/2022	0 ppt	2 NA
Chateau Well 2	EPA 522	1,4-Dioxane	4/21/2022	0 ppb	0.07 1
Chateau Well 2	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	4/21/2022	0 ppt	2 NA
Chateau Well 2	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	4/21/2022	0 ppt	2 NA
Chateau Well 2	EPA 537	Perfluorobutanesulfonic acid	4/21/2022	5.4 ppt	2 NA
Chateau Well 2	EPA 537	Perfluorodecanoic acid	4/21/2022	0 ppt	2 NA
Chateau Well 2	EPA 537	Perfluorododecanoic acid	4/21/2022	0 ppt	2 NA
Chateau Well 2	EPA 537	Perfluoroheptanoic acid	4/21/2022	3 ppt	2 NA
Chateau Well 2	EPA 537	Perfluorohexanesulfonic acid	4/21/2022	2 ppt	2 NA
Chateau Well 2	EPA 537	Perfluorohexanoic acid	4/21/2022	6 ppt	2 NA
Chateau Well 2	EPA 537	Perfluorononanoic acid	4/21/2022	0 ppt	2 NA
Chateau Well 2	EPA 537	Perfluorooctanesulfonic acid	4/21/2022	9.7 ppt	2 10
Chateau Well 2	EPA 537	Perfluorooctanoic acid	4/21/2022	11 ppt	2 10
Chateau Well 2	EPA 537	Perfluorotetradecanoic acid	4/21/2022	0 ppt	2 NA
Chateau Well 2	EPA 537	Perfluorotridecanoic acid	4/21/2022	0 ppt	2 NA
Chateau Well 2	EPA 537	Perfluoroundecanoic acid	4/21/2022	0 ppt	2 NA
Chateau Well 2	EPA 522	1,4-Dioxane	6/7/2022	0 ppb	1 1
Chateau Well 2	EPA 537	N-ethylperfluorooctanesulfonamidoacetic acid	6/7/2022	0 ppt	2 NA
Chateau Well 2	EPA 537	N-methylperfluorooctanesulfonamidoacetic acid	6/7/2022	0 ppt	2 NA
Chateau Well 2	EPA 537	Perfluorobutanesulfonic acid	6/7/2022	4.6 ppt	2 NA
Chateau Well 2	EPA 537	Perfluorodecanoic acid	6/7/2022	0 ppt	2 NA
Chateau Well 2	EPA 537	Perfluorododecanoic acid	6/7/2022	0 ppt	2 NA
Chateau Well 2	EPA 537	Perfluoroheptanoic acid	6/7/2022	2.8 ppt	2 NA
Chateau Well 2	EPA 537	Perfluorohexanesulfonic acid	6/7/2022	2 ppt	2 NA
Chateau Well 2	EPA 537	Perfluorohexanoic acid	6/7/2022	4.2 ppt	2 NA
Chateau Well 2	EPA 537	Perfluorononanoic acid	6/7/2022	0 ppt	2 NA
Chateau Well 2	EPA 537	Perfluorooctanesulfonic acid	6/7/2022	8.4 ppt	2 10
Chateau Well 2	EPA 537	Perfluorooctanoic acid	6/7/2022	8.8 ppt	2 10
Chateau Well 2	EPA 537	Perfluorotetradecanoic acid	6/7/2022	0 ppt	2 NA
Chateau Well 2	EPA 537	Perfluorotridecanoic acid	6/7/2022	0 ppt	2 NA
Chateau Well 2	EPA 537	Perfluoroundecanoic acid	6/7/2022	0 ppt	2 NA
CHATEAU WELL 1	EPA 522	1,4-Dioxane	8/16/2022	0 ug/L	0.07 1
CHATEAU WELL 2	EPA 522	1,4-Dioxane	8/16/2022	0 ug/L	0.07 1
CHATEAU WELL 1	EPA 533	11-Chloroicosafuoro-3-oxaundecane-1-sulfonic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 1	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 1	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 1	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 1	EPA 533	4,8-Dioxa-3H-perfluorononanoic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 1	EPA 533	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 1	EPA 533	Hexafluoropropylene Oxide Dimer Acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 1	EPA 533	Nonafluoro-3,6-dioxaheptanoic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 1	EPA 533	Perfluoro(2-ethoxyethane)sulfonic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 1	EPA 533	Perfluoro-3-methoxypropanoic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 1	EPA 533	Perfluoro-4-methoxybutanoic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 1	EPA 533	Perfluorobutanesulfonic acid	9/14/2022	5.4 ppt	2 NA
CHATEAU WELL 1	EPA 533	Perfluorobutanoic acid	9/14/2022	7.3 ppt	2 NA
CHATEAU WELL 1	EPA 533	Perfluorodecanoic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 1	EPA 533	Perfluorododecanoic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 1	EPA 533	Perfluoroheptanesulfonic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 1	EPA 533	Perfluoroheptanoic acid	9/14/2022	4.4 ppt	2 NA
CHATEAU WELL 1	EPA 533	Perfluorohexanesulfonic acid	9/14/2022	2.2 ppt	2 NA

VWNY - Supplemental Sample Test Results - Chateau Ridge Q3 2022

CHATEAU WELL 1	EPA 533	Perfluorohexanoic acid	9/14/2022	8 ppt	2 NA
CHATEAU WELL 1	EPA 533	Perfluorononanoic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 1	EPA 533	Perfluorooctanesulfonic acid	9/14/2022	14 ppt	2 10
CHATEAU WELL 1	EPA 533	Perfluorooctanoic acid	9/14/2022	13 ppt	2 10
CHATEAU WELL 1	EPA 533	Perfluoropentanesulfonic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 1	EPA 533	Perfluoropentanoic acid	9/14/2022	9.4 ppt	2 NA
CHATEAU WELL 1	EPA 533	Perfluoroundecanoic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 2	EPA 533	11-Chloroeicosafuoro-3-oxaundecane-1-sulfonic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 2	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 2	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 2	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 2	EPA 533	4,8-Dioxa-3H-perfluorononanoic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 2	EPA 533	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 2	EPA 533	Hexafluoropropylene Oxide Dimer Acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 2	EPA 533	Nonafluoro-3,6-dioxaheptanoic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 2	EPA 533	Perfluoro(2-ethoxyethane)sulfonic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 2	EPA 533	Perfluoro-3-methoxypropanoic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 2	EPA 533	Perfluoro-4-methoxybutanoic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 2	EPA 533	Perfluorobutanesulfonic acid	9/14/2022	4.7 ppt	2 NA
CHATEAU WELL 2	EPA 533	Perfluorobutanoic acid	9/14/2022	5 ppt	2 NA
CHATEAU WELL 2	EPA 533	Perfluorodecanoic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 2	EPA 533	Perfluorododecanoic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 2	EPA 533	Perfluoroheptanesulfonic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 2	EPA 533	Perfluoroheptanoic acid	9/14/2022	2.9 ppt	2 NA
CHATEAU WELL 2	EPA 533	Perfluorohexanesulfonic acid	9/14/2022	2 ppt	2 NA
CHATEAU WELL 2	EPA 533	Perfluorohexanoic acid	9/14/2022	3.5 ppt	2 NA
CHATEAU WELL 2	EPA 533	Perfluorononanoic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 2	EPA 533	Perfluorooctanesulfonic acid	9/14/2022	9 ppt	2 10
CHATEAU WELL 2	EPA 533	Perfluorooctanoic acid	9/14/2022	8.4 ppt	2 10
CHATEAU WELL 2	EPA 533	Perfluoropentanesulfonic acid	9/14/2022	0 ppt	2 NA
CHATEAU WELL 2	EPA 533	Perfluoropentanoic acid	9/14/2022	4.8 ppt	2 NA
CHATEAU WELL 2	EPA 533	Perfluoroundecanoic acid	9/14/2022	0 ppt	2 NA
List of Abbreviations:					
MRL = Method Reporting Limit, the lowest level the laboratory analysis method can reliably detect					
MCL = Maximum Contaminant Level, the regulatory limit set by the State					
NA = Not applicable					
ND = Not detected					
ppt = parts per trillion					
ppb = parts per billion					
Analytical results depicted from 9/2020 through 6/2022 are EPA Method 537. Analytical results from 7/2022 to date are EPA Method 533.					
EPA Method 537.1 data from 7/2022 to date is available upon request.					