

Sample ID	System	Type	Method	Analyte	Analyte Acronym	Sample Date	Result	Units	MRL	MCL
Chateau Well 2	Forest Park	Compliance	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	10/20/2021	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorobutanesulfonic acid	PFBS	10/20/2021	4.7	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorodecanoic acid	PFDA	10/20/2021	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorododecanoic acid	PFDoA	10/20/2021	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluoroheptanoic acid	PFHpA	10/20/2021	2.2	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorohexanesulfonic acid	PFHxS	10/20/2021	2	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorohexanoic acid	PFHxA	10/20/2021	3.5	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorononanoic acid	PFNA	10/20/2021	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorooctanesulfonic acid	PFOS	10/20/2021	8.2	ppt	2	10
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorooctanoic acid	PFOA	10/20/2021	8.3	ppt	2	10
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorotetradecanoic acid	PFTeDA	10/20/2021	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorotrideoic acid	PFTrDA	10/20/2021	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluoroundecanoic acid	PFUnA	10/20/2021	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	NETFOSAA	1/20/2022	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	1/20/2022	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorobutanesulfonic acid	PFBS	1/20/2022	5.9	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorodecanoic acid	PFDA	1/20/2022	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorododecanoic acid	PFDoA	1/20/2022	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluoroheptanoic acid	PFHpA	1/20/2022	3.7	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorohexanesulfonic acid	PFHxS	1/20/2022	2.3	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorohexanoic acid	PFHxA	1/20/2022	7.6	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorononanoic acid	PFNA	1/20/2022	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorooctanesulfonic acid	PFOS	1/20/2022	11	ppt	2	10
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorooctanoic acid	PFOA	1/20/2022	11	ppt	2	10
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorotetradecanoic acid	PFTeDA	1/20/2022	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorotrideoic acid	PFTrDA	1/20/2022	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluoroundecanoic acid	PFUnA	1/20/2022	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	NETFOSAA	1/20/2022	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	1/20/2022	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorobutanesulfonic acid	PFBS	1/20/2022	4.7	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorodecanoic acid	PFDA	1/20/2022	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorododecanoic acid	PFDoA	1/20/2022	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluoroheptanoic acid	PFHpA	1/20/2022	2.8	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorohexanesulfonic acid	PFHxS	1/20/2022	2.1	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorohexanoic acid	PFHxA	1/20/2022	4.8	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorononanoic acid	PFNA	1/20/2022	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorooctanesulfonic acid	PFOS	1/20/2022	9.7	ppt	2	10
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorooctanoic acid	PFOA	1/20/2022	9.6	ppt	2	10
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorotetradecanoic acid	PFTeDA	1/20/2022	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorotrideoic acid	PFTrDA	1/20/2022	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluoroundecanoic acid	PFUnA	1/20/2022	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	NETFOSAA	4/21/2022	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	4/21/2022	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorobutanesulfonic acid	PFBS	4/21/2022	6.8	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorodecanoic acid	PFDA	4/21/2022	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorododecanoic acid	PFDoA	4/21/2022	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluoroheptanoic acid	PFHpA	4/21/2022	3.6	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorohexanesulfonic acid	PFHxS	4/21/2022	2	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorohexanoic acid	PFHxA	4/21/2022	8.5	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorononanoic acid	PFNA	4/21/2022	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorooctanesulfonic acid	PFOS	4/21/2022	10	ppt	2	10
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorooctanoic acid	PFOA	4/21/2022	12	ppt	2	10
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorotetradecanoic acid	PFTeDA	4/21/2022	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorotrideoic acid	PFTrDA	4/21/2022	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluoroundecanoic acid	PFUnA	4/21/2022	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	NETFOSAA	4/21/2022	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	4/21/2022	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorobutanesulfonic acid	PFBS	4/21/2022	5.4	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorodecanoic acid	PFDA	4/21/2022	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorododecanoic acid	PFDoA	4/21/2022	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluoroheptanoic acid	PFHpA	4/21/2022	3	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorohexanesulfonic acid	PFHxS	4/21/2022	2	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorohexanoic acid	PFHxA	4/21/2022	6	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorononanoic acid	PFNA	4/21/2022	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorooctanesulfonic acid	PFOS	4/21/2022	9.7	ppt	2	10
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorooctanoic acid	PFOA	4/21/2022	11	ppt	2	10
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorotetradecanoic acid	PFTeDA	4/21/2022	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorotrideoic acid	PFTrDA	4/21/2022	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluoroundecanoic acid	PFUnA	4/21/2022	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	N-ethylperfluorooctanesulfonamidoacetic acid	NETFOSAA	6/7/2022	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	N-methylperfluorooctanesulfonamidoacetic acid	NMeFOSAA	6/7/2022	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorobutanesulfonic acid	PFBS	6/7/2022	4.6	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorodecanoic acid	PFDA	6/7/2022	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorododecanoic acid	PFDoA	6/7/2022	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluoroheptanoic acid	PFHpA	6/7/2022	2.8	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorohexanesulfonic acid	PFHxS	6/7/2022	2	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorohexanoic acid	PFHxA	6/7/2022	4.2	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorononanoic acid	PFNA	6/7/2022	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorooctanesulfonic acid	PFOS	6/7/2022	8.4	ppt	2	10
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorooctanoic acid	PFOA	6/7/2022	8.8	ppt	2	10
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorotetradecanoic acid	PFTeDA	6/7/2022	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorotrideoic acid	PFTrDA	6/7/2022	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluoroundecanoic acid	PFUnA	6/7/2022	0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	11-Chloroicosafuoro-3-oxaundecane-1-sulfonic acid	11CI-PF30UdS	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	4,8-Dioxo-3H-perfluorononanoic acid	ADONNA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9CI-PF30NS	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	8/16/2022	0	ppt	1.9	NA

Sample ID	System	Type	Method	Analyte	Analyte Acronym	Sample Date	Result	Units	MRL	MCL
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	N-ethylperfluorooctanesulfonamidoacetic acid	NETFOSAA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	N-methylperfluorooctanesulfonamidoacetic acid	NMeFOSAA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorobutanesulfonic acid	PFBS	8/16/2022	6	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorodecanoic acid	PFDA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorododecanoic acid	PFDoA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorohexanoic acid	PFHxA	8/16/2022	4.6	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorohexanesulfonic acid	PFHxS	8/16/2022	2.4	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorohexanoic acid	PFHxA	8/16/2022	8.3	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorononanoic acid	PFNA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorooctanesulfonic acid	PFOS	8/16/2022	16	ppt	1.9	10
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorooctanoic acid	PFOA	8/16/2022	17	ppt	1.9	10
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorotetradecanoic acid	PFTeDA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorotridecanoic acid	PFTrDA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluoroundecanoic acid	PFUnA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	11-Chloroicosafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	4,8-Dioxa-3H-perfluorononanoic acid	ADONA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9CI-PF3ONS	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	N-ethylperfluorooctanesulfonamidoacetic acid	NETFOSAA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	N-methylperfluorooctanesulfonamidoacetic acid	NMeFOSAA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorobutanesulfonic acid	PFBS	8/16/2022	5.1	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorodecanoic acid	PFDA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorododecanoic acid	PFDoA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorohexanoic acid	PFHxA	8/16/2022	3	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorohexanesulfonic acid	PFHxS	8/16/2022	2.1	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorohexanoic acid	PFHxA	8/16/2022	4.4	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorononanoic acid	PFNA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorooctanesulfonic acid	PFOS	8/16/2022	11	ppt	1.9	10
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorooctanoic acid	PFOA	8/16/2022	12	ppt	1.9	10
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorotetradecanoic acid	PFTeDA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorotridecanoic acid	PFTrDA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluoroundecanoic acid	PFUnA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	11-Chloroicosafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	9/14/2022	0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	9/14/2022	0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	9/14/2022	0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	9/14/2022	0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	4,8-Dioxa-3H-perfluorononanoic acid	ADONA	9/14/2022	0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9CI-PF3ONS	9/14/2022	0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	9/14/2022	0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Nonafluoro-3,6-dioxaheptanoic acid	NFDHA	9/14/2022	0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid	PFMPA	9/14/2022	0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBA	9/14/2022	0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoro(2-ethoxyethane)sulfonic acid	PFEESA	9/14/2022	0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorobutanesulfonic acid	PFBS	9/14/2022	5.4	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorobutanoic acid	PFBA	9/14/2022	7.3	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorodecanoic acid	PFDA	9/14/2022	0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorododecanoic acid	PFDoA	9/14/2022	0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorohexanesulfonic acid	PFHxS	9/14/2022	0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorohexanoic acid	PFHxA	9/14/2022	4.4	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorohexanesulfonic acid	PFHxS	9/14/2022	2.2	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorohexanoic acid	PFHxA	9/14/2022	8	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorononanoic acid	PFNA	9/14/2022	0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorooctanesulfonic acid	PFOS	9/14/2022	14	ppt	2	10
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorooctanoic acid	PFOA	9/14/2022	13	ppt	2	10
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoropentanesulfonic acid	PFPeS	9/14/2022	0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoropentanoic acid	PFPeA	9/14/2022	9.4	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoroundecanoic acid	PFUnA	9/14/2022	0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	11-Chloroicosafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	9/14/2022	0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	9/14/2022	0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	9/14/2022	0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	9/14/2022	0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	4,8-Dioxa-3H-perfluorononanoic acid	ADONA	9/14/2022	0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9CI-PF3ONS	9/14/2022	0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	9/14/2022	0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Nonafluoro-3,6-dioxaheptanoic acid	NFDHA	9/14/2022	0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid	PFMPA	9/14/2022	0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBA	9/14/2022	0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoro(2-ethoxyethane)sulfonic acid	PFEESA	9/14/2022	0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorobutanesulfonic acid	PFBS	9/14/2022	4.7	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorobutanoic acid	PFBA	9/14/2022	5	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorodecanoic acid	PFDA	9/14/2022	0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorododecanoic acid	PFDoA	9/14/2022	0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorohexanesulfonic acid	PFHxS	9/14/2022	0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorohexanoic acid	PFHxA	9/14/2022	2.9	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorohexanesulfonic acid	PFHxS	9/14/2022	2	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorohexanoic acid	PFHxA	9/14/2022	3.5	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorononanoic acid	PFNA	9/14/2022	0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorooctanesulfonic acid	PFOS	9/14/2022	9	ppt	2	10
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorooctanoic acid	PFOA	9/14/2022	8.4	ppt	2	10
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoropentanesulfonic acid	PFPeS	9/14/2022	0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoropentanoic acid	PFPeA	9/14/2022	4.8	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoroundecanoic acid	PFUnA	9/14/2022	0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 533	11-Chloroicosafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	10/24/2022	0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	10/24/2022	0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	10/24/2022	0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	10/24/2022	0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 533	4,8-Dioxa-3H-perfluorononanoic acid	ADONA	10/24/2022	0	ppt	2	NA

Sample ID	System	Type	Method	Analyte	Analyte Acronym	Sample Date	Result	Units	MRL	MCL
CHATEAU WELL 1	Chateau	Compliance	EPA 533	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9CI-PF3ONS	10/24/2022	0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 533	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	10/24/2022	0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxiheptanoic acid	NFDHA	10/24/2022	0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 533	Perfluoro(2-ethoxyethane)sulfonic acid	PFEESA	10/24/2022	0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid	PFMPA	10/24/2022	0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBA	10/24/2022	0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid	PFBS	10/24/2022	4.3	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 533	Perfluorobutanoic acid	PFBA	10/24/2022	5	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 533	Perfluorodecanoic acid	PFDA	10/24/2022	0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 533	Perfluorododecanoic acid	PFDoA	10/24/2022	0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid	PFHpS	10/24/2022	0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 533	Perfluoroheptanoic acid	PFHpA	10/24/2022	2.4	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid	PFHxS	10/24/2022	0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 533	Perfluorohexanoic acid	PFHxA	10/24/2022	3.5	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 533	Perfluorononanoic acid	PFNA	10/24/2022	0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid	PFOS	10/24/2022	8.5	ppt	2	10
CHATEAU WELL 1	Chateau	Compliance	EPA 533	Perfluorooctanoic acid	PFOA	10/24/2022	8.3	ppt	2	10
CHATEAU WELL 1	Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid	PFPeS	10/24/2022	0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 533	Perfluoropentanoic acid	PFPeA	10/24/2022	5.1	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 533	Perfluoroundecanoic acid	PFUnA	10/24/2022	0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 537.1	11-Chloroeicosfluoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	10/24/2022	0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 537.1	4,8-Dioxa-3H-perfluorononanoic acid	ADONA	10/24/2022	0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 537.1	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9CI-PF3ONS	10/24/2022	0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 537.1	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	10/24/2022	0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 537.1	N-ethylperfluorooctanesulfonamidoacetic acid	NEFOSAA	10/24/2022	0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 537.1	N-methylperfluorooctanesulfonamidoacetic acid	NMeFOSAA	10/24/2022	0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 537.1	Perfluorobutanesulfonic acid	PFBS	10/24/2022	5.3	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 537.1	Perfluorodecanoic acid	PFDA	10/24/2022	0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 537.1	Perfluorododecanoic acid	PFDoA	10/24/2022	0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 537.1	Perfluoroheptanoic acid	PFHpA	10/24/2022	4.5	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 537.1	Perfluorohexanesulfonic acid	PFHxS	10/24/2022	2.3	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 537.1	Perfluorohexanoic acid	PFHxA	10/24/2022	8.8	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 537.1	Perfluorononanoic acid	PFNA	10/24/2022	0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 537.1	Perfluorooctanesulfonic acid	PFOS	10/24/2022	12	ppt	2	10
CHATEAU WELL 1	Chateau	Compliance	EPA 537.1	Perfluorooctanoic acid	PFOA	10/24/2022	14	ppt	2	10
CHATEAU WELL 1	Chateau	Compliance	EPA 537.1	Perfluorotetradecanoic acid	PFTA	10/24/2022	0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 537.1	Perfluorotridecanoic acid	PFTrDA	10/24/2022	0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 537.1	Perfluoroundecanoic acid	PFUnA	10/24/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 537.1	11-Chloroeicosfluoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	10/24/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 537.1	4,8-Dioxa-3H-perfluorononanoic acid	ADONA	10/24/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 537.1	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9CI-PF3ONS	10/24/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 537.1	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	10/24/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 537.1	N-ethylperfluorooctanesulfonamidoacetic acid	NEFOSAA	10/24/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 537.1	N-methylperfluorooctanesulfonamidoacetic acid	NMeFOSAA	10/24/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 537.1	Perfluorobutanesulfonic acid	PFBS	10/24/2022	4.6	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 537.1	Perfluorodecanoic acid	PFDA	10/24/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 537.1	Perfluorododecanoic acid	PFDoA	10/24/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 537.1	Perfluoroheptanoic acid	PFHpA	10/24/2022	2.6	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 537.1	Perfluorohexanesulfonic acid	PFHxS	10/24/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 537.1	Perfluorohexanoic acid	PFHxA	10/24/2022	4.6	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 537.1	Perfluorononanoic acid	PFNA	10/24/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 537.1	Perfluorooctanesulfonic acid	PFOS	10/24/2022	7.7	ppt	2	10
CHATEAU WELL 2	Chateau	Compliance	EPA 537.1	Perfluorooctanoic acid	PFOA	10/24/2022	9.1	ppt	2	10
CHATEAU WELL 2	Chateau	Compliance	EPA 537.1	Perfluorotetradecanoic acid	PFTA	10/24/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 537.1	Perfluorotridecanoic acid	PFTrDA	10/24/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 537.1	Perfluoroundecanoic acid	PFUnA	10/24/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 533	11-Chloroeicosfluoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	11/22/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	11/22/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	11/22/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	11/22/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 533	4,8-Dioxa-3H-perfluorononanoic acid	ADONA	11/22/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 533	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9CI-PF3ONS	11/22/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 533	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	11/22/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxiheptanoic acid	NFDHA	11/22/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 533	Perfluoro(2-ethoxyethane)sulfonic acid	PFEESA	11/22/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid	PFMPA	11/22/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBA	11/22/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid	PFBS	11/22/2022	4.7	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 533	Perfluorobutanoic acid	PFBA	11/22/2022	6	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 533	Perfluorodecanoic acid	PFDA	11/22/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 533	Perfluorododecanoic acid	PFDoA	11/22/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid	PFHpS	11/22/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 533	Perfluoroheptanoic acid	PFHpA	11/22/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid	PFHxS	11/22/2022	2	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 533	Perfluorohexanoic acid	PFHxA	11/22/2022	2.9	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 533	Perfluorononanoic acid	PFNA	11/22/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid	PFOS	11/22/2022	8.2	ppt	2	10
CHATEAU WELL 2	Chateau	Compliance	EPA 533	Perfluorooctanoic acid	PFOA	11/22/2022	7.7	ppt	2	10
CHATEAU WELL 2	Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid	PFPeS	11/22/2022	0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 533	Perfluoropentanoic acid	PFPeA	11/22/2022	4.3	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 533	Perfluoroundecanoic acid	PFUnA	11/22/2022	0	ppt	2	NA

List of Abbreviations

MRL = Method Reporting Limit, the lowest level the laboratory analysis method can reliably detect

MCL = Maximum Contaminant Level, the regulatory limit set by the State

NA = Not applicable

ND = Not detected

ppt = parts per trillion

Sample ID	System	Type	Method	Analyte	Analyte Acronym	Sample Date	Result	Units	MRL	MCL
-----------	--------	------	--------	---------	-----------------	-------------	--------	-------	-----	-----

ppb = parts per billion

Analytical results depicted from 9/2020 through 6/2022 are EPA Method 537. Analytical results from 7/2022 to date are EPA Method 533.

EPA Method 537.1 data from 7/2022 to date is also included in the table.

Table has been sorted by sample date