

July 6, 2023

1

Sample ID	System	Type	Project	Method	Analyte	Analyte Acronym	Sample Date	Results	Units	MRL	MCL
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorohexanoic acid	PFHxA	4/19/2021	4	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic acid	PFNA	4/19/2021	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanesulfonic acid	PFOS	4/19/2021	13	ppt	2	10
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic acid	PFOA	4/19/2021	9	ppt	2	10
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorotetradecanoic acid	PFTeDA	4/19/2021	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorotridecanoic acid	PFTrDA	4/19/2021	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluoroundecanoic acid	PFUnA	4/19/2021	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 522	1,4-Dioxane		8/18/2021	0	ppb	0.07	1
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	NeFOSAA	8/18/2021	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	8/18/2021	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorobutanesulfonic acid	PFBS	8/18/2021	5.5	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorodecanoic acid	PFDA	8/18/2021	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorododecanoic acid	PFDoA	8/18/2021	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluoroheptanoic acid	PFHpA	8/18/2021	3.2	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorohexanesulfonic acid	PFHxS	8/18/2021	2	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorohexanoic acid	PFHxA	8/18/2021	6.4	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic acid	PFNA	8/18/2021	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanesulfonic acid	PFOS	8/18/2021	10	ppt	2	10
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic acid	PFOA	8/18/2021	10	ppt	2	10
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorotetradecanoic acid	PFTeDA	8/18/2021	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorotridecanoic acid	PFTrDA	8/18/2021	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluoroundecanoic acid	PFUnA	8/18/2021	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 522	1,4-Dioxane		8/18/2021	0	ppb	0.07	1
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	NeFOSAA	8/18/2021	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	8/18/2021	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorobutanesulfonic acid	PFBS	8/18/2021	11	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorodecanoic acid	PFDA	8/18/2021	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorododecanoic acid	PFDoA	8/18/2021	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluoroheptanoic acid	PFHpA	8/18/2021	2.6	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorohexanesulfonic acid	PFHxS	8/18/2021	2.4	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorohexanoic acid	PFHxA	8/18/2021	4.4	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic acid	PFNA	8/18/2021	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanesulfonic acid	PFOS	8/18/2021	14	ppt	2	10
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic acid	PFOA	8/18/2021	9.8	ppt	2	10
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorotetradecanoic acid	PFTeDA	8/18/2021	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorotridecanoic acid	PFTrDA	8/18/2021	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluoroundecanoic acid	PFUnA	8/18/2021	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 522	1,4-Dioxane		10/20/2021	0	ppb	0.07	1
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	NeFOSAA	10/20/2021	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	10/20/2021	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorobutanesulfonic acid	PFBS	10/20/2021	7.8	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorodecanoic acid	PFDA	10/20/2021	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorododecanoic acid	PFDoA	10/20/2021	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluoroheptanoic acid	PFHpA	10/20/2021	4.2	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorohexanesulfonic acid	PFHxS	10/20/2021	2.6	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorohexanoic acid	PFHxA	10/20/2021	7.7	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic acid	PFNA	10/20/2021	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanesulfonic acid	PFOS	10/20/2021	13	ppt	2	10
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic acid	PFOA	10/20/2021	13	ppt	2	10
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorotetradecanoic acid	PFTeDA	10/20/2021	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorotridecanoic acid	PFTrDA	10/20/2021	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluoroundecanoic acid	PFUnA	10/20/2021	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 522	1,4-Dioxane		10/20/2021	0	ppb	0.07	1
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	NeFOSAA	10/20/2021	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	10/20/2021	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorobutanesulfonic acid	PFBS	10/20/2021	8.2	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorodecanoic acid	PFDA	10/20/2021	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorododecanoic acid	PFDoA	10/20/2021	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluoroheptanoic acid	PFHpA	10/20/2021	3	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorohexanesulfonic acid	PFHxS	10/20/2021	2.6	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorohexanoic acid	PFHxA	10/20/2021	5	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic acid	PFNA	10/20/2021	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanesulfonic acid	PFOS	10/20/2021	15	ppt	2	10
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic acid	PFOA	10/20/2021	11	ppt	2	10
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorotetradecanoic acid	PFTeDA	10/20/2021	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorotridecanoic acid	PFTrDA	10/20/2021	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluoroundecanoic acid	PFUnA	10/20/2021	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 522	1,4-Dioxane		1/20/2022	0	ppb	0.07	1
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	NeFOSAA	1/20/2022	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	1/20/2022	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorobutanesulfonic acid	PFBS	1/20/2022	6	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorodecanoic acid	PFDA	1/20/2022	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorododecanoic acid	PFDoA	1/20/2022	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluoroheptanoic acid	PFHpA	1/20/2022	3.2	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorohexanesulfonic acid	PFHxS	1/20/2022	2	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorohexanoic acid	PFHxA	1/20/2022	6.4	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic acid	PFNA	1/20/2022	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanesulfonic acid	PFOS	1/20/2022	11	ppt	2	10
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic acid	PFOA	1/20/2022	10	ppt	2	10
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorotetradecanoic acid	PFTeDA	1/20/2022	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorotridecanoic acid	PFTrDA	1/20/2022	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluoroundecanoic acid	PFUnA	1/20/2022	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 522	1,4-Dioxane		1/20/2022	0	ppb	0.07	1
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	NeFOSAA	1/20/2022	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	1/20/2022	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorobutanesulfonic acid	PFBS	1/20/2022	86	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorodecanoic acid	PFDA	1/20/2022	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorododecanoic acid	PFDoA	1/20/2022	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluoroheptanoic acid	PFHpA	1/20/2022	2.4	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorohexanesulfonic acid	PFHxS	1/20/2022	2.2	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorohexanoic acid	PFHxA	1/20/2022	3.8	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic acid	PFNA	1/20/2022	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanesulfonic acid	PFOS	1/20/2022	13	ppt	2	10
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic acid	PFOA	1/20/2022	8.2	ppt	2	10
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorotetradecanoic acid	PFTeDA	1/20/2022	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorotridecanoic acid	PFTrDA	1/20/2022	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluoroundecanoic acid	PFUnA	1/20/2022	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 522	1,4-Dioxane		4/21/2022	0	ppb	0.07	1
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	NeFOSAA	4/21/2022	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	4/21/2022	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorobutanesulfonic acid	PFBS	4/21/2022	5.8	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorodecanoic acid	PFDA	4/21/2022	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorododecanoic acid	PFDoA	4/21/2022	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluoroheptanoic acid	PFHpA	4/21/2022	3	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorohexanesulfonic acid	PFHxS	4/21/2022	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorohexanoic acid	PFHxA	4/21/2022	6.8	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic acid	PFNA	4/21/2022	0	ppt	2	NA

Sample ID	System	Type	Project	Method	Analyte	Analyte Acronym	Sample Date	Results	Units	MRL	MCL
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanesulfonic acid	PFOS	4/21/2022	9.6	ppt	2	10
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic acid	PFDA	4/21/2022	11	ppt	2	10
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorotetradecanoic acid	PFtDA	4/21/2022	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorotridecanoic acid	PFTrDA	4/21/2022	0	ppt	2	NA
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluoroundecanoic acid	PFUnA	4/21/2022	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 522	1,4-Dioxane		4/21/2022	0	ppb	0.07	1
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	NtEFOSAA	4/21/2022	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	4/21/2022	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorobutanesulfonic acid	PFBS	4/21/2022	7	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorodecanoic acid	PFDA	4/21/2022	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorododecanoic acid	PFDoA	4/21/2022	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluoroheptanoic acid	PFHpA	4/21/2022	2.3	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorohexanesulfonic acid	PFHxS	4/21/2022	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorohexanoic acid	PFHxA	4/21/2022	4.9	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorononanoic acid	PFNA	4/21/2022	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanesulfonic acid	PFOS	4/21/2022	12	ppt	2	10
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic acid	PFDA	4/21/2022	8.6	ppt	2	10
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorotetradecanoic acid	PFtDA	4/21/2022	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorotridecanoic acid	PFTrDA	4/21/2022	0	ppt	2	NA
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluoroundecanoic acid	PFUnA	4/21/2022	0	ppt	2	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 522	1,4-Dioxane		8/16/2022	0	ug/L	0.07	1
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	11-Chlorooctasulfoaro-3-oxaundecane-1-sulfonic acid	11CI-PF30UdS	8/16/2022	0	ppt	2	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	8/16/2022	0	ppt	2	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	8/16/2022	0	ppt	2	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	8/16/2022	0	ppt	2	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	8/16/2022	0	ppt	2	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid	9CI-PF30NS	8/16/2022	0	ppt	2	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	8/16/2022	0	ppt	2	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Nonafluoro-3,6-dioxahexanoic acid	NFDHA	8/16/2022	0	ppt	2	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro-3-methoxypropanoic acid	PFMPA	8/16/2022	0	ppt	2	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBa	8/16/2022	0	ppt	2	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro(2-ethoxyethane)sulfonic acid	PFEEsA	8/16/2022	0	ppt	2	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorobutanesulfonic acid	PFBS	8/16/2022	7.1	ppt	2	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorobutanoic acid	PFBA	8/16/2022	3.4	ppt	2	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorodecanoic acid	PFDA	8/16/2022	0	ppt	2	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorododecanoic acid	PFDoA	8/16/2022	0	ppt	2	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroheptanesulfonic acid	PFHpS	8/16/2022	0	ppt	2	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroheptanoic acid	PFHpA	8/16/2022	2.4	ppt	2	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorohexanesulfonic acid	PFHxS	8/16/2022	0	ppt	2	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorohexanoic acid	PFHxA	8/16/2022	5	ppt	2	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorononanoic acid	PFNA	8/16/2022	0	ppt	2	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanesulfonic acid	PFOS	8/16/2022	9.3	ppt	2	10
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic acid	PFDA	8/16/2022	8.8	ppt	2	10
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoropentanesulfonic acid	PFPeS	8/16/2022	0	ppt	2	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoropentanoic acid	PFPeA	8/16/2022	5.2	ppt	2	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroundecanoic acid	PFUnA	8/16/2022	0	ppt	2	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	11-Chlorooctasulfoaro-3-oxaundecane-1-sulfonic acid	11CI-PF30UdS	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid	9CI-PF30NS	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	N-ethylperfluorooctanesulfonamidoacetic acid	NtEFOSAA	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	N-methylperfluorooctanesulfonamidoacetic acid	NMeFOSAA	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorobutanesulfonic acid	PFBS	8/16/2022	7.8	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorodecanoic acid	PFDA	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorododecanoic acid	PFDoA	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluoroheptanoic acid	PFHpA	8/16/2022	2.7	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorohexanesulfonic acid	PFHxS	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorohexanoic acid	PFHxA	8/16/2022	5.1	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorononanoic acid	PFNA	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorooctanesulfonic acid	PFOS	8/16/2022	11	ppt	1.9	10
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorooctanoic acid	PFDA	8/16/2022	11	ppt	1.9	10
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorotetradecanoic acid	PFtDA	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorotridecanoic acid	PFTrDA	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluoroundecanoic acid	PFUnA	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 522	1,4-Dioxane		8/16/2022	0	ug/L	0.07	1
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	11-Chlorooctasulfoaro-3-oxaundecane-1-sulfonic acid	11CI-PF30UdS	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid	9CI-PF30NS	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Nonafluoro-3,6-dioxahexanoic acid	NFDHA	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro-3-methoxypropanoic acid	PFMPA	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBa	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro(2-ethoxyethane)sulfonic acid	PFEEsA	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorobutanesulfonic acid	PFBS	8/16/2022	19	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorobutanoic acid	PFBA	8/16/2022	6.9	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorodecanoic acid	PFDA	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorododecanoic acid	PFDoA	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroheptanesulfonic acid	PFHpS	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroheptanoic acid	PFHpA	8/16/2022	4.1	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorohexanesulfonic acid	PFHxS	8/16/2022	2.5	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorohexanoic acid	PFHxA	8/16/2022	8.1	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorononanoic acid	PFNA	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanesulfonic acid	PFOS	8/16/2022	18	ppt	1.9	10
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic acid	PFDA	8/16/2022	15	ppt	1.9	10
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoropentanesulfonic acid	PFPeS	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoropentanoic acid	PFPeA	8/16/2022	9.6	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroundecanoic acid	PFUnA	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	11-Chlorooctasulfoaro-3-oxaundecane-1-sulfonic acid	11CI-PF30UdS	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid	9CI-PF30NS	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	N-ethylperfluorooctanesulfonamidoacetic acid	NtEFOSAA	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	N-methylperfluorooctanesulfonamidoacetic acid	NMeFOSAA	8/16/2022	20	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorobutanesulfonic acid	PFBS	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorodecanoic acid	PFDA	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorododecanoic acid	PFDoA	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluoroheptanoic acid	PFHpA	8/16/2022	4.6	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorohexanesulfonic acid	PFHxS	8/16/2022	2.7	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorohexanoic acid	PFHxA	8/16/2022	8.1	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorononanoic acid	PFNA	8/16/2022	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorooctanesulfonic acid	PFOS	8/16/2022	20	ppt	1.9	10
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorooctanoic acid	PFDA	8/16/2022	18	ppt	1.9	10

July 6, 2023

4

Sample ID	System	Type	Project	Method	Analyte	Analyte Acronym	Sample Date	Results	Units	MRL	MCL
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorododecanoic acid	PFDoA	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroheptanesulfonic acid	PFHpS	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroheptanoic acid	PFHpA	1/25/2023	4	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorohexanesulfonic acid	PFHxS	1/25/2023	2.2	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorohexanoic acid	PFHxA	1/25/2023	8.2	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorononanoic acid	PFNA	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanesulfonic acid	PFOS	1/25/2023	11	ppt	1.9	10
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic acid	PFOA	1/25/2023	13	ppt	1.9	10
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoropentanesulfonic acid	PFPeS	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoropentanoic acid	PFPeA	1/25/2023	8.9	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroundecanoic acid	PFUnA	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	11-Chloroicosafuoro-3-oxaundecane-1-sulfonic acid	11Cl-PF30uDS	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9Cl-PF30NS	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Hexafluoropropylene Oxide Dimer Acid	HFPD-ADo/GenX	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	N-ethylperfluorooctanesulfonamidoacetic acid	NEtFOSAA	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	N-methylperfluorooctanesulfonamidoacetic acid	NMeFOSAA	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorobutanesulfonic acid	PFBS	1/25/2023	8.2	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorodecanoic acid	PFDA	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorododecanoic acid	PFDoA	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluoroheptanoic acid	PFHpA	1/25/2023	4.6	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorohexanesulfonic acid	PFHxS	1/25/2023	2.1	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorohexanoic acid	PFHxA	1/25/2023	8.2	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorononanoic acid	PFNA	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorooctanesulfonic acid	PFOS	1/25/2023	13	ppt	1.9	10
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorooctanoic acid	PFOA	1/25/2023	15	ppt	1.9	10
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorotetradecanoic acid	PFTeDA	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorotridecanoic acid	PFTrDA	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluoroundecanoic acid	PFUnA	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	11-Chloroicosafuoro-3-oxaundecane-1-sulfonic acid	11Cl-PF30uDS	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9Cl-PF30NS	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Hexafluoropropylene Oxide Dimer Acid	HFPD-ADo/GenX	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Nonafluoro-3,6-dioxahexanoic acid	NFDHA	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro-4-methoxypropanoic acid	PFMPA	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBa	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro(2-ethoxyethane)sulfonic acid	PFEEsA	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorobutanesulfonic acid	PFBS	1/25/2023	9.7	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorobutanoic acid	PFBA	1/25/2023	4.7	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorodecanoic acid	PFDA	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorododecanoic acid	PFDoA	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroheptanesulfonic acid	PFHpS	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroheptanoic acid	PFHpA	1/25/2023	3.4	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorohexanesulfonic acid	PFHxS	1/25/2023	2.1	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorohexanoic acid	PFHxA	1/25/2023	7.1	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorononanoic acid	PFNA	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanesulfonic acid	PFOS	1/25/2023	10	ppt	1.9	10
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic acid	PFOA	1/25/2023	11	ppt	1.9	10
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoropentanesulfonic acid	PFPeS	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoropentanoic acid	PFPeA	1/25/2023	7.5	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroundecanoic acid	PFUnA	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	11-Chloroicosafuoro-3-oxaundecane-1-sulfonic acid	11Cl-PF30uDS	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9Cl-PF30NS	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Hexafluoropropylene Oxide Dimer Acid	HFPD-ADo/GenX	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	N-ethylperfluorooctanesulfonamidoacetic acid	NEtFOSAA	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	N-methylperfluorooctanesulfonamidoacetic acid	NMeFOSAA	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorobutanesulfonic acid	PFBS	1/25/2023	10	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorodecanoic acid	PFDA	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorododecanoic acid	PFDoA	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluoroheptanoic acid	PFHpA	1/25/2023	3.7	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorohexanesulfonic acid	PFHxS	1/25/2023	2	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorohexanoic acid	PFHxA	1/25/2023	6.6	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorononanoic acid	PFNA	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorooctanesulfonic acid	PFOS	1/25/2023	11	ppt	1.9	10
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorooctanoic acid	PFOA	1/25/2023	13	ppt	1.9	10
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorotetradecanoic acid	PFTeDA	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorotridecanoic acid	PFTrDA	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluoroundecanoic acid	PFUnA	1/25/2023	0	ppt	1.9	NA
ARCHER WELL 1	Archer	Compliance	PFAS-DIOXANE	EPA 533	11-Chloroicosafuoro-3-oxaundecane-1-sulfonic acid	11Cl-PF30uDS	4/25/2023	0	ppt	2	NA
ARCHER WELL 1	Archer	Compliance	PFAS-DIOXANE	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	4/25/2023	0	ppt	2	NA
ARCHER WELL 1	Archer	Compliance	PFAS-DIOXANE	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	4/25/2023	0	ppt	2	NA
ARCHER WELL 1	Archer	Compliance	PFAS-DIOXANE	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	4/25/2023	0	ppt	2	NA
ARCHER WELL 1	Archer	Compliance	PFAS-DIOXANE	EPA 533	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	4/25/2023	0	ppt	2	NA
ARCHER WELL 1	Archer	Compliance	PFAS-DIOXANE	EPA 533	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9Cl-PF30NS	4/25/2023	0	ppt	2	NA
ARCHER WELL 1	Archer	Compliance	PFAS-DIOXANE	EPA 533	Hexafluoropropylene Oxide Dimer Acid	HFPD-ADo/GenX	4/25/2023	0	ppt	2	NA
ARCHER WELL 1	Archer	Compliance	PFAS-DIOXANE	EPA 533	Nonafluoro-3,6-dioxahexanoic acid	NFDHA	4/25/2023	0	ppt	2	NA
ARCHER WELL 1	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro(2-ethoxyethane)sulfonic acid	PFEEsA	4/25/2023	0	ppt	2	NA
ARCHER WELL 1	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro-4-methoxypropanoic acid	PFMPA	4/25/2023	0	ppt	2	NA
ARCHER WELL 1	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBa	4/25/2023	0	ppt	2	NA
ARCHER WELL 1	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluorobutanesulfonic acid	PFBS	4/25/2023	6.8	ppt	2	NA
ARCHER WELL 1	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluorobutanoic acid	PFBA	4/25/2023	3.9	ppt	2	NA
ARCHER WELL 1	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluorodecanoic acid	PFDA	4/25/2023	0	ppt	2	NA
ARCHER WELL 1	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluorododecanoic acid	PFDoA	4/25/2023	0	ppt	2	NA
ARCHER WELL 1	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroheptanesulfonic acid	PFHpS	4/25/2023	0	ppt	2	NA
ARCHER WELL 1	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroheptanoic acid	PFHpA	4/25/2023	3.7	ppt	2	NA
ARCHER WELL 1	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluorohexanesulfonic acid	PFHxS	4/25/2023	0	ppt	2	NA
ARCHER WELL 1	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluorohexanoic acid	PFHxA	4/25/2023	7.1	ppt	2	NA
ARCHER WELL 1	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluorononanoic acid	PFNA	4/25/2023	0	ppt	2	NA
ARCHER WELL 1	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanesulfonic acid	PFOS	4/25/2023	12	ppt	2	10
ARCHER WELL 1	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic acid	PFOA	4/25/2023	13	ppt	2	10
ARCHER WELL 1	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluoropentanesulfonic acid	PFPeS	4/25/2023	0	ppt	2	NA
ARCHER WELL 1	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluoropentanoic acid	PFPeA	4/25/2023	7.8	ppt	2	NA
ARCHER WELL 1	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroundecanoic acid	PFUnA	4/25/2023	0	ppt	2	NA
ARCHER WELL 1	Archer	Compliance	PFAS-DIOXANE	EPA 537.1	N-ethylperfluorooctanesulfonamidoacetic acid	NEtFOSAA	4/25/2023	0	ppt	2	NA
ARCHER WELL 1	Archer	Compliance	PFAS-DIOXANE	EPA 537.1	N-methylperfluorooctanesulfonamidoacetic acid	NMeFOSAA	4/25/2023	0	ppt	2	NA
ARCHER WELL 1	Archer	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorotetradecanoic acid	PFTA	4/25/2023	0	ppt	2	NA
ARCHER WELL 1	Archer	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorotridecanoic acid	PFTrDA	4/25/2023	0	ppt	2	NA
ARCHER WELL 2	Archer	Compliance	PFAS-DIOXANE	EPA 533	11-Chloroicosafuoro-3-oxaundecane-1-sulfonic acid	11Cl-PF30uDS	4/25/2023	0	ppt	2	NA
ARCHER WELL 2	Archer	Compliance	PFAS-DIOXANE	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	4/25/2023	0	ppt	2	NA
ARCHER WELL 2	Archer	Compliance	PFAS-DIOXANE	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	4/25/2023	0	ppt	2	NA
ARCHER WELL 2	Archer	Compliance	PFAS-DIOXANE	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	4/25/2023	0	ppt	2	NA

Sample ID	System	Type	Project	Method	Analyte	Analyte Acronym	Sample Date	Results	Units	MRL	MCL
ARCHER WELL 2	Archer	Compliance	PFAS-DIOXANE	EPA 533	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	4/25/2023	0	ppt	2	NA
ARCHER WELL 2	Archer	Compliance	PFAS-DIOXANE	EPA 533	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9Cl-PF3ONS	4/25/2023	0	ppt	2	NA
ARCHER WELL 2	Archer	Compliance	PFAS-DIOXANE	EPA 533	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	4/25/2023	0	ppt	2	NA
ARCHER WELL 2	Archer	Compliance	PFAS-DIOXANE	EPA 533	Nonafluoro-3,6-dioxahexanoic acid	NFDHA	4/25/2023	0	ppt	2	NA
ARCHER WELL 2	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro(2-ethoxyethane)sulfonic acid	PFEESA	4/25/2023	0	ppt	2	NA
ARCHER WELL 2	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro-3-methoxypropanoic acid	PFMPA	4/25/2023	0	ppt	2	NA
ARCHER WELL 2	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBA	4/25/2023	0	ppt	2	NA
ARCHER WELL 2	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluorobutanesulfonic acid	PFBS	4/25/2023	9.3	ppt	2	NA
ARCHER WELL 2	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluorobutanoic acid	PFBA	4/25/2023	3.2	ppt	2	NA
ARCHER WELL 2	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluorodecanoic acid	PFDA	4/25/2023	0	ppt	2	NA
ARCHER WELL 2	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluorododecanoic acid	PFDoA	4/25/2023	0	ppt	2	NA
ARCHER WELL 2	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroheptanesulfonic acid	PFHpS	4/25/2023	0	ppt	2	NA
ARCHER WELL 2	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroheptanoic acid	PFHpA	4/25/2023	2.4	ppt	2	NA
ARCHER WELL 2	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluorohexanesulfonic acid	PFHxS	4/25/2023	2	ppt	2	NA
ARCHER WELL 2	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluorohexanoic acid	PFHxA	4/25/2023	4.9	ppt	2	NA
ARCHER WELL 2	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluorononanoic acid	PFNA	4/25/2023	0	ppt	2	NA
ARCHER WELL 2	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanesulfonic acid	PFOS	4/25/2023	11	ppt	2	10
ARCHER WELL 2	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic acid	PFOA	4/25/2023	8.3	ppt	2	10
ARCHER WELL 2	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluoropentanesulfonic acid	PFPeS	4/25/2023	0	ppt	2	NA
ARCHER WELL 2	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluoropentanoic acid	PFPeA	4/25/2023	4.9	ppt	2	NA
ARCHER WELL 2	Archer	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroundecanoic acid	PFUnA	4/25/2023	0	ppt	2	NA
ARCHER WELL 2	Archer	Compliance	PFAS-DIOXANE	EPA 537.1	N-ethylperfluorooctanesulfonamidoacetic acid	NEtFOSAA	4/25/2023	0	ppt	2	NA
ARCHER WELL 2	Archer	Compliance	PFAS-DIOXANE	EPA 537.1	N-methylperfluorooctanesulfonamidoacetic acid	NMeFOSAA	4/25/2023	0	ppt	2	NA
ARCHER WELL 2	Archer	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorotetradecanoic acid	PFTA	4/25/2023	0	ppt	2	NA
ARCHER WELL 2	Archer	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorotridecanoic acid	PFTDA	4/25/2023	0	ppt	2	NA

List of Abbreviations
MRL = Method Reporting Limit, the lowest level the laboratory analysis method can reliably detect
MCL = Maximum Contaminant Level, the regulatory limit set by the State
NA = Not applicable
ND = Not detected
ppt = parts per trillion
ppb = parts per billion
Analytical results depicted from 9/2020 through 6/2022 are EPA Method 537. Analytical results from 7/2022 to date are EPA Method 533.

EPA Method 537.1 data from 7/2022 to date is also included in the table.
Table has been sorted by sample date
All Rockland locations have been added to this supplemental report per NYSDOH Request following Q3 2022
Not all wells sampled within the quarter were operations

*Beginning Q2 2023, Veolia Water New York made the following changes to its PFAS sampling protocol. Method 533 is used to analyze all 25 unique PFAS compounds covered by this Method as indicated on the US EPA, Office of Water, table number MS-140 dated December 2019. Method 537.1 is used to analyze only the 4 additional PFAS compounds not addressed by Method 533 as presented in the same above reference EPA table. Supplemental reports will also reflect this change beginning Q2 2023.
** In Q2 2023 Veolia also began to use Pace in addition to Eurofins to perform some of the Method 533 and 537.1 analysis. Veolia is working on correcting some formatting issues between the two laboratory data sets