

	System	Type	Method	Analyte	Analyte Acronym	Sample Date	Result	Final	Units	MRL	MCL
Chateau Well 3	Forest Park	Compliance	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	NeiFOSAA	10/7/2020	ND	0	ppt	2	NA
Chateau Well 3	Forest Park	Compliance	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	10/7/2020	ND	0	ppt	2	NA
Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluorobutanesulfonic acid	PFBS	10/7/2020	0.0058	5.8	ppt	2	NA
Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluorodecanoic acid	PFDA	10/7/2020	ND	0	ppt	2	NA
Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluorododecanoic acid	PFDoA	10/7/2020	ND	0	ppt	2	NA
Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluoroheptanoic acid	PFHpA	10/7/2020	0.0031	3.1	ppt	2	NA
Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluorohexanoic acid	PFHxA	10/7/2020	0.0071	7.1	ppt	2	NA
Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluorohexanesulfonic acid	PFHxS	10/7/2020	0.0022	2.2	ppt	2	NA
Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluorononanoic acid	PFNA	10/7/2020	ND	0	ppt	2	NA
Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluorooctanoic acid	PFOA	10/7/2020	0.012	12	ppt	2	10
Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluorooctanesulfonic acid	PFOS	10/7/2020	0.007	7	ppt	2	10
Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluorotetradecanoic acid	PFTeDA	10/7/2020	ND	0	ppt	2	NA
Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluorotridecanoic acid	PFTrDA	10/7/2020	ND	0	ppt	2	NA
Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluoroundecanoic acid	PFUnA	10/7/2020	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 522	1,4-Dioxane		10/8/2020	ND	0	ppb	0.07	1
Chateau Well 1	Forest Park	Compliance	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	NeiFOSAA	10/8/2020	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	10/8/2020	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorobutanesulfonic acid	PFBS	10/8/2020	0.0051	5.1	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorodecanoic acid	PFDA	10/8/2020	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorododecanoic acid	PFDoA	10/8/2020	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluoroheptanoic acid	PFHpA	10/8/2020	0.0042	4.2	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorohexanoic acid	PFHxA	10/8/2020	0.0077	7.7	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorohexanesulfonic acid	PFHxS	10/8/2020	0.0028	2.8	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorononanoic acid	PFNA	10/8/2020	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorooctanoic acid	PFOA	10/8/2020	0.014	14	ppt	2	10
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorooctanesulfonic acid	PFOS	10/8/2020	0.012	12	ppt	2	10
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorotetradecanoic acid	PFTeDA	10/8/2020	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorotridecanoic acid	PFTrDA	10/8/2020	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluoroundecanoic acid	PFUnA	10/8/2020	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 522	1,4-Dioxane		10/8/2020	0.085	0.085	ppb	0.07	1
Chateau Well 2	Forest Park	Compliance	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	NeiFOSAA	10/8/2020	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	10/8/2020	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorobutanesulfonic acid	PFBS	10/8/2020	0.004	4	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorodecanoic acid	PFDA	10/8/2020	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorododecanoic acid	PFDoA	10/8/2020	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluoroheptanoic acid	PFHpA	10/8/2020	0.002	2	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorohexanoic acid	PFHxA	10/8/2020	0.0029	2.9	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorohexanesulfonic acid	PFHxS	10/8/2020	0.002	2	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorononanoic acid	PFNA	10/8/2020	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorooctanoic acid	PFOA	10/8/2020	0.0082	8.2	ppt	2	10
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorooctanesulfonic acid	PFOS	10/8/2020	0.0069	6.9	ppt	2	10
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorotetradecanoic acid	PFTeDA	10/8/2020	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorotridecanoic acid	PFTrDA	10/8/2020	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluoroundecanoic acid	PFUnA	10/8/2020	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	NeiFOSAA	10/26/2020	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	10/26/2020	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorobutanesulfonic acid	PFBS	10/26/2020	0.0051	5.1	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorodecanoic acid	PFDA	10/26/2020	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorododecanoic acid	PFDoA	10/26/2020	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluoroheptanoic acid	PFHpA	10/26/2020	0.0039	3.9	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorohexanoic acid	PFHxA	10/26/2020	0.0071	7.1	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorohexanesulfonic acid	PFHxS	10/26/2020	0.0028	2.8	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorononanoic acid	PFNA	10/26/2020	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorooctanoic acid	PFOA	10/26/2020	0.014	14	ppt	2	10
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorooctanesulfonic acid	PFOS	10/26/2020	0.015	15	ppt	2	10
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorotetradecanoic acid	PFTeDA	10/26/2020	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorotridecanoic acid	PFTrDA	10/26/2020	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluoroundecanoic acid	PFUnA	10/26/2020	ND	0	ppt	2	NA
Chateau Well 3	Forest Park	Compliance	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	NeiFOSAA	10/29/2020	ND	0	ppt	2	NA
Chateau Well 3	Forest Park	Compliance	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	10/29/2020	ND	0	ppt	2	NA
Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluorobutanesulfonic acid	PFBS	10/29/2020	0.0041	4.1	ppt	2	NA
Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluorodecanoic acid	PFDA	10/29/2020	ND	0	ppt	2	NA
Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluorododecanoic acid	PFDoA	10/29/2020	ND	0	ppt	2	NA
Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluoroheptanoic acid	PFHpA	10/29/2020	0.002	2	ppt	2	NA
Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluorohexanoic acid	PFHxA	10/29/2020	0.0031	3.1	ppt	2	NA
Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluorohexanesulfonic acid	PFHxS	10/29/2020	ND	0	ppt	2	NA
Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluorononanoic acid	PFNA	10/29/2020	ND	0	ppt	2	NA
Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluorooctanoic acid	PFOA	10/29/2020	0.0076	7.6	ppt	2	10
Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluorooctanesulfonic acid	PFOS	10/29/2020	0.0049	4.9	ppt	2	10
Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluorotetradecanoic acid	PFTeDA	10/29/2020	ND	0	ppt	2	NA
Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluorotridecanoic acid	PFTrDA	10/29/2020	ND	0	ppt	2	NA
Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluoroundecanoic acid	PFUnA	10/29/2020	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 522	1,4-Dioxane		1/28/2021	ND	0	ppb	0.07	1
Chateau Well 1	Forest Park	Compliance	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	NeiFOSAA	1/28/2021	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	1/28/2021	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorobutanesulfonic acid	PFBS	1/28/2021	0.0052	5.2	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorodecanoic acid	PFDA	1/28/2021	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorododecanoic acid	PFDoA	1/28/2021	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluoroheptanoic acid	PFHpA	1/28/2021	0.0029	2.9	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorohexanoic acid	PFHxA	1/28/2021	0.0056	5.6	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorohexanesulfonic acid	PFHxS	1/28/2021	0.0023	2.3	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorononanoic acid	PFNA	1/28/2021	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorooctanoic acid	PFOA	1/28/2021	0.011	11	ppt	2	10
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorooctanesulfonic acid	PFOS	1/28/2021	0.0096	9.6	ppt	2	10
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorotetradecanoic acid	PFTeDA	1/28/2021	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorotridecanoic acid	PFTrDA	1/28/2021	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluoroundecanoic acid	PFUnA	1/28/2021	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 522	1,4-Dioxane		1/28/2021	ND	0	ppb	0.07	1
Chateau Well 2	Forest Park	Compliance	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	NeiFOSAA	1/28/2021	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	1/28/2021	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorobutanesulfonic acid	PFBS	1/28/2021	0.0038	3.8	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorodecanoic acid	PFDA	1/28/2021	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorododecanoic acid	PFDoA	1/28/2021	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluoroheptanoic acid	PFHpA	1/28/2021	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorohexanoic acid	PFHxA	1/28/2021	0.0024	2.4	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorohexanesulfonic acid	PFHxS	1/28/2021	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorononanoic acid	PFNA	1/28/2021	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorooctanoic acid	PFOA	1/28/2021	0.0071	7.1	ppt	2	10
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorooctanesulfonic acid	PFOS	1/28/2021	0.0064	6.4	ppt	2	10
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorotetradecanoic acid	PFTeDA	1/28/2021	ND	0	ppt	2	NA

	System	Type	Metho	Analyte	Analyte Acronym	Sample Date	Result	Final	Units	MRL	MCL	
	Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorotridecanoic acid	PFTrDA	1/28/2021	ND	0	ppt	2	NA
	Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluoroundecanoic acid	PFUnA	1/28/2021	ND	0	ppt	2	NA
	Chateau Well 3	Forest Park	Compliance	EPA 522	1,4-Dioxane		1/28/2021	ND	0	ppb	0.07	1
	Chateau Well 1	Forest Park	Compliance	EPA 522	1,4-Dioxane		4/19/2021	ND	0	ppb	0.07	1
	Chateau Well 1	Forest Park	Compliance	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	NeiFOSAA	4/19/2021	ND	0	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	4/19/2021	ND	0	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorobutanesulfonic acid	PFBS	4/19/2021	0.0059	5.9	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorodecanoic acid	PFDA	4/19/2021	ND	0	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorododecanoic acid	PFDoA	4/19/2021	ND	0	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluoroheptanoic acid	PFHpA	4/19/2021	0.0032	3.2	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorohexanoic acid	PFHxA	4/19/2021	0.0071	7.1	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorohexanesulfonic acid	PFHxS	4/19/2021	0.0026	2.6	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorononanoic acid	PFNA	4/19/2021	ND	0	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorooctanoic acid	PFOA	4/19/2021	0.012	12	ppt	2	10
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorooctanesulfonic acid	PFOS	4/19/2021	0.0099	9.9	ppt	2	10
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorotetradecanoic acid	PFTeDA	4/19/2021	ND	0	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorotridecanoic acid	PFTrDA	4/19/2021	ND	0	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluoroundecanoic acid	PFUnA	4/19/2021	ND	0	ppt	2	NA
	Chateau Well 2	Forest Park	Compliance	EPA 522	1,4-Dioxane		4/19/2021	ND	0	ppb	0.07	1
	Chateau Well 2	Forest Park	Compliance	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	NeiFOSAA	4/19/2021	ND	0	ppt	2	NA
	Chateau Well 2	Forest Park	Compliance	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	4/19/2021	ND	0	ppt	2	NA
	Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorobutanesulfonic acid	PFBS	4/19/2021	0.0043	4.3	ppt	2	NA
	Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorodecanoic acid	PFDA	4/19/2021	ND	0	ppt	2	NA
	Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorododecanoic acid	PFDoA	4/19/2021	ND	0	ppt	2	NA
	Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluoroheptanoic acid	PFHpA	4/19/2021	ND	0	ppt	2	NA
	Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorohexanoic acid	PFHxA	4/19/2021	0.0031	3.1	ppt	2	NA
	Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorohexanesulfonic acid	PFHxS	4/19/2021	ND	0	ppt	2	NA
	Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorononanoic acid	PFNA	4/19/2021	ND	0	ppt	2	NA
	Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorooctanoic acid	PFOA	4/19/2021	0.0077	7.7	ppt	2	10
	Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorooctanesulfonic acid	PFOS	4/19/2021	0.0072	7.2	ppt	2	10
	Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorotetradecanoic acid	PFTeDA	4/19/2021	ND	0	ppt	2	NA
	Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorotridecanoic acid	PFTrDA	4/19/2021	ND	0	ppt	2	NA
	Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluoroundecanoic acid	PFUnA	4/19/2021	ND	0	ppt	2	NA
	Chateau Well 3	Forest Park	Compliance	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	NeiFOSAA	4/21/2021	ND	0	ppt	2	NA
	Chateau Well 3	Forest Park	Compliance	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	4/21/2021	ND	0	ppt	2	NA
	Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluorobutanesulfonic acid	PFBS	4/21/2021	6.1	ppt	2	NA	
	Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluorodecanoic acid	PFDA	4/21/2021	0	ppt	2	NA	
	Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluorododecanoic acid	PFDoA	4/21/2021	0	ppt	2	NA	
	Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluoroheptanoic acid	PFHpA	4/21/2021	3.2	ppt	2	NA	
	Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluorohexanoic acid	PFHxA	4/21/2021	5.5	ppt	2	NA	
	Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluorohexanesulfonic acid	PFHxS	4/21/2021	2.7	ppt	2	NA	
	Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluorononanoic acid	PFNA	4/21/2021	ND	0	ppt	2	NA
	Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluorooctanoic acid	PFOA	4/21/2021	12	ppt	2	10	
	Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluorooctanesulfonic acid	PFOS	4/21/2021	10	ppt	2	10	
	Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluorotetradecanoic acid	PFTeDA	4/21/2021	0	ppt	2	NA	
	Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluorotridecanoic acid	PFTrDA	4/21/2021	0	ppt	2	NA	
	Chateau Well 3	Forest Park	Compliance	EPA 537	Perfluoroundecanoic acid	PFUnA	4/21/2021	0	ppt	2	NA	
	Chateau Well 3	Forest Park	Compliance	EPAS22	1,4-Dioxane		4/21/2021	0	ppb	0.07	1	
	Chateau Well 1	Forest Park	Compliance	EPA 522	1,4-Dioxane		7/21/2021	ND	0	ppb	0.07	1
	Chateau Well 1	Forest Park	Compliance	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	NeiFOSAA	7/21/2021	ND	0	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	7/21/2021	ND	0	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorobutanesulfonic acid	PFBS	7/21/2021	0.0054	5.4	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorodecanoic acid	PFDA	7/21/2021	ND	0	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorododecanoic acid	PFDoA	7/21/2021	ND	0	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluoroheptanoic acid	PFHpA	7/21/2021	0.0034	3.4	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorohexanoic acid	PFHxA	7/21/2021	0.0077	7.7	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorohexanesulfonic acid	PFHxS	7/21/2021	0.0022	2.2	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorononanoic acid	PFNA	7/21/2021	ND	0	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorooctanoic acid	PFOA	7/21/2021	0.011	11	ppt	2	10
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorooctanesulfonic acid	PFOS	7/21/2021	0.0098	9.8	ppt	2	10
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorotetradecanoic acid	PFTeDA	7/21/2021	ND	0	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorotridecanoic acid	PFTrDA	7/21/2021	ND	0	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluoroundecanoic acid	PFUnA	7/21/2021	ND	0	ppt	2	NA
	Chateau Well 2	Forest Park	Compliance	EPA 522	1,4-Dioxane		7/21/2021	ND	0	ppb	0.07	1
	Chateau Well 2	Forest Park	Compliance	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	NeiFOSAA	7/21/2021	ND	0	ppt	2	NA
	Chateau Well 2	Forest Park	Compliance	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	7/21/2021	ND	0	ppt	2	NA
	Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorobutanesulfonic acid	PFBS	7/21/2021	0.0041	4.1	ppt	2	NA
	Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorodecanoic acid	PFDA	7/21/2021	ND	0	ppt	2	NA
	Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorododecanoic acid	PFDoA	7/21/2021	ND	0	ppt	2	NA
	Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluoroheptanoic acid	PFHpA	7/21/2021	ND	0	ppt	2	NA
	Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorohexanoic acid	PFHxA	7/21/2021	0.0028	2.8	ppt	2	NA
	Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorohexanesulfonic acid	PFHxS	7/21/2021	ND	0	ppt	2	NA
	Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorononanoic acid	PFNA	7/21/2021	ND	0	ppt	2	NA
	Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorooctanoic acid	PFOA	7/21/2021	0.0076	7.6	ppt	2	10
	Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorooctanesulfonic acid	PFOS	7/21/2021	0.0067	6.7	ppt	2	10
	Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorotetradecanoic acid	PFTeDA	7/21/2021	ND	0	ppt	2	NA
	Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorotridecanoic acid	PFTrDA	7/21/2021	ND	0	ppt	2	NA
	Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluoroundecanoic acid	PFUnA	7/21/2021	ND	0	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 522	1,4-Dioxane		10/20/2021	ND	0	ppb	0.07	1
	Chateau Well 1	Forest Park	Compliance	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	NeiFOSAA	10/20/2021	ND	0	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	10/20/2021	ND	0	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorobutanesulfonic acid	PFBS	10/20/2021	0.0062	6.2	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorodecanoic acid	PFDA	10/20/2021	ND	0	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorododecanoic acid	PFDoA	10/20/2021	ND	0	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluoroheptanoic acid	PFHpA	10/20/2021	0.004	4	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorohexanoic acid	PFHxA	10/20/2021	0.008	8	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorohexanesulfonic acid	PFHxS	10/20/2021	0.0024	2.4	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorononanoic acid	PFNA	10/20/2021	ND	0	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorooctanoic acid	PFOA	10/20/2021	0.013	13	ppt	2	10
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorooctanesulfonic acid	PFOS	10/20/2021	0.011	11	ppt	2	10
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorotetradecanoic acid	PFTeDA	10/20/2021	ND	0	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorotridecanoic acid	PFTrDA	10/20/2021	ND	0	ppt	2	NA
	Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluoroundecanoic acid	PFUnA	10/20/2021	ND	0	ppt	2	NA
	Chateau Well 2	Forest Park	Compliance	EPA 522	1,4-Dioxane		10/20/2021	ND	0	ppb	0.07	1
	Chateau Well 2	Forest Park	Compliance	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	NeiFOSAA	10/20/2021	ND	0	ppt	2	NA
	Chateau Well 2	Forest Park	Compliance	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	10/20/2021	ND	0	ppt	2	NA
	Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorobutanesulfonic acid	PFBS	10/20/2021	0.0047	4.7	ppt	2	NA
	Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorodecanoic acid	PFDA	10/20/2021	ND	0	ppt	2	NA
	Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorododecanoic acid	PFDoA	10/20/2021	ND	0	ppt	2	NA

	System	Type	Method	Analyte	Analyte Acronym	Sample Date	Result	Final	Units	MRL	MCL
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorooheptanoic acid	PFHpA	10/20/2021	0.0022	2.2	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorohexanoic acid	PFHxA	10/20/2021	0.0035	3.5	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorohexanesulfonic acid	PFHxS	10/20/2021	0.002	2	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorononanoic acid	PFNA	10/20/2021	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorooctanoic acid	PFOA	10/20/2021	0.0083	8.3	ppt	2	10
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorooctanesulfonic acid	PFOS	10/20/2021	0.0082	8.2	ppt	2	10
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorotetradecanoic acid	PFTeDA	10/20/2021	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorotridecanoic acid	PFTrDA	10/20/2021	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluoroundecanoic acid	PFUnA	10/20/2021	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 522	1,4-Dioxane		1/20/2022	ND	0	ppb	0.07	1
Chateau Well 1	Forest Park	Compliance	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	NEtFOSAA	1/20/2022	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	1/20/2022	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorobutanesulfonic acid	PFBS	1/20/2022	0.0059	5.9	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorodecanoic acid	PFDA	1/20/2022	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorododecanoic acid	PFDoA	1/20/2022	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluoroheptanoic acid	PFHpA	1/20/2022	0.0037	3.7	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorohexanoic acid	PFHxA	1/20/2022	0.0076	7.6	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorohexanesulfonic acid	PFHxS	1/20/2022	0.0023	2.3	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorononanoic acid	PFNA	1/20/2022	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorooctanoic acid	PFOA	1/20/2022	0.011	11	ppt	2	10
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorooctanesulfonic acid	PFOS	1/20/2022	0.011	11	ppt	2	10
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorotetradecanoic acid	PFTeDA	1/20/2022	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorotridecanoic acid	PFTrDA	1/20/2022	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluoroundecanoic acid	PFUnA	1/20/2022	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 522	1,4-Dioxane		1/20/2022	ND	0	ppb	0.07	1
Chateau Well 2	Forest Park	Compliance	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	NEtFOSAA	1/20/2022	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	1/20/2022	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorobutanesulfonic acid	PFBS	1/20/2022	0.0047	4.7	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorodecanoic acid	PFDA	1/20/2022	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorododecanoic acid	PFDoA	1/20/2022	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluoroheptanoic acid	PFHpA	1/20/2022	0.0028	2.8	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorohexanoic acid	PFHxA	1/20/2022	0.0048	4.8	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorohexanesulfonic acid	PFHxS	1/20/2022	0.0021	2.1	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorononanoic acid	PFNA	1/20/2022	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorooctanoic acid	PFOA	1/20/2022	0.0096	9.6	ppt	2	10
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorooctanesulfonic acid	PFOS	1/20/2022	0.0097	9.7	ppt	2	10
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorotetradecanoic acid	PFTeDA	1/20/2022	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorotridecanoic acid	PFTrDA	1/20/2022	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluoroundecanoic acid	PFUnA	1/20/2022	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 522	1,4-Dioxane		4/21/2022	ND	0	ppb	0.07	1
Chateau Well 1	Forest Park	Compliance	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	NEtFOSAA	4/21/2022	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	4/21/2022	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorobutanesulfonic acid	PFBS	4/21/2022	0.0068	6.8	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorodecanoic acid	PFDA	4/21/2022	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorododecanoic acid	PFDoA	4/21/2022	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluoroheptanoic acid	PFHpA	4/21/2022	0.0036	3.6	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorohexanoic acid	PFHxA	4/21/2022	0.0085	8.5	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorohexanesulfonic acid	PFHxS	4/21/2022	0.002	2	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorononanoic acid	PFNA	4/21/2022	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorooctanoic acid	PFOA	4/21/2022	0.012	12	ppt	2	10
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorooctanesulfonic acid	PFOS	4/21/2022	0.01	10	ppt	2	10
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorotetradecanoic acid	PFTeDA	4/21/2022	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluorotridecanoic acid	PFTrDA	4/21/2022	ND	0	ppt	2	NA
Chateau Well 1	Forest Park	Compliance	EPA 537	Perfluoroundecanoic acid	PFUnA	4/21/2022	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 522	1,4-Dioxane		4/21/2022	ND	0	ppb	0.07	1
Chateau Well 2	Forest Park	Compliance	EPA 537	N-ethyl Perfluorooctanesulfonamidoacetic acid	NEtFOSAA	4/21/2022	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	4/21/2022	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorobutanesulfonic acid	PFBS	4/21/2022	0.0054	5.4	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorodecanoic acid	PFDA	4/21/2022	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorododecanoic acid	PFDoA	4/21/2022	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluoroheptanoic acid	PFHpA	4/21/2022	0.003	3	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorohexanoic acid	PFHxA	4/21/2022	0.006	6	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorohexanesulfonic acid	PFHxS	4/21/2022	0.002	2	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorononanoic acid	PFNA	4/21/2022	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorooctanoic acid	PFOA	4/21/2022	0.011	11	ppt	2	10
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorooctanesulfonic acid	PFOS	4/21/2022	0.0097	9.7	ppt	2	10
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorotetradecanoic acid	PFTeDA	4/21/2022	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorotridecanoic acid	PFTrDA	4/21/2022	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluoroundecanoic acid	PFUnA	4/21/2022	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 522	1,4-Dioxane		6/7/2022	ND	0	ppb	1	1
Chateau Well 2	Forest Park	Compliance	EPA 537	N-ethylperfluorooctanesulfonamidoacetic acid		6/7/2022	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	N-methylperfluorooctanesulfonamidoacetic acid		6/7/2022	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorobutanesulfonic acid	PFBS	6/7/2022	4.6	4.6	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorodecanoic acid	PFDA	6/7/2022	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorododecanoic acid	PFDoA	6/7/2022	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluoroheptanoic acid	PFHpA	6/7/2022	2.8	2.8	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorohexanoic acid	PFHxA	6/7/2022	4.2	4.2	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorohexanesulfonic acid	PFHxS	6/7/2022	2	2	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorononanoic acid	PFNA	6/7/2022	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorooctanoic acid	PFOA	6/7/2022	8.8	8.8	ppt	2	10
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorooctanesulfonic acid	PFOS	6/7/2022	8.4	8.4	ppt	2	10
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorotetradecanoic acid	PFTeDA	6/7/2022	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorotridecanoic acid	PFTrDA	6/7/2022	ND	0	ppt	2	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluoroundecanoic acid	PFUnA	6/7/2022	ND	0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 522	1,4-Dioxane		8/16/2022	0	0	ug/L	0.07	1
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	11-Chloroicosadecafluoro-3-oxadecane-1-sulfonic acid	11CI-PF30uDS	8/16/2022	0	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid	9CI-PF3ONS	8/16/2022	0	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	8/16/2022	0	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	8/16/2022	0	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	N-ethylperfluorooctanesulfonamidoacetic acid	NEtFOSAA	8/16/2022	0	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	N-methylperfluorooctanesulfonamidoacetic acid	NMeFOSAA	8/16/2022	0	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorobutanesulfonic acid	PFBS	8/16/2022	6	6	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorodecanoic acid	PFDA	8/16/2022	0	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorododecanoic acid	PFDoA	8/16/2022	0	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluoroheptanoic acid	PFHpA	8/16/2022	4.6	4.6	ppt	1.9	NA

	System	Type	Method	Analyte	Analyte Acronym	Sample Date	Result	Final	Units	MRL	MCL
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorohexanoic acid	PFHxA	8/16/2022		8.3	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorohexanesulfonic acid	PFHxS	8/16/2022		2.4	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorononanoic acid	PFNA	8/16/2022		0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorooctanoic acid	PFOA	8/16/2022		17	ppt	1.9	10
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorooctanesulfonic acid	PFOS	8/16/2022		16	ppt	1.9	10
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorotetradecanoic acid	PFTeDA	8/16/2022		0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorotridecanoic acid	PFTrDA	8/16/2022		0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluoroundecanoic acid	PFUnA	8/16/2022		0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 522	1,4-Dioxane		8/16/2022		0	ug/L	0.07	1
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	11-Chloroicosafuoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	8/16/2022		0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9CI-PF3ONS	8/16/2022		0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	8/16/2022		0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	8/16/2022		0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	N-ethylperfluorooctanesulfonamidoacetic acid	NEtFOSAA	8/16/2022		0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	N-methylperfluorooctanesulfonamidoacetic acid	NMeFOSAA	8/16/2022		0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorobutanesulfonic acid	PFBS	8/16/2022		5.1	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorodecanoic acid	PFDA	8/16/2022		0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorododecanoic acid	PFDoA	8/16/2022		0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluoroheptanoic acid	PFHpA	8/16/2022		3	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorohexanoic acid	PFHxA	8/16/2022		4.4	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorohexanesulfonic acid	PFHxS	8/16/2022		2.1	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorononanoic acid	PFNA	8/16/2022		0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorooctanoic acid	PFOA	8/16/2022		12	ppt	1.9	10
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorooctanesulfonic acid	PFOS	8/16/2022		11	ppt	1.9	10
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorotetradecanoic acid	PFTeDA	8/16/2022		0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorotridecanoic acid	PFTrDA	8/16/2022		0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluoroundecanoic acid	PFUnA	8/16/2022		0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	11-Chloroicosafuoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	9/14/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	9/14/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	9/14/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	9/14/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9CI-PF3ONS	9/14/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	9/14/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	9/14/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Nonafluoro-3,6-dioxaheptanoic acid	NFDHA	9/14/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorobutanoic acid	PFBA	9/14/2022		7.3	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorobutanesulfonic acid	PFBS	9/14/2022		5.4	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorodecanoic acid	PFDA	9/14/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorododecanoic acid	PFDoA	9/14/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoro(2-ethoxyethane)sulfonic acid	PFEESA	9/14/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoroheptanoic acid	PFHpA	9/14/2022		4.4	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoroheptanesulfonic acid	PFHpS	9/14/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorohexanoic acid	PFHxA	9/14/2022		8	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorohexanesulfonic acid	PFHxS	9/14/2022		2.2	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBA	9/14/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid	PFMPA	9/14/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorononanoic acid	PFNA	9/14/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorooctanoic acid	PFOA	9/14/2022		13	ppt	2	10
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorooctanesulfonic acid	PFOS	9/14/2022		14	ppt	2	10
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoropentanoic acid	PFPeA	9/14/2022		9.4	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoropentanesulfonic acid	PFPeS	9/14/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoroundecanoic acid	PFUnA	9/14/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	11-Chloroicosafuoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	9/14/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	9/14/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	9/14/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	9/14/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9CI-PF3ONS	9/14/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	9/14/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	9/14/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Nonafluoro-3,6-dioxaheptanoic acid	NFDHA	9/14/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorobutanoic acid	PFBA	9/14/2022		5	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorobutanesulfonic acid	PFBS	9/14/2022		4.7	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorodecanoic acid	PFDA	9/14/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorododecanoic acid	PFDoA	9/14/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoro(2-ethoxyethane)sulfonic acid	PFEESA	9/14/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoroheptanoic acid	PFHpA	9/14/2022		2.9	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoroheptanesulfonic acid	PFHpS	9/14/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorohexanoic acid	PFHxA	9/14/2022		3.5	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorohexanesulfonic acid	PFHxS	9/14/2022		2	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBA	9/14/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid	PFMPA	9/14/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorononanoic acid	PFNA	9/14/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorooctanoic acid	PFOA	9/14/2022		8.4	ppt	2	10
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorooctanesulfonic acid	PFOS	9/14/2022		9	ppt	2	10
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoropentanoic acid	PFPeA	9/14/2022		4.8	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoropentanesulfonic acid	PFPeS	9/14/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoroundecanoic acid	PFUnA	9/14/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 522	1,4-Dioxane		10/24/2022		0	ug/L	0.07	1
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	11-Chloroicosafuoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	10/24/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	10/24/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	10/24/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	10/24/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9CI-PF3ONS	10/24/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	10/24/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	10/24/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Nonafluoro-3,6-dioxaheptanoic acid	NFDHA	10/24/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorobutanoic acid	PFBA	10/24/2022		5	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorobutanesulfonic acid	PFBS	10/24/2022		4.3	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorodecanoic acid	PFDA	10/24/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorododecanoic acid	PFDoA	10/24/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoro(2-ethoxyethane)sulfonic acid	PFEESA	10/24/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoroheptanoic acid	PFHpA	10/24/2022		2.4	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoroheptanesulfonic acid	PFHpS	10/24/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorohexanoic acid	PFHxA	10/24/2022		3.5	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorohexanesulfonic acid	PFHxS	10/24/2022		0	ppt	2	NA

	System	Type	Method	Analyte	Analyte Acronym	Sample Date	Result	Final	Units	MRL	MCL
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBA	10/24/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid	PFMPA	10/24/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorononanoic acid	PFNA	10/24/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorooctanoic acid	PFOA	10/24/2022		8.3	ppt	2	10
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorooctanesulfonic acid	PFOS	10/24/2022		8.5	ppt	2	10
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoropentanoic acid	PFPeA	10/24/2022		5.1	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoropentanesulfonic acid	PFPeS	10/24/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoroundecanoic acid	PFUnA	10/24/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	11-Chloroicosafuoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	10/24/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9CI-PF3ONS	10/24/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	10/24/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	10/24/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	N-ethylperfluorooctanesulfonamidoacetic acid	NEtFOSAA	10/24/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	N-methylperfluorooctanesulfonamidoacetic acid	NMeFOSAA	10/24/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorobutanesulfonic acid	PFBS	10/24/2022		5.3	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorodecanoic acid	PFDA	10/24/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorododecanoic acid	PFDoA	10/24/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluoroheptanoic acid	PFHpA	10/24/2022		4.5	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorohexanoic acid	PFHxA	10/24/2022		8.8	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorohexanesulfonic acid	PFHxS	10/24/2022		2.3	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorononanoic acid	PFNA	10/24/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorooctanoic acid	PFOA	10/24/2022		14	ppt	2	10
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorooctanesulfonic acid	PFOS	10/24/2022		12	ppt	2	10
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorotetradecanoic acid	PFTA	10/24/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorotridecanoic acid	PFTriDA	10/24/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluoroundecanoic acid	PFUnA	10/24/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 522	1,4-Dioxane		10/24/2022		0.069	ug/L	0.069	1
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	11-Chloroicosafuoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	10/24/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9CI-PF3ONS	10/24/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	10/24/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	10/24/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	N-ethylperfluorooctanesulfonamidoacetic acid	NEtFOSAA	10/24/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	N-methylperfluorooctanesulfonamidoacetic acid	NMeFOSAA	10/24/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorobutanesulfonic acid	PFBS	10/24/2022		4.6	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorodecanoic acid	PFDA	10/24/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorododecanoic acid	PFDoA	10/24/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluoroheptanoic acid	PFHpA	10/24/2022		2.6	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorohexanoic acid	PFHxA	10/24/2022		4.6	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorohexanesulfonic acid	PFHxS	10/24/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorononanoic acid	PFNA	10/24/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorooctanoic acid	PFOA	10/24/2022		9.1	ppt	2	10
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorooctanesulfonic acid	PFOS	10/24/2022		7.7	ppt	2	10
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorotetradecanoic acid	PFTA	10/24/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorotridecanoic acid	PFTriDA	10/24/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluoroundecanoic acid	PFUnA	10/24/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	11-Chloroicosafuoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	11/22/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	11/22/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	11/22/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	11/22/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9CI-PF3ONS	11/22/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	11/22/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	11/22/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Nonafluoro-3,6-dioxahexanoic acid	NFDHA	11/22/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorobutanoic acid	PFBA	11/22/2022		6	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorobutanesulfonic acid	PFBS	11/22/2022		4.7	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorodecanoic acid	PFDA	11/22/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorododecanoic acid	PFDoA	11/22/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoro(2-ethoxyethane)sulfonic acid	PFEESA	11/22/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoroheptanoic acid	PFHpA	11/22/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoroheptanesulfonic acid	PFHpS	11/22/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorohexanoic acid	PFHxA	11/22/2022		2.9	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorohexanesulfonic acid	PFHxS	11/22/2022		2	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBA	11/22/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid	PFMPA	11/22/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorononanoic acid	PFNA	11/22/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorooctanoic acid	PFOA	11/22/2022		7.7	ppt	2	10
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorooctanesulfonic acid	PFOS	11/22/2022		8.2	ppt	2	10
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoropentanoic acid	PFPeA	11/22/2022		4.3	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoropentanesulfonic acid	PFPeS	11/22/2022		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoroundecanoic acid	PFUnA	11/22/2022		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 522	1,4-Dioxane		1/25/2023		0	ug/L	0.071	1
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	11-Chloroicosafuoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	1/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	1/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	1/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	1/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9CI-PF3ONS	1/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	1/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Nonafluoro-3,6-dioxahexanoic acid	NFDHA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorobutanoic acid	PFBA	1/25/2023		6.5	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorobutanesulfonic acid	PFBS	1/25/2023		5.2	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorodecanoic acid	PFDA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorododecanoic acid	PFDoA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoro(2-ethoxyethane)sulfonic acid	PFEESA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoroheptanoic acid	PFHpA	1/25/2023		4.3	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoroheptanesulfonic acid	PFHpS	1/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorohexanoic acid	PFHxA	1/25/2023		8.4	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorohexanesulfonic acid	PFHxS	1/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid	PFMPA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorononanoic acid	PFNA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorooctanoic acid	PFOA	1/25/2023		12	ppt	2	10
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorooctanesulfonic acid	PFOS	1/25/2023		12	ppt	2	10
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoropentanoic acid	PFPeA	1/25/2023		10	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoropentanesulfonic acid	PFPeS	1/25/2023		0	ppt	2	NA

	System	Type	Method	Analyte	Analyte Acronym	Sample Date	Result	Final	Units	MRL	MCL
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoroundecanoic acid	PFUnA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	11-Chloroicosafuoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	1/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9CI-PF3ONS	1/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	1/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	N-ethylperfluorooctanesulfonamidoacetic acid	NEtFOSAA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	N-methylperfluorooctanesulfonamidoacetic acid	NMeFOSAA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorobutanesulfonic acid	PFBS	1/25/2023		6	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorodecanoic acid	PFDA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorododecanoic acid	PFDoA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluoroheptanoic acid	PFHpA	1/25/2023		5.1	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorohexanoic acid	PFHxA	1/25/2023		9	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorohexanesulfonic acid	PFHxS	1/25/2023		2.3	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorononanoic acid	PFNA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorooctanoic acid	PFOA	1/25/2023		14	ppt	2	10
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorooctanesulfonic acid	PFOS	1/25/2023		13	ppt	2	10
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorotetradecanoic acid	PFTA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorotridecanoic acid	PFTrDA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluoroundecanoic acid	PFUnA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 522	1,4-Dioxane		1/25/2023		0	ug/L	0.069	1
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	11-Chloroicosafuoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9CI-PF3ONS	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Nonafluoro-3,6-dioxiheptanoic acid	NFDHA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorobutanoic acid	PFBA	1/25/2023		4.3	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorobutanesulfonic acid	PFBS	1/25/2023		3.9	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorodecanoic acid	PFDA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorododecanoic acid	PFDoA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoro(2-ethoxyethane)sulfonic acid	PFEESA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoroheptanoic acid	PFHpA	1/25/2023		2	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoroheptanesulfonic acid	PFHpS	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorohexanoic acid	PFHxA	1/25/2023		3.3	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorohexanesulfonic acid	PFHxS	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid	PFMPA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorononanoic acid	PFNA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorooctanoic acid	PFOA	1/25/2023		6.9	ppt	2	10
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorooctanesulfonic acid	PFOS	1/25/2023		7.1	ppt	2	10
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoropentanoic acid	PFPeA	1/25/2023		3.4	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoropentanesulfonic acid	PFPeS	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoroundecanoic acid	PFUnA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	11-Chloroicosafuoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9CI-PF3ONS	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	N-ethylperfluorooctanesulfonamidoacetic acid	NEtFOSAA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	N-methylperfluorooctanesulfonamidoacetic acid	NMeFOSAA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorobutanesulfonic acid	PFBS	1/25/2023		4.6	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorodecanoic acid	PFDA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorododecanoic acid	PFDoA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluoroheptanoic acid	PFHpA	1/25/2023		2.3	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorohexanoic acid	PFHxA	1/25/2023		3.3	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorohexanesulfonic acid	PFHxS	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorononanoic acid	PFNA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorooctanoic acid	PFOA	1/25/2023		7.8	ppt	2	10
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorooctanesulfonic acid	PFOS	1/25/2023		6.9	ppt	2	10
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorotetradecanoic acid	PFTA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorotridecanoic acid	PFTTrDA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluoroundecanoic acid	PFUnA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	533	11-chloroicosafuoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	6/1/2023 8:25		0	ng/L		NA
CHATEAU WELL 2	Forest Park	Compliance	533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	6/1/2023 8:25		0	ng/L		NA
CHATEAU WELL 2	Forest Park	Compliance	533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	6/1/2023 8:25		0	ng/L		NA
CHATEAU WELL 2	Forest Park	Compliance	533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	6/1/2023 8:25		0	ng/L		NA
CHATEAU WELL 2	Forest Park	Compliance	533	9-chlorohexadecafluoro-3-oxanonane-sulfonic acid	9CI-PF3ONS	6/1/2023 8:25		0	ng/L		NA
CHATEAU WELL 2	Forest Park	Compliance	533	4,8-dioxo-3H-perfluorononanoic acid (ADONA)	ADONA	6/1/2023 8:25		0	ng/L		NA
CHATEAU WELL 2	Forest Park	Compliance	533	Hexafluoropropylene oxide dimer acid	HFPO-DA/GenX	6/1/2023 8:25		0	ng/L		NA
CHATEAU WELL 2	Forest Park	Compliance	533	Nonafluoro-3,6-dioxiheptanoic acid	NFDHA	6/1/2023 8:25		0	ng/L		NA
CHATEAU WELL 2	Forest Park	Compliance	533	Perfluorobutanoic acid	PFBA	6/1/2023 8:25		4.6	ng/L		NA
CHATEAU WELL 2	Forest Park	Compliance	533	Perfluorobutanesulfonic acid	PFBS	6/1/2023 8:25		5.3	ng/L		NA
CHATEAU WELL 2	Forest Park	Compliance	533	Perfluorodecanoic acid	PFDA	6/1/2023 8:25		0	ng/L		NA
CHATEAU WELL 2	Forest Park	Compliance	533	Perfluorododecanoic acid	PFDoA	6/1/2023 8:25		0	ng/L		NA
CHATEAU WELL 2	Forest Park	Compliance	533	Perfluoro(2-ethoxyethane) sulfonic acid	PFEESA	6/1/2023 8:25		0	ng/L		NA
CHATEAU WELL 2	Forest Park	Compliance	533	Perfluoroheptanoic acid	PFHpA	6/1/2023 8:25		2.5	ng/L		NA
CHATEAU WELL 2	Forest Park	Compliance	533	Perfluoroheptanesulfonic acid	PFHpS	6/1/2023 8:25		0	ng/L		NA
CHATEAU WELL 2	Forest Park	Compliance	533	Perfluorohexanoic acid	PFHxA	6/1/2023 8:25		4	ng/L		NA
CHATEAU WELL 2	Forest Park	Compliance	533	Perfluorohexanesulfonic acid	PFHxS	6/1/2023 8:25		0	ng/L		NA
CHATEAU WELL 2	Forest Park	Compliance	533	Perfluoro-4-methoxybutanoic acid	PFMBA	6/1/2023 8:25		0	ng/L		NA
CHATEAU WELL 2	Forest Park	Compliance	533	Perfluoro-3-methoxypropanoic acid	PFMPA	6/1/2023 8:25		0	ng/L		NA
CHATEAU WELL 2	Forest Park	Compliance	533	Perfluorononanoic acid	PFNA	6/1/2023 8:25		0	ng/L		NA
CHATEAU WELL 2	Forest Park	Compliance	533	Perfluorooctanoic acid	PFOA	6/1/2023 8:25		7.8	ng/L		10
CHATEAU WELL 2	Forest Park	Compliance	533	Perfluorooctanesulfonic acid	PFOS	6/1/2023 8:25		8.2	ng/L		10
CHATEAU WELL 2	Forest Park	Compliance	533	Perfluoropentanoic acid	PFPeA	6/1/2023 8:25		4.9	ng/L		NA
CHATEAU WELL 2	Forest Park	Compliance	533	Perfluoropentanesulfonic acid	PFPeS	6/1/2023 8:25		0	ng/L		NA
CHATEAU WELL 2	Forest Park	Compliance	533	Perfluoroundecanoic acid	PFUnA	6/1/2023 8:25		0	ng/L		NA
CHATEAU WELL 1	Forest Park	Compliance	533	11-chloroicosafuoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	6/1/2023 8:37		0	ng/L		NA
CHATEAU WELL 1	Forest Park	Compliance	533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	6/1/2023 8:37		0	ng/L		NA
CHATEAU WELL 1	Forest Park	Compliance	533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	6/1/2023 8:37		0	ng/L		NA
CHATEAU WELL 1	Forest Park	Compliance	533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	6/1/2023 8:37		0	ng/L		NA
CHATEAU WELL 1	Forest Park	Compliance	533	9-chlorohexadecafluoro-3-oxanonane-sulfonic acid	9CI-PF3ONS	6/1/2023 8:37		0	ng/L		NA
CHATEAU WELL 1	Forest Park	Compliance	533	4,8-dioxo-3H-perfluorononanoic acid (ADONA)	ADONA	6/1/2023 8:37		0	ng/L		NA
CHATEAU WELL 1	Forest Park	Compliance	533	Hexafluoropropylene oxide dimer acid	HFPO-DA/GenX	6/1/2023 8:37		0	ng/L		NA

	System	Type	Method	Analyte	Analyte Acronym	Sample Date	Result	Final	Units	MRL	MCL
CHATEAU WELL 1	Forest Park	Compliance	533	Nonafluoro-3,6-dioxiheptanoic acid	NFDHA	6/1/2023 8:37		0	ng/L		NA
CHATEAU WELL 1	Forest Park	Compliance	533	Perfluorobutanoic acid	PFBA	6/1/2023 8:37		6.1	ng/L		NA
CHATEAU WELL 1	Forest Park	Compliance	533	Perfluorobutanesulfonic acid	PFBS	6/1/2023 8:37		6.6	ng/L		NA
CHATEAU WELL 1	Forest Park	Compliance	533	Perfluorodecanoic acid	PFDA	6/1/2023 8:37		0	ng/L		NA
CHATEAU WELL 1	Forest Park	Compliance	533	Perfluorododecanoic acid	PFDoA	6/1/2023 8:37		0	ng/L		NA
CHATEAU WELL 1	Forest Park	Compliance	533	Perfluoro (2-ethoxyethane) sulfonic acid	PFEESA	6/1/2023 8:37		0	ng/L		NA
CHATEAU WELL 1	Forest Park	Compliance	533	Perfluoroheptanoic acid	PFHpA	6/1/2023 8:37		4	ng/L		NA
CHATEAU WELL 1	Forest Park	Compliance	533	Perfluoroheptanesulfonic acid	PFHpS	6/1/2023 8:37		0	ng/L		NA
CHATEAU WELL 1	Forest Park	Compliance	533	Perfluorohexanoic acid	PFHxA	6/1/2023 8:37		9.2	ng/L		NA
CHATEAU WELL 1	Forest Park	Compliance	533	Perfluorohexanesulfonic acid	PFHxS	6/1/2023 8:37		2.1	ng/L		NA
CHATEAU WELL 1	Forest Park	Compliance	533	Perfluoro-4-methoxybutanoic acid	PFMBA	6/1/2023 8:37		0	ng/L		NA
CHATEAU WELL 1	Forest Park	Compliance	533	Perfluoro-3-methoxypropanoic acid	PFMPA	6/1/2023 8:37		0	ng/L		NA
CHATEAU WELL 1	Forest Park	Compliance	533	Perfluorononanoic acid	PFNA	6/1/2023 8:37		0	ng/L		NA
CHATEAU WELL 1	Forest Park	Compliance	533	Perfluorooctanoic acid	PFOA	6/1/2023 8:37		12	ng/L		10
CHATEAU WELL 1	Forest Park	Compliance	533	Perfluorooctanesulfonic acid	PFOS	6/1/2023 8:37		11	ng/L		10
CHATEAU WELL 1	Forest Park	Compliance	533	Perfluoropentanoic acid	PFPeA	6/1/2023 8:37		10	ng/L		NA
CHATEAU WELL 1	Forest Park	Compliance	533	Perfluoropentanesulfonic acid	PFPeS	6/1/2023 8:37		0	ng/L		NA
CHATEAU WELL 1	Forest Park	Compliance	533	Perfluoroundecanoic acid	PFUnA	6/1/2023 8:37		0	ng/L		NA
CHATEAU RAW COMBO	Chateau	Compliance	E533	11-chloroicosafafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF30UdS	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau	Compliance	E533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau	Compliance	E533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau	Compliance	E533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau	Compliance	E533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid	9CI-PF3ONS	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau	Compliance	E533	4,8-dioxo-3H-perfluorononanoic acid (ADONA)	ADONA	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau	Compliance	E533	Hexafluoropropylene oxide dimer acid	HFPO-DA/GenX	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau	Compliance	E533	Nonafluoro-3,6-dioxiheptanoic acid	NFDHA	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau	Compliance	E533	Perfluorobutanoic acid	PFBA	08/31/2023 11:45		3.58	ng/L		NA
CHATEAU RAW COMBO	Chateau	Compliance	E533	Perfluorobutanesulfonic acid	PFBS	08/31/2023 11:45		4.03	ng/L		NA
CHATEAU RAW COMBO	Chateau	Compliance	E533	Perfluorodecanoic acid	PFDA	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau	Compliance	E533	Perfluorododecanoic acid	PFDoA	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau	Compliance	E533	Perfluoro (2-ethoxyethane) sulfonic acid	PFEESA	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau	Compliance	E533	Perfluoroheptanoic acid	PFHpA	08/31/2023 11:45		1.89	ng/L		NA
CHATEAU RAW COMBO	Chateau	Compliance	E533	Perfluoroheptanesulfonic acid	PFHpS	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau	Compliance	E533	Perfluorohexanoic acid	PFHxA	08/31/2023 11:45		4.48	ng/L		NA
CHATEAU RAW COMBO	Chateau	Compliance	E533	Perfluorohexanesulfonic acid	PFHxS	08/31/2023 11:45		1.46	ng/L		NA
CHATEAU RAW COMBO	Chateau	Compliance	E533	Perfluoro-4-methoxybutanoic acid	PFMBA	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau	Compliance	E533	Perfluoro-3-methoxypropanoic acid	PFMPA	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau	Compliance	E533	Perfluorononanoic acid	PFNA	08/31/2023 11:45		0.528	ng/L		NA
CHATEAU RAW COMBO	Chateau	Compliance	E533	Perfluorooctanoic acid	PFOA	08/31/2023 11:45		7.69	ng/L		10
CHATEAU RAW COMBO	Chateau	Compliance	E533	Perfluorooctanesulfonic acid	PFOS	08/31/2023 11:45		8.92	ng/L		10
CHATEAU RAW COMBO	Chateau	Compliance	E533	Perfluoropentanoic acid	PFPeA	08/31/2023 11:45		5.04	ng/L		NA
CHATEAU RAW COMBO	Chateau	Compliance	E533	Perfluoropentanesulfonic acid	PFPeS	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau	Compliance	E533	Perfluoroundecanoic acid	PFUnA	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau	Compliance	E537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid	NEtFOSAA	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau	Compliance	E537.1	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau	Compliance	E537.1	Perfluorotetradecanoic acid	PFTeDA	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau	Compliance	E537.1	Perfluorotridecanoic acid	PFTriDA	08/31/2023 11:45		0	ng/L		NA
CHATEAU V1 EFF	Chateau	Compliance	E533	11-chloroicosafafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF30UdS	08/31/2023 11:45		0	ng/L		NA
CHATEAU V1 EFF	Chateau	Compliance	E533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	08/31/2023 11:45		0	ng/L		NA
CHATEAU V1 EFF	Chateau	Compliance	E533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	08/31/2023 11:45		0	ng/L		NA
CHATEAU V1 EFF	Chateau	Compliance	E533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	08/31/2023 11:45		0	ng/L		NA
CHATEAU V1 EFF	Chateau	Compliance	E533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid	9CI-PF3ONS	08/31/2023 11:45		0	ng/L		NA
CHATEAU V1 EFF	Chateau	Compliance	E533	4,8-dioxo-3H-perfluorononanoic acid (ADONA)	ADONA	08/31/2023 11:45		0	ng/L		NA
CHATEAU V1 EFF	Chateau	Compliance	E533	Hexafluoropropylene oxide dimer acid	HFPO-DA/GenX	08/31/2023 11:45		0	ng/L		NA
CHATEAU V1 EFF	Chateau	Compliance	E533	Nonafluoro-3,6-dioxiheptanoic acid	NFDHA	08/31/2023 11:45		0	ng/L		NA
CHATEAU V1 EFF	Chateau	Compliance	E533	Perfluorobutanoic acid	PFBA	08/31/2023 11:45		0	ng/L		NA
CHATEAU V1 EFF	Chateau	Compliance	E533	Perfluorobutanesulfonic acid	PFBS	08/31/2023 11:45		0	ng/L		NA
CHATEAU V1 EFF	Chateau	Compliance	E533	Perfluorodecanoic acid	PFDA	08/31/2023 11:45		0	ng/L		NA
CHATEAU V1 EFF	Chateau	Compliance	E533	Perfluorododecanoic acid	PFDoA	08/31/2023 11:45		0	ng/L		NA
CHATEAU V1 EFF	Chateau	Compliance	E533	Perfluoro (2-ethoxyethane) sulfonic acid	PFEESA	08/31/2023 11:45		0	ng/L		NA
CHATEAU V1 EFF	Chateau	Compliance	E533	Perfluoroheptanoic acid	PFHpA	08/31/2023 11:45		0	ng/L		NA
CHATEAU V1 EFF	Chateau	Compliance	E533	Perfluoroheptanesulfonic acid	PFHpS	08/31/2023 11:45		0	ng/L		NA
CHATEAU V1 EFF	Chateau	Compliance	E533	Perfluorohexanoic acid	PFHxA	08/31/2023 11:45		0	ng/L		NA
CHATEAU V1 EFF	Chateau	Compliance	E533	Perfluorohexanesulfonic acid	PFHxS	08/31/2023 11:45		0	ng/L		NA
CHATEAU V1 EFF	Chateau	Compliance	E533	Perfluoro-4-methoxybutanoic acid	PFMBA	08/31/2023 11:45		0	ng/L		NA
CHATEAU V1 EFF	Chateau	Compliance	E533	Perfluoro-3-methoxypropanoic acid	PFMPA	08/31/2023 11:45		0	ng/L		NA
CHATEAU V1 EFF	Chateau	Compliance	E533	Perfluorononanoic acid	PFNA	08/31/2023 11:45		0	ng/L		NA
CHATEAU V1 EFF	Chateau	Compliance	E533	Perfluorooctanoic acid	PFOA	08/31/2023 11:45		0	ng/L		10
CHATEAU V1 EFF	Chateau	Compliance	E533	Perfluorooctanesulfonic acid	PFOS	08/31/2023 11:45		0	ng/L		10
CHATEAU V1 EFF	Chateau	Compliance	E533	Perfluoropentanoic acid	PFPeA	08/31/2023 11:45		0	ng/L		NA
CHATEAU V1 EFF	Chateau	Compliance	E533	Perfluoropentanesulfonic acid	PFPeS	08/31/2023 11:45		0	ng/L		NA
CHATEAU V1 EFF	Chateau	Compliance	E533	Perfluoroundecanoic acid	PFUnA	08/31/2023 11:45		0	ng/L		NA
CHATEAU V1 EFF	Chateau	Compliance	E537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid	NEtFOSAA	08/31/2023 11:45		0	ng/L		NA
CHATEAU V1 EFF	Chateau	Compliance	E537.1	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	08/31/2023 11:45		0	ng/L		NA
CHATEAU V1 EFF	Chateau	Compliance	E537.1	Perfluorotetradecanoic acid	PFTeDA	08/31/2023 11:45		0	ng/L		NA
CHATEAU V1 EFF	Chateau	Compliance	E537.1	Perfluorotridecanoic acid	PFTriDA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau	Compliance	E537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid	NEtFOSAA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau	Compliance	E537.1	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau	Compliance	E537.1	Perfluorotetradecanoic acid	PFTeDA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau	Compliance	E537.1	Perfluorotridecanoic acid	PFTriDA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau	Compliance	E533	11-chloroicosafafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF30UdS	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau	Compliance	E533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau	Compliance	E533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau	Compliance	E533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau	Compliance	E533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid	9CI-PF3ONS	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau	Compliance	E533	4,8-dioxo-3H-perfluorononanoic acid (ADONA)	ADONA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau	Compliance	E533	Hexafluoropropylene oxide dimer acid	HFPO-DA/GenX	08/31/2023 11:45		0.611	ng/L		NA
CHATEAU POE	Chateau	Compliance	E533	Nonafluoro-3,6-dioxiheptanoic acid	NFDHA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau	Compliance	E533	Perfluorobutanoic acid	PFBA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau	Compliance	E533	Perfluorobutanesulfonic acid	PFBS	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau	Compliance	E533	Perfluorodecanoic acid	PFDA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau	Compliance	E533	Perfluorododecanoic acid	PFDoA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau	Compliance	E533	Perfluoro (2-ethoxyethane) sulfonic acid	PFEESA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau	Compliance	E533	Perfluoroheptanoic acid	PFHpA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau	Compliance	E533	Perfluoroheptanesulfonic acid	PFHpS	08/31/2023 11:45		0	ng/L		NA

	System	Type	Method	Analyte	Analyte Acronym	Sample Date	Result	Final	Units	MRL	MCL
CHATEAU POE	Chateau	Compliance	E533	Perfluorohexanoic acid	PFHxA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau	Compliance	E533	Perfluorohexanesulfonic acid	PFHxS	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau	Compliance	E533	Perfluoro-4-methoxybutanoic acid	PFMBA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau	Compliance	E533	Perfluoro-3-methoxypropanoic acid	PFMPA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau	Compliance	E533	Perfluorononanoic acid	PFNA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau	Compliance	E533	Perfluorooctanoic acid	PFQA	08/31/2023 11:45		0	ng/L		10
CHATEAU POE	Chateau	Compliance	E533	Perfluorooctanesulfonic acid	PFOS	08/31/2023 11:45		0	ng/L		10
CHATEAU POE	Chateau	Compliance	E533	Perfluoropentanoic acid	PFPeA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau	Compliance	E533	Perfluoropentanesulfonic acid	PFPeS	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau	Compliance	E533	Perfluoroundecanoic acid	PFUnA	08/31/2023 11:45		0	ng/L		NA

List of Abbreviations

MRL = Method Reporting Limit, the lowest level the laboratory analysis method can reliably detect

MCL = Maximum Contaminant Level, the regulatory limit set by the State

NA = Not applicable

ND = Not detected

ppt = parts per trillion

ppb = parts per billion

Analytical results depicted from 9/2020 through 6/2022 are EPA Method 537. Analytical results from 7/2022 to date are EPA Method 533.

EPA Method 537.1 data from 7/2022 to date is also included in the table.

Table has been sorted by sample date

Not all wells sampled within the quarter were operational for that quarter

*Beginning Q2 2023, Veolia Water New York made the following changes to its PFAS sampling protocol. Method 533 is used to analyze all 25 unique PFAS compounds covered by this Method as indicated on the US EPA, Office of Water, table number MS-140 December 2019. Method 537.1 is used to analyze only the 4 additional PFAS compounds not addressed by Method 533 as presented in the same above reference EPA table. Supplemental reports will also reflect this change beginning Q2 2023.

**** As systems are placed into service, the locations of samples/analysis are modified from individual well results to the following locations per DOH requirement. Locations include "Combine Raw", "Discharge from Lead Vessel(s)" and "Effluent"**