

Well ID	Location	Compliance	Chemical Name	EPA Method	Contaminant Name	Method	Date	Concentration	Unit	Limit	Result
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	erfluorooctanoic aci	PFOA	10/26/2020	0.01		10	ppt
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	erfluorooctanoic aci	PFOA	10/26/2020	0.011		11	ppt
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 522	1,4-Dioxane	ND	4/21/2022	ND		0	ppb
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	uroctanesulfonam	NEtFOSAA	4/21/2022	ND		0	ppt
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	uorooctanesulfonam	NMeFOSAA	4/21/2022	ND		0	ppt
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	uorobutanesulfonic	PFBS	4/21/2022	0.0058		5.8	ppt
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	erfluorodecanoic aci	PFDA	4/21/2022	ND		0	ppt
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	fluorododecanoic a	PFDoA	4/21/2022	ND		0	ppt
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	rfluoroheptanoic ac	PFHpA	4/21/2022	0.003		3	ppt
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorohexanoic i	PFHxI	4/21/2022	0.0068		6.8	ppt
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorohexanoic i	PFHxS	4/21/2022	ND		0	ppt
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorononanoic i	PFNA	4/21/2022	ND		0	ppt
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic a	PFOA	4/21/2022	0.011		11	ppt
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanesulf	PFOS	4/21/2022	0.0096		9.6	ppt
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorotetradecan	PFTEa	4/21/2022	ND		0	ppt
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorotridecanol	PFTrDA	4/21/2022	ND		0	ppt
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluoroundecano	PFUNA	4/21/2022	ND		0	ppt
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 522	1,4-Dioxane	ND	4/21/2022	ND		0	ppb
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	N-ethyl Perfluoroo	NEtFOSAA	4/21/2022	ND		0	ppt
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	N-methyl Perfluoro	NMeFOSAA	4/21/2022	ND		0	ppt
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorobutanesul	PFBS	4/21/2022	0.007		7	ppt
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorodecanoic i	PFDA	4/21/2022	ND		0	ppt
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorododecano	PFDoA	4/21/2022	ND		0	ppt
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluoroheptanoic	PFHpA	4/21/2022	0.0023		2.3	ppt
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorohexanoic i	PFHxI	4/21/2022	0.0049		4.9	ppt
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorohexanoic i	PFHxS	4/21/2022	ND		0	ppt
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorononanoic i	PFNA	4/21/2022	ND		0	ppt
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic a	PFOA	4/21/2022	0.0086		8.6	ppt
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanesulf	PFOS	4/21/2022	0.012		12	ppt
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorotetradecan	PFTEa	4/21/2022	ND		0	ppt
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorotridecanol	PFTrDA	4/21/2022	ND		0	ppt
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluoroundecano	PFUNA	4/21/2022	ND		0	ppt
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic a	PFOA	1/29/2021	0.012		12	ppt
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic a	PFOA	1/29/2021	0.011		11	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 522	1,4-Dioxane	ND	8/16/2022			0	ug/L
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	11-Chloroicosasulf	11CI-PF30UdS	8/16/2022			0	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	1H,1H,2H,2H-Perflu	4:2 FTS	8/16/2022			0	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	1H,1H,2H,2H-Perflu	6:2 FTS	8/16/2022			0	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	1H,1H,2H,2H-Perflu	8:2 FTS	8/16/2022			0	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	9-Chlorohexadecafl	9CI-PF30NS	8/16/2022			0	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	4,8-Dioxa-3H-perflu	ADONA	8/16/2022			0	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Hexafluoropropylen	HFPO-DA/GenX	8/16/2022			0	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Nonafluoro-3,6-dio	NFDHA	8/16/2022			0	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorobutanoic i	PFBA	8/16/2022			3.4	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorobutanesul	PFBS	8/16/2022			7.1	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorodecanoic i	PFDA	8/16/2022			0	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorododecano	PFDoA	8/16/2022			0	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro[2-ethoxy	PFEEESA	8/16/2022			0	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroheptanoic	PFHpA	8/16/2022			2.4	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroheptanesu	PFHpS	8/16/2022			0	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorohexanoic i	PFHxI	8/16/2022			5	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorohexanoic i	PFHxS	8/16/2022			0	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro-4-methox	PFMBA	8/16/2022			0	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro-3-methox	PFMPA	8/16/2022			0	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorononanoic i	PFNA	8/16/2022			0	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic a	PFOA	8/16/2022			8.8	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanesulf	PFOS	8/16/2022			9.3	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoropentanoic	PFPeA	8/16/2022			5.2	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoropentanesu	PFPeS	8/16/2022			0	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroundecano	PFUNA	8/16/2022			0	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	11-Chloroicosasulf	11CI-PF30UdS	8/16/2022			0	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	9-Chlorohexadecafl	9CI-PF30NS	8/16/2022			0	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	4,8-Dioxa-3H-perflu	ADONA	8/16/2022			0	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Hexafluoropropylen	HFPO-DA/GenX	8/16/2022			0	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	N-ethylperfluoroo	NEtFOSAA	8/16/2022			0	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	N-methylperfluoro	NMeFOSAA	8/16/2022			0	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorobutanesul	PFBS	8/16/2022			7.8	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorodecanoic i	PFDA	8/16/2022			0	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorododecano	PFDoA	8/16/2022			0	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluoroheptanoic	PFHpA	8/16/2022			2.7	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorohexanoic i	PFHxI	8/16/2022			5.1	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorohexanoic i	PFHxS	8/16/2022			0	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorononanoic i	PFNA	8/16/2022			0	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorooctanoic a	PFOA	8/16/2022			11	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorooctanesulf	PFOS	8/16/2022			11	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorotetradecan	PFTEa	8/16/2022			0	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorotridecanol	PFTrDA	8/16/2022			0	ppt
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluoroundecano	PFUNA	8/16/2022			0	ppt
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 522	1,4-Dioxane	ND	8/16/2022			0	ug/L
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	11-Chloroicosasulf	11CI-PF30UdS	8/16/2022			0	ppt
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	1H,1H,2H,2H-Perflu	4:2 FTS	8/16/2022			0	ppt
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	1H,1H,2H,2H-Perflu	6:2 FTS	8/16/2022			0	ppt
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	1H,1H,2H,2H-Perflu	8:2 FTS	8/16/2022			0	ppt
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	9-Chlorohexadecafl	9CI-PF30NS	8/16/2022			0	ppt
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	4,8-Dioxa-3H-perflu	ADONA	8/16/2022			0	ppt
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Hexafluoropropylen	HFPO-DA/GenX	8/16/2022			0	ppt
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Nonafluoro-3,6-dio	NFDHA	8/16/2022			0	ppt
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorobutanoic i	PFBA	8/16/2022			6.9	ppt
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorobutanesul	PFBS	8/16/2022			19	ppt
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorodecanoic i	PFDA	8/16/2022			0	ppt
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorododecano	PFDoA	8/16/2022			0	ppt
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro[2-ethoxy	PFEEESA	8/16/2022			0	ppt
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroheptanoic	PFHpA	8/16/2022			4.1	ppt
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroheptanesu	PFHpS	8/16/2022			0	ppt
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorohexanoic i	PFHxI	8/16/2022			8.1	ppt
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorohexanoic i	PFHxS	8/16/2022			2.5	ppt
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro-4-methox	PFMBA	8/16/2022			0	ppt
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro-3-methox	PFMPA	8/16/2022			0	ppt
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorononanoic i	PFNA	8/16/2022			0	ppt
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic a	PFOA	8/16/2022			15	ppt

ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic a PFOA	7/26/2023	9 ppt	1.9 10
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanesulf PFOS	7/26/2023	12.6 ppt	1.9 10
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic a PFOA	10/24/2022	14 ppt	2 10
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorooctanoic a PFOA	10/24/2022	13 ppt	2 10
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic a PFOA	10/24/2022	15 ppt	2 10
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorooctanoic a PFOA	10/24/2022	13 ppt	2 10
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic a PFOA	10/8/2020 0.013	13 ppt	2 10
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic a PFOA	10/8/2020 0.011	11 ppt	2 10
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic a PFOA	10/26/2020 0.01	10 ppt	2 10
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic a PFOA	10/26/2020 0.011	11 ppt	2 10
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic a PFOA	1/29/2021 0.012	12 ppt	2 10
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic a PFOA	1/29/2021 0.011	11 ppt	2 10
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic a PFOA	4/19/2021 0.0097	9.7 ppt	2 10
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic a PFOA	4/19/2021 0.009	9 ppt	2 10
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic a PFOA	8/18/2021 0.01	10 ppt	2 10
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic a PFOA	8/18/2021 0.0098	9.8 ppt	2 10
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic a PFOA	10/20/2021 0.013	13 ppt	2 10
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic a PFOA	10/20/2021 0.011	11 ppt	2 10
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic a PFOA	1/20/2022 0.01	10 ppt	2 10
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic a PFOA	1/20/2022 0.0082	8.2 ppt	2 10
Archer Well 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic a PFOA	4/21/2022 0.011	11 ppt	2 10
Archer Well 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537	Perfluorooctanoic a PFOA	4/21/2022 0.0086	8.6 ppt	2 10
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic a PFOA	8/16/2022	8.8 ppt	2 10
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorooctanoic a PFOA	8/16/2022	11 ppt	1.9 10
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic a PFOA	8/16/2022	15 ppt	1.9 10
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorooctanoic a PFOA	8/16/2022	18 ppt	1.9 10
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic a PFOA	10/24/2022	14 ppt	2 10
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorooctanoic a PFOA	10/24/2022	13 ppt	2 10
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic a PFOA	10/24/2022	15 ppt	2 10
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorooctanoic a PFOA	10/24/2022	13 ppt	2 10
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic a PFOA	1/25/2023	13 ppt	1.9 10
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorooctanoic a PFOA	1/25/2023	15 ppt	1.9 10
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic a PFOA	1/25/2023	11 ppt	1.9 10
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorooctanoic a PFOA	1/25/2023	13 ppt	1.9 10
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic a PFOA	4/25/2023	8.3 ppt	1.9 10
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic a PFOA	4/25/2023	13 ppt	1.9 10
ARCHER WELL 1	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic a PFOA	7/26/2023	11.6 ppt	1.9 10
ARCHER WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic a PFOA	7/26/2023	9 ppt	1.9 10
Archer Raw Combined	NY-Archer	Compliance	PFAS Compliance	EPA 533	Perfluorooctanoic a PFOA	12/5/2023 18.5	18.5 ng/L	0.91 10
Archer V1 EFF	NY-Archer	Compliance	PFAS Compliance	EPA 533	Perfluorooctanoic a PFOA	12/5/2023 ND	0 ng/L	0.91 10
Archer V3 EFF	NY-Archer	Compliance	PFAS Compliance	EPA 533	Perfluorooctanoic a PFOA	12/5/2023 ND	0 ng/L	0.91 10
Archer POE	NY-Archer	Compliance	PFAS Compliance	EPA 533	Perfluorooctanoic a PFOA	12/5/2023 ND	0 ng/L	0.91 10

List of Abbreviations

MRL = Method Reporting Limit, the lowest level the laboratory analysis method can reliably detect

MCL = Maximum Contaminant Level, the regulatory limit set by the State

NA = Not applicable

ND = Not detected

ppt = parts per trillion

ppb = parts per billion

Analytical results depicted from 9/2020 through 6/2022 are EPA Method 537. Analytical results from 7/2022 to date are EPA Method 533.

EPA Method 537.1 data from 7/2022 to date is also included in the table.

Table has been sorted by sample date

All Rockland locations have been added to this supplemental report per NYSDOH Request following Q3 2022

Not all wells sampled within the quarter were operational for that quarter

*Beginning Q2 2023, Veolia Water New York made the following changes to its PFAS sampling protocol. Method 533 is used to analyze all 25 unique PFAS compounds covered by this Method as indicated on the US EPA, Office of Water, table number MS-140 dated December 2019. Method 537.1 is used to analyze only the 4 additional PFAS compounds not addressed by Method 533 as presented in the same above reference EPA table. Supplemental reports will also reflect this change beginning Q2 2023.

** As systems are placed into service, the locations of samples/analysis are modified from individual well results to the following locations per DOH requirement. Locations include "Combine Raw", "Discharge from Lead Vessel(s)" and "Effluent"