

CHATEAU WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorohexanoic acid	PFHxA	1/25/2023	3.3 ppt	2	NA			
CHATEAU WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorohexanesulfonic acid	PFHxS	1/25/2023	0 ppt	2	NA			
CHATEAU WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorononanoic acid	PFNA	1/25/2023	0 ppt	2	NA			
CHATEAU WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorooctanoic acid	PFOA	1/25/2023	7.8 ppt	2	10			
CHATEAU WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorooctanesulfonic acid	PFOS	1/25/2023	6.9 ppt	2	10			
CHATEAU WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorotetradecanoic acid	PFTA	1/25/2023	0 ppt	2	NA			
CHATEAU WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorotridecanoic acid	PFTrDA	1/25/2023	0 ppt	2	NA			
CHATEAU WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluoroundecanoic acid	PFUnA	1/25/2023	0 ppt	2	NA			
CHATEAU WELL 2	Forest Park	Compliance	PFAS-DIOXANE	533	Perfluorooctanoic acid	PFOA	6/1/2023	7.8 ng/L		10			
CHATEAU WELL 2	Forest Park	Compliance	PFAS-DIOXANE	533	Perfluorooctanesulfonic acid	PFOS	6/1/2023	8.2 ng/L		10			
CHATEAU WELL 1	Forest Park	Compliance	PFAS-DIOXANE	533	Perfluorooctanoic acid	PFOA	6/1/2023	12 ng/L		10			
CHATEAU WELL 1	Forest Park	Compliance	PFAS-DIOXANE	533	Perfluorooctanesulfonic acid	PFOS	6/1/2023	11 ng/L		10			
CHATEAU RAW COMBO	Forest Park	Compliance	PFAS-DIOXANE	E533	Perfluorooctanoic acid	PFOA	8/31/2023	7.69 ng/L		10			
CHATEAU V1 EFF	Forest Park	Compliance	PFAS-DIOXANE	E533	Perfluorooctanoic acid	PFOA	8/31/2023	0 ng/L		10			
CHATEAU POE	Forest Park	Compliance	PFAS-DIOXANE	E533	Perfluorooctanoic acid	PFOA	8/31/2023	0 ng/L		10			
Chateau Raw Combined	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic acid	PFOA	10/20/2023	8.19		0.45	10		
Chateau V1 EFF	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic acid	PFOA	10/20/2023	8.26		0.5	10		
Chateau POE	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic acid	PFOA	10/20/2023	ND		0	ng/L	0.42	10

List of Abbreviations

MRL = Method Reporting Limit, the lowest level the laboratory analysis method can reliably detect

MCL = Maximum Contaminant Level, the regulatory limit set by the State

NA = Not applicable

ND = Not detected

ppt = parts per trillion

ppb = parts per billion

Analytical results depicted from 9/2020 through 6/2022 are EPA Method 537. Analytical results from 7/2022 to date are EPA Method 533.

EPA Method 537.1 data from 7/2022 to date is also included in the table.

Table has been sorted by sample date

All Rockland locations have been added to this supplemental report per NYSDOH Request following Q3 2022

Not all wells sampled within the quarter were operational for that quarter

*Beginning Q2 2023, Veolia Water New York made the following changes to its PFAS sampling protocol. Method 533 is used to analyze all 25 unique PFAS compounds covered by this Method as indicated on the US EPA, Office of Water, table number MS-140 dated December 2019. Method 537.1 is used to analyze only the 4 additional PFAS compounds not addressed by Method 533 as presented in the same above reference EPA table. Supplemental reports will also reflect this change beginning Q2 2023.

** As systems are placed into service, the locations of samples/analysis are modified from individual well results to the following locations per DOH requirement. Locations include "Combine Raw", "Discharge from Lead Vessel(s)" and "Effluent"