











GEYMER POE	Geymer	E533	4,8-dioxa-3H-perfluorononanoic acid (ADONA)	ADONA	8/31/2023	0 ng/L	NA		
GEYMER POE	Geymer	E533	Hexafluoropropylene oxide dimer acid	HFPO-DA/GenX	8/31/2023	0 ng/L	NA		
GEYMER POE	Geymer	E533	Nonafluoro-3,6-dioxaheptanoic acid	NFDHA	8/31/2023	0 ng/L	NA		
GEYMER POE	Geymer	E533	Perfluorodecanoic acid	PFDA	8/31/2023	0 ng/L	NA		
GEYMER POE	Geymer	E533	Perfluorododecanoic acid	PFDoA	8/31/2023	0 ng/L	NA		
GEYMER POE	Geymer	E533	Perfluoro (2-ethoxyethane) sulfonic acid	PFEESA	8/31/2023	0 ng/L	NA		
GEYMER POE	Geymer	E533	Perfluoroheptanesulfonic acid	PFHpS	8/31/2023	0 ng/L	NA		
GEYMER POE	Geymer	E533	Perfluoro-4-methoxybutanoic acid	PFMBA	8/31/2023	0 ng/L	NA		
GEYMER POE	Geymer	E533	Perfluoro-3-methoxypropanoic acid	PFMPA	8/31/2023	0 ng/L	NA		
GEYMER POE	Geymer	E533	Perfluorononanoic acid	PFNA	8/31/2023	0 ng/L	NA		
GEYMER POE	Geymer	E533	Perfluoropentanesulfonic acid	PFPeS	8/31/2023	0 ng/L	NA		
GEYMER POE	Geymer	E533	Perfluoroundecanoic acid	PFUnA	8/31/2023	0 ng/L	NA		
GEYMER POE	Geymer	E533	Perfluorobutanoic acid	PFBA	8/31/2023	0 ng/L	NA		
GEYMER POE	Geymer	E533	Perfluorobutanesulfonic acid	PFBS	8/31/2023	0 ng/L	NA		
GEYMER POE	Geymer	E533	Perfluoroheptanoic acid	PFHpA	8/31/2023	0 ng/L	NA		
GEYMER POE	Geymer	E533	Perfluorohexanoic acid	PFHxA	8/31/2023	0 ng/L	NA		
GEYMER POE	Geymer	E533	Perfluorohexanesulfonic acid	PFHxS	8/31/2023	0 ng/L	NA		
GEYMER POE	Forest Park	Compliance	Perfluorooctanoic acid	PFOA	8/31/2023	0 ng/L	10		
GEYMER POE	Geymer	E533	Perfluorooctanesulfonic acid	PFOS	8/31/2023	0 ng/L	10		
GEYMER POE	Geymer	E533	Perfluoropentanoic acid	PFPeA	8/31/2023	0 ng/L	NA		
GEYMER POE	Geymer	E537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid	NETFOSAA	8/31/2023	0 ng/L	NA		
GEYMER POE	Geymer	E537.1	N-methyl Perfluorooctanesulfonamidoacetic acid	NMEFOSAA	8/31/2023	0 ng/L	NA		
GEYMER POE	Geymer	E537.1	Perfluorotetradecanoic acid	PFTeDA	8/31/2023	0 ng/L	NA		
GEYMER POE	Geymer	E537.1	Perfluorotridecanoic acid	PFTrDA	8/31/2023	0 ng/L	NA		
Geymer Raw Combined	Forest Park	Compliance	EPA 533	Perfluorooctanoic acid	PFOA	10/19/2023	9.36 ng/L	0.46 10	
Geymer POE	Forest Park	Compliance	EPA 533	Perfluorooctanoic acid	PFOA	10/19/2023	ND	0 ng/L	0.46 10

List of Abbreviations

MRL = Method Reporting Limit, the lowest level the laboratory analysis method can reliably detect

MCL = Maximum Contaminant Level, the regulatory limit set by the State

NA = Not applicable

ND = Not detected

ppt = parts per trillion

ppb = parts per billion

Analytical results depicted from 9/2020 through 6/2022 are EPA Method 537. Analytical results from 7/2022 to date are EPA Method 533.

EPA Method 537.1 data from 7/2022 to date is also included in the table.

Table has been sorted by sample date

All Rockland locations have been added to this supplemental report per NYSDOH Request following Q3 2022

Not all wells sampled within the quarter were operational for that quarter

\*Beginning Q2 2023, Veolia Water New York made the following changes to its PFAS sampling protocol. Method 533 is used to analyze all 25 unique PFAS compounds covered by this Method as indicated on the US EPA, Office of Water, table number MS-140 dated December 2019. Method 537.1 is used to analyze only the 4 additional PFAS compounds not addressed by Method 533 as presented in the same above reference EPA table. Supplemental reports will also reflect this change beginning Q2 2023.

\*\* As systems are placed into service, the locations of samples/analysis are modified from individual well results to the following locations per DOH requirement. Locations include "Combine Raw", "Discharge from Lead Vessel(s)" and "Effluent"