

Table with columns: System, Method, Analyte, Analyte Acronym, Sample Date, Final, Final, Units, MRL, MCL. Contains multiple rows of test results for various analytes such as Perfluorododecanoic acid, Perfluoroheptanoic acid, etc.

| | System | Method | Analyte | Analyte Acronym | Sample Date | Final | Final | Units | MRL | MCL |
|-----------------|------------|--------|---|-----------------|-------------|-------|-------|--------|-------|-----|
| Mahopac WTP POE | NY-Mahopac | E537.1 | N-methyl Perfluorooctanesulfonamidoacetic acid (NMEFOSAA) | NMEFOSAA | 1/18/2024 | ND | | 0 ng/L | 0.943 | NA |
| Mahopac WTP POE | NY-Mahopac | E533 | Nonafluoro-3,6-dioxahexanoic acid (NFDHA) | NFDHA | 1/18/2024 | ND | | 0 ng/L | 0.893 | NA |
| Mahopac WTP POE | NY-Mahopac | E533 | Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA) | PFEEESA | 1/18/2024 | ND | | 0 ng/L | 0.893 | NA |
| Mahopac WTP POE | NY-Mahopac | E533 | Perfluoro-3-methoxypropanoic acid (PFMPA) | PFMPA | 1/18/2024 | ND | | 0 ng/L | 0.893 | NA |
| Mahopac WTP POE | NY-Mahopac | E533 | Perfluoro-4-methoxybutanoic acid (PFMBA) | PFMBA | 1/18/2024 | ND | | 0 ng/L | 0.893 | NA |
| Mahopac WTP POE | NY-Mahopac | E533 | Perfluorobutanesulfonic acid (PFBS) | PFBS | 1/18/2024 | ND | | 0 ng/L | 0.893 | NA |
| Mahopac WTP POE | NY-Mahopac | E533 | Perfluorobutanoic acid (PFBA) | PFBA | 1/18/2024 | ND | | 0 ng/L | 0.893 | NA |
| Mahopac WTP POE | NY-Mahopac | E533 | Perfluorodecanoic acid (PFDA) | PFDA | 1/18/2024 | ND | | 0 ng/L | 0.893 | NA |
| Mahopac WTP POE | NY-Mahopac | E533 | Perfluorododecanoic acid (PFDoA) | PFDoA | 1/18/2024 | ND | | 0 ng/L | 0.893 | NA |
| Mahopac WTP POE | NY-Mahopac | E533 | Perfluoroheptanesulfonic acid (PFHpS) | PFHpS | 1/18/2024 | ND | | 0 ng/L | 1.79 | NA |
| Mahopac WTP POE | NY-Mahopac | E533 | Perfluoroheptanoic acid (PFHpA) | PFHpA | 1/18/2024 | ND | | 0 ng/L | 0.893 | NA |
| Mahopac WTP POE | NY-Mahopac | E533 | Perfluorohexanesulfonic acid (PFHxS) | PFHxS | 1/18/2024 | ND | | 0 ng/L | 0.893 | NA |
| Mahopac WTP POE | NY-Mahopac | E533 | Perfluorohexanoic acid (PFHxA) | PFHxA | 1/18/2024 | ND | | 0 ng/L | 0.893 | NA |
| Mahopac WTP POE | NY-Mahopac | E533 | Perfluorononanoic acid (PFNA) | PFNA | 1/18/2024 | ND | | 0 ng/L | 0.893 | NA |
| Mahopac WTP POE | NY-Mahopac | E533 | Perfluorooctanesulfonic acid (PFOS) | PFOS | 1/18/2024 | ND | | 0 ng/L | 0.893 | 10 |
| Mahopac WTP POE | NY-Mahopac | E533 | Perfluorooctanoic acid (PFOA) | PFOA | 1/18/2024 | ND | | 0 ng/L | 0.893 | 10 |
| Mahopac WTP POE | NY-Mahopac | E533 | Perfluoropentanesulfonic acid (PFPeS) | PFPeS | 1/18/2024 | ND | | 0 ng/L | 0.893 | NA |
| Mahopac WTP POE | NY-Mahopac | E533 | Perfluoropentanoic acid (PFPeA) | PFPeA | 1/18/2024 | ND | | 0 ng/L | 0.893 | NA |
| Mahopac WTP POE | NY-Mahopac | E537.1 | Perfluorotetradecanoic acid (PFTeDA) | PFTeDA | 1/18/2024 | ND | | 0 ng/L | 0.943 | NA |
| Mahopac WTP POE | NY-Mahopac | E537.1 | Perfluorotridecanoic acid (PFTrDA) | PFTrDA | 1/18/2024 | ND | | 0 ng/L | 0.943 | NA |
| Mahopac WTP POE | NY-Mahopac | E533 | Perfluoroundecanoic acid (PFUnA) | PFUnA | 1/18/2024 | ND | | 0 ng/L | 0.893 | NA |

List of Abbreviations MRL = Method Reporting Limit, the

ppt = parts per trillion

ppb = parts per billion

Analytical results depicted from 9/2020 through 6/2022 are EPA Method 537. Analytical results from 7/2022 to date are EPA Method 533.

EPA Method 537.1 data from 7/2022 to date is also included in the table.

Table has been sorted by sample date

All Rockland locations have been added to this supplemental report per NYSDOH Request following Q3 2022. Not all wells sampled within the quarter were operational for that quarter.

*Beginning Q2 2023, Veolia Water New York made the following changes to its PFAS sampling protocol. Method 533 is used to analyze all 25 unique PFAS compounds covered by this Method as indicated on the US EPA, Office of Water, table number MS-140 dated December 2019. Method 537.1 is used to analyze only the 4 additional PFAS compounds not addressed by Method 533 as presented in the same above reference EPA table. Supplemental reports will also reflect this change beginning Q2 2023.

** As systems are placed into service, the locations of samples/analysis are modified from individual well results to the following locations per DOH requirement.

Locations include "Combine Raw", "Discharge from Lead Vessel(s)" and "Effluent"