















	System	Type	Project	Method	Analyte	Analyte Acronym	Sample Date	Final	Results	Units	MRL	MCL
CHATEAU WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	4,8-Dioxa-3H-perfluorononanoic acid	ADONA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	N-ethylperfluorooctanesulfonamidoacetic acid	NEtFOSAA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	N-methylperfluorooctanesulfonamidoacetic acid	NMeFOSAA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorobutanesulfonic acid	PFBS	1/25/2023		4.6	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorodecanoic acid	PFDA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorododecanoic acid	PFDOA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluoroheptanoic acid	PFHpA	1/25/2023		2.3	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorohexanoic acid	PFHxA	1/25/2023		3.3	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorohexanesulfonic acid	PFHxS	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorononanoic acid	PFNA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorooctanoic acid	PFOA	1/25/2023		7.8	ppt	2	10
CHATEAU WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorooctanesulfonic acid	PFOS	1/25/2023		6.9	ppt	2	10
CHATEAU WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorotetradecanoic acid	PFTA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorotridecanoic acid	PFTDA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluoroundecanoic acid	PFUnA	1/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	PFAS-DIOXANE	EPA 537.1	N-ethylperfluorooctanesulfonamidoacetic acid	NEtFOSAA	4/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	PFAS-DIOXANE	EPA 537.1	N-methylperfluorooctanesulfonamidoacetic acid	NMeFOSAA	4/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorotetradecanoic acid	PFTA	4/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorotridecanoic acid	PFTDA	4/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	PFAS-DIOXANE	EPA 537.1	N-ethylperfluorooctanesulfonamidoacetic acid	NEtFOSAA	4/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	PFAS-DIOXANE	EPA 537.1	N-methylperfluorooctanesulfonamidoacetic acid	NMeFOSAA	4/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorotetradecanoic acid	PFTA	4/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorotridecanoic acid	PFTDA	4/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Forest Park	Compliance	PFAS-DIOXANE	533	Perfluorooctanoic acid	PFOA	6/1/2023 8:25		7.8	ng/L		10
CHATEAU WELL 2	Forest Park	Compliance	PFAS-DIOXANE	533	Perfluorooctanesulfonic acid	PFOS	6/1/2023 8:25		8.2	ng/L		10
CHATEAU WELL 1	Forest Park	Compliance	PFAS-DIOXANE	533	Perfluorooctanoic acid	PFOA	6/1/2023 8:37		12	ng/L		10
CHATEAU WELL 1	Forest Park	Compliance	PFAS-DIOXANE	533	Perfluorooctanesulfonic acid	PFOS	6/1/2023 8:37		11	ng/L		10
CHATEAU RAW COMBO	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic acid	PFOA	08/31/2023 11:45		7.69	ng/L		10
CHATEAU POE	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic acid	PFOA	08/31/2023 11:45		0	ng/L		10
Chateau Raw Combined	NY-Chateau	Compliance	PFAS Compliance	EPA 533	11-chloroicosafafluoro-3-oxaundecane-1-sulfonic acid	11Cl-PF30UdS	10/20/2023 9:00 ND		0	ng/L		0.45 NA
Chateau Raw Combined	NY-Chateau	Compliance	PFAS Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	10/20/2023 9:00 ND		0	ng/L		0.89 NA
Chateau Raw Combined	NY-Chateau	Compliance	PFAS Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	10/20/2023 9:00 ND		0	ng/L		0.45 NA
Chateau Raw Combined	NY-Chateau	Compliance	PFAS Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	10/20/2023 9:00	2.13	2.13	ng/L		1.79 NA
Chateau Raw Combined	NY-Chateau	Compliance	PFAS Compliance	EPA 533	4,8-dioxa-3H-perfluorononanoic acid	ADONA	10/20/2023 9:00 ND		0	ng/L		0.45 NA
Chateau Raw Combined	NY-Chateau	Compliance	PFAS Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid	9Cl-PF30NS	10/20/2023 9:00 ND		0	ng/L		0.45 NA
Chateau Raw Combined	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Hexafluoropropylene oxide dimer acid	HFPO-DA/GenX	10/20/2023 9:00 ND		0	ng/L		0.45 10
Chateau Raw Combined	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Nonafluoro-3,6-dioxaheptanoic acid	NFDHA	10/20/2023 9:00 ND		0	ng/L		0.45 NA
Chateau Raw Combined	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid	PFEESA	10/20/2023 9:00 ND		0	ng/L		0.45 NA
Chateau Raw Combined	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid	PFMPA	10/20/2023 9:00 ND		0	ng/L		0.45 NA
Chateau Raw Combined	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBA	10/20/2023 9:00 ND		0	ng/L		0.45 NA
Chateau Raw Combined	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluorobutanesulfonic acid	PFBS	10/20/2023 9:00	4.73	4.73	ng/L		0.45 NA
Chateau Raw Combined	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluorobutanoic acid	PFBA	10/20/2023 9:00	4.17	4.17	ng/L		0.45 NA
Chateau Raw Combined	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluorodecanoic acid	PFDA	10/20/2023 9:00 ND		0	ng/L		0.45 10
Chateau Raw Combined	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluorododecanoic acid	PFDOA	10/20/2023 9:00 ND		0	ng/L		0.45 NA
Chateau Raw Combined	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluoroheptanesulfonic acid	PFHpS	10/20/2023 9:00 ND		0	ng/L		0.89 NA
Chateau Raw Combined	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluoroheptanoic acid	PFHpA	10/20/2023 9:00	2.11	2.11	ng/L		0.45 10
Chateau Raw Combined	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluorohexanesulfonic acid	PFHxS	10/20/2023 9:00	1.79	1.79	ng/L		0.45 10
Chateau Raw Combined	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluorohexanoic acid	PFHxA	10/20/2023 9:00	4.7	4.7	ng/L		0.45 NA
Chateau Raw Combined	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluorononanoic acid	PFNA	10/20/2023 9:00	0.57	0.57	ng/L		0.45 10
Chateau Raw Combined	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluorooctanesulfonic acid	PFOS	10/20/2023 9:00	7.64	7.64	ng/L		0.45 10
Chateau Raw Combined	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic acid	PFOA	10/20/2023 9:00	8.19	8.19	ng/L		0.45 10
Chateau Raw Combined	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluoropentanesulfonic acid	PFPeS	10/20/2023 9:00 ND		0	ng/L		0.45 NA
Chateau Raw Combined	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluoropentanoic acid	PFPeA	10/20/2023 9:00	4.82	4.82	ng/L		0.45 NA
Chateau Raw Combined	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluoroundecanoic acid	PFUnA	10/20/2023 9:00 ND		0	ng/L		0.45 NA
Chateau Raw Combined	NY-Chateau	Compliance	PFAS Compliance	EPA 537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid	NEtFOSAA	10/20/2023 9:00 ND		0	ng/L		0.91 NA
Chateau Raw Combined	NY-Chateau	Compliance	PFAS Compliance	EPA 537.1	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	10/20/2023 9:00 ND		0	ng/L		0.91 NA
Chateau Raw Combined	NY-Chateau	Compliance	PFAS Compliance	EPA 537.1	Perfluorotetradecanoic acid	PFTDA	10/20/2023 9:00 ND		0	ng/L		0.91 NA
Chateau Raw Combined	NY-Chateau	Compliance	PFAS Compliance	EPA 537.1	Perfluorotridecanoic acid	PFTDA	10/20/2023 9:00 ND		0	ng/L		0.91 NA
Chateau POE	NY-Chateau	Compliance	PFAS Compliance	EPA 533	11-chloroicosafafluoro-3-oxaundecane-1-sulfonic acid	11Cl-PF30UdS	10/20/2023 9:09 ND		0	ng/L		0.42 NA
Chateau POE	NY-Chateau	Compliance	PFAS Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	10/20/2023 9:09 ND		0	ng/L		0.83 NA
Chateau POE	NY-Chateau	Compliance	PFAS Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	10/20/2023 9:09 ND		0	ng/L		0.42 NA
Chateau POE	NY-Chateau	Compliance	PFAS Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	10/20/2023 9:09 ND		0	ng/L		1.67 NA
Chateau POE	NY-Chateau	Compliance	PFAS Compliance	EPA 533	4,8-dioxa-3H-perfluorononanoic acid	ADONA	10/20/2023 9:09 ND		0	ng/L		0.42 NA
Chateau POE	NY-Chateau	Compliance	PFAS Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid	9Cl-PF30NS	10/20/2023 9:09 ND		0	ng/L		0.42 NA
Chateau POE	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Hexafluoropropylene oxide dimer acid	HFPO-DA/GenX	10/20/2023 9:09 ND		0	ng/L		0.42 10
Chateau POE	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Nonafluoro-3,6-dioxaheptanoic acid	NFDHA	10/20/2023 9:09 ND		0	ng/L		0.42 NA
Chateau POE	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid	PFEESA	10/20/2023 9:09 ND		0	ng/L		0.42 NA
Chateau POE	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid	PFMPA	10/20/2023 9:09 ND		0	ng/L		0.42 NA
Chateau POE	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBA	10/20/2023 9:09 ND		0	ng/L		0.42 NA
Chateau POE	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluorobutanesulfonic acid	PFBS	10/20/2023 9:09 ND		0	ng/L		0.42 NA
Chateau POE	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluorobutanoic acid	PFBA	10/20/2023 9:09	0.82	0.82	ng/L		0.42 NA
Chateau POE	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluorodecanoic acid	PFDA	10/20/2023 9:09 ND		0	ng/L		0.42 10
Chateau POE	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluorododecanoic acid	PFDOA	10/20/2023 9:09 ND		0	ng/L		0.42 NA
Chateau POE	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluoroheptanesulfonic acid	PFHpS	10/20/2023 9:09 ND		0	ng/L		0.83 NA
Chateau POE	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluoroheptanoic acid	PFHpA	10/20/2023 9:09 ND		0	ng/L		0.42 10
Chateau POE	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluorohexanesulfonic acid	PFHxS	10/20/2023 9:09 ND		0	ng/L		0.42 10
Chateau POE	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluorohexanoic acid	PFHxA	10/20/2023 9:09 ND		0	ng/L		0.42 NA
Chateau POE	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluorononanoic acid	PFNA	10/20/2023 9:09 ND		0	ng/L		0.42 10
Chateau POE	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluorooctanesulfonic acid	PFOS	10/20/2023 9:09 ND		0	ng/L		0.42 10
Chateau POE	Forest Park	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic acid	PFOA	10/20/2023 9:09 ND		0	ng/L		0.42 10
Chateau POE	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluoropentanesulfonic acid	PFPeS	10/20/2023 9:09 ND		0	ng/L		0.42 NA
Chateau POE	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluoropentanoic acid	PFPeA	10/20/2023 9:09 ND		0	ng/L		0.42 NA
Chateau POE	NY-Chateau	Compliance	PFAS Compliance	EPA 533	Perfluoroundecanoic acid	PFUnA	10/20/2023 9:09 ND		0	ng/L		0.42 NA
Chateau POE	NY-Chateau	Compliance	PFAS Compliance	EPA 537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid	NEtFOSAA	10/20/2023 9:09 ND		0	ng/L		0.89 NA
Chateau POE	NY-Chateau	Compliance	PFAS Compliance	EPA 537.1	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	10/20/2023 9:09 ND		0	ng/L		0.89 NA
Chateau POE	NY-Chateau	Compliance	PFAS Compliance	EPA 537.1	Perfluorotetradecanoic acid	PFTDA	10/20/2023 9:09 ND		0	ng/L		0.89 NA

	System	Type	Project	Method	Analyte	Analyte Acronym	Sample Date	Final	Results	Units	MRL	MCL	
Chateau POE	NY-Chateau	Compliance	PFAS Compliance	EPA 537.1	Perfluorotridecanoic acid	PFTrDA	10/20/2023 9:09	ND	0	ng/L	0.89	NA	
Chateau Well 3	NY-Chateau	Compliance	PROCESS	EPA 533	11-chloroheptafluoro-3-oxaundecane-1-sulfonic acid	11Cl-PF3OUdS	11/10/2023 9:40	ND	0	ng/L	0.86	NA	
Chateau Well 3	NY-Chateau	Compliance	PROCESS	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	11/10/2023 9:40	ND	0	ng/L	1.72	NA	
Chateau Well 3	NY-Chateau	Compliance	PROCESS	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	11/10/2023 9:40	ND	0	ng/L	0.86	NA	
Chateau Well 3	NY-Chateau	Compliance	PROCESS	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	11/10/2023 9:40	ND	0	ng/L	1.72	NA	
Chateau Well 3	NY-Chateau	Compliance	PROCESS	EPA 533	4,8-dioxo-3H-perfluorononanoic acid	ADONA	11/10/2023 9:40	ND	0	ng/L	0.86	NA	
Chateau Well 3	NY-Chateau	Compliance	PROCESS	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid	9Cl-PF3ONS	11/10/2023 9:40	ND	0	ng/L	0.86	NA	
Chateau Well 3	NY-Chateau	Compliance	PROCESS	EPA 533	Hexafluoropropylene oxide dimer acid	HFPO-DA/GenX	11/10/2023 9:40	ND	0	ng/L	0.86	10	
Chateau Well 3	NY-Chateau	Compliance	PROCESS	EPA 533	Nonafluoro-3,6-dioxaheptanoic acid	NFDHA	11/10/2023 9:40	ND	0	ng/L	0.86	NA	
Chateau Well 3	NY-Chateau	Compliance	PROCESS	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid	PFEESA	11/10/2023 9:40	ND	6.56	6.56	ng/L	0.86	NA
Chateau Well 3	NY-Chateau	Compliance	PROCESS	EPA 533	Perfluoro-3-methoxypropanoic acid	PFMPA	11/10/2023 9:40	ND	9.83	9.83	ng/L	0.86	NA
Chateau Well 3	NY-Chateau	Compliance	PROCESS	EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBA	11/10/2023 9:40	ND	0	ng/L	0.86	NA	
Chateau Well 3	NY-Chateau	Compliance	PROCESS	EPA 533	Perfluorobutanesulfonic acid	PFBS	11/10/2023 9:40	ND	0	ng/L	0.86	NA	
Chateau Well 3	NY-Chateau	Compliance	PROCESS	EPA 533	Perfluorobutanoic acid	PFBA	11/10/2023 9:40	ND	0	ng/L	0.86	NA	
Chateau Well 3	NY-Chateau	Compliance	PROCESS	EPA 533	Perfluorodecanoic acid	PFDA	11/10/2023 9:40	ND	0	ng/L	0.86	10	
Chateau Well 3	NY-Chateau	Compliance	PROCESS	EPA 533	Perfluorododecanoic acid	PFDoA	11/10/2023 9:40	ND	0	ng/L	0.86	NA	
Chateau Well 3	NY-Chateau	Compliance	PROCESS	EPA 533	Perfluoroheptanesulfonic acid	PFHpS	11/10/2023 9:40	ND	0	ng/L	1.72	NA	
Chateau Well 3	NY-Chateau	Compliance	PROCESS	EPA 533	Perfluoroheptanoic acid	PFHpA	11/10/2023 9:40	ND	3.95	3.95	ng/L	0.86	10
Chateau Well 3	NY-Chateau	Compliance	PROCESS	EPA 533	Perfluorohexanesulfonic acid	PFHxS	11/10/2023 9:40	ND	2.09	2.09	ng/L	0.86	10
Chateau Well 3	NY-Chateau	Compliance	PROCESS	EPA 533	Perfluorohexanoic acid	PFHxA	11/10/2023 9:40	ND	7.58	7.58	ng/L	0.86	NA
Chateau Well 3	NY-Chateau	Compliance	PROCESS	EPA 533	Perfluorononanoic acid	PFNA	11/10/2023 9:40	ND	0.92	0.92	ng/L	0.86	10
Chateau Well 3	NY-Chateau	Compliance	PROCESS	EPA 533	Perfluorooctanesulfonic acid	PFOS	11/10/2023 9:40	ND	8.9	8.9	ng/L	0.86	10
Chateau Well 3	NY-Chateau	Compliance	PROCESS	EPA 533	Perfluoropentanesulfonic acid	PFPeS	11/10/2023 9:40	ND	0	ng/L	0.86	NA	
Chateau Well 3	NY-Chateau	Compliance	PROCESS	EPA 533	Perfluoropentanoic acid	PFPeA	11/10/2023 9:40	ND	8.87	8.87	ng/L	0.86	NA
Chateau Well 3	NY-Chateau	Compliance	PROCESS	EPA 533	Perfluoroundecanoic acid	PFUnA	11/10/2023 9:40	ND	0	ng/L	0.86	NA	
Chateau Well 3	NY-Chateau	Compliance	PROCESS	EPA 537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid	NEtFOSAA	11/10/2023 9:40	ND	0	ng/L	0.93	NA	
Chateau Well 3	NY-Chateau	Compliance	PROCESS	EPA 537.1	N-methyl Perfluorooctanesulfonamidoacetic acid	NMFEFOSAA	11/10/2023 9:40	ND	0	ng/L	0.93	NA	
Chateau Well 3	NY-Chateau	Compliance	PROCESS	EPA 537.1	Perfluorotetradecanoic acid	PFTeDA	11/10/2023 9:40	ND	0	ng/L	0.93	NA	
Chateau Well 3	NY-Chateau	Compliance	PROCESS	EPA 537.1	Perfluorotridecanoic acid	PFTrDA	11/10/2023 9:40	ND	0	ng/L	0.93	NA	
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 522	1,4-Dioxane	1,4-Dioxane	1/16/2024	ND	0	ug/L	0.2	1	
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	11-chloroheptafluoro-3-oxaundecane-1-sulfonic acid	11Cl-PF3OUdS	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	8:2 FTS	1/18/2024	ND	0	ng/L	1.85	NA	
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	4:2 FTS	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	6:2 FTS	1/18/2024	ND	0	ng/L	1.85	NA	
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	4,8-dioxo-3H-perfluorononanoic acid (ADONA)	ADONA	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9Cl-9CI-PF3ONS)	9Cl-9CI-PF3ONS	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Hexafluoropropylene oxide dimer acid (HFPO-DA)(Ge)	HFPO-DA/GenX	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtF)	NEtFOSAA	1/18/2024	ND	0	ng/L	0.893	NA	
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 537.1	N-methyl Perfluorooctanesulfonamidoacetic acid (NMv)	NMFEFOSAA	1/18/2024	ND	0	ng/L	0.893	NA	
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	NFDHA	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	PFEESA	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBA)	PFMBA	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	1/18/2024	7.08	7.08	ng/L	0.926	NA	
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	1/18/2024	5.35	5.35	ng/L	0.926	NA	
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorododecanoic acid (PFDoA)	PFDoA	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	1/18/2024	ND	0	ng/L	1.85	NA	
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	1/18/2024	2.58	2.58	ng/L	0.926	NA	
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorohexanesulfonic acid (PFHxS)	PFHxS	1/18/2024	2.06	2.06	ng/L	0.926	NA	
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	1/18/2024	6.47	6.47	ng/L	0.926	NA	
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	1/18/2024	0.988	0.988	ng/L	0.926	NA	
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	1/18/2024	14.9	14.9	ng/L	0.926	10	
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	1/18/2024	10.6	10.6	ng/L	0.926	10	
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	1/18/2024	7	7	ng/L	0.926	NA	
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorotetradecanoic acid (PFTeDA)	PFTeDA	1/18/2024	ND	0	ng/L	0.893	NA	
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorotridecanoic acid (PFTrDA)	PFTrDA	1/18/2024	ND	0	ng/L	0.893	NA	
Chateau Raw Combined	NY-Chateau	Calculated	PFAS-DIOXANE	Calculated	PFAS EC13	Calculated PFAS EC13	1/18/2024	35.156	35.156	ng/L	NA		
Chateau Raw Combined	NY-Chateau	Calculated	PFAS-DIOXANE	Calculated	PFAS EC6	Calculated PFAS EC6	1/18/2024	6.48	6.48	ng/L	NA		
Chateau Raw Combined	NY-Chateau	Calculated	PFAS-DIOXANE	Calculated	PFAS6	Calculated PFAS6	1/18/2024	32.054	32.054	ng/L	NA		
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	11-chloroheptafluoro-3-oxaundecane-1-sulfonic acid	11Cl-PF3OUdS	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	8:2 FTS	1/18/2024	ND	0	ng/L	1.85	NA	
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	4:2 FTS	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	6:2 FTS	1/18/2024	ND	0	ng/L	1.85	NA	
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	4,8-dioxo-3H-perfluorononanoic acid (ADONA)	ADONA	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9Cl-9CI-PF3ONS)	9Cl-9CI-PF3ONS	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Hexafluoropropylene oxide dimer acid (HFPO-DA)(Ge)	HFPO-DA/GenX	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtF)	NEtFOSAA	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 537.1	N-methyl Perfluorooctanesulfonamidoacetic acid (NMv)	NMFEFOSAA	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	NFDHA	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	PFEESA	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBA)	PFMBA	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorododecanoic acid (PFDoA)	PFDoA	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	1/18/2024	ND	0	ng/L	1.85	NA	
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorohexanesulfonic acid (PFHxS)	PFHxS	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	1/18/2024	ND	0	ng/L	0.926	NA	
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanesulfonic acid (PF								





	System	Type	Project	Method	Analyte	Analyte Acronym	Sample Date	Final	Results	Units	MRL	MCL
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Nonafluoro-3,6-dioxheptanoic acid (NFDHA)	NFDHA	7/15/2024	ND	0 ng/L		0.94 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Nonafluoro-3,6-dioxheptanoic acid (NFDHA)	NFDHA	7/15/2024	ND	0 ng/L		0.93 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	PFEEESA	7/15/2024	ND	0 ng/L		0.94 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	PFEEESA	7/15/2024	ND	0 ng/L		0.93 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	7/15/2024	ND	0 ng/L		0.94 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	7/15/2024	ND	0 ng/L		0.93 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBA)	PFMBA	7/15/2024	ND	0 ng/L		0.94 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBA)	PFMBA	7/15/2024	ND	0 ng/L		0.93 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	7/15/2024	ND	0 ng/L		0.94 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	7/15/2024	5.63	5.63 ng/L		0.93 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	7/15/2024	ND	0 ng/L		0.94 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	7/15/2024	5.14	5.14 ng/L		0.93 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	7/15/2024	ND	0 ng/L		0.94 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	7/15/2024	ND	0 ng/L		0.93 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorododecanoic acid (PFDoA)	PFDoA	7/15/2024	ND	0 ng/L		0.94 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorododecanoic acid (PFDoA)	PFDoA	7/15/2024	ND	0 ng/L		0.93 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	7/15/2024	ND	0 ng/L		1.88 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	7/15/2024	ND	0 ng/L		1.85 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	7/15/2024	ND	0 ng/L		0.94 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	7/15/2024	3.44	3.44 ng/L		0.93 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorohexanesulfonic acid (PFHxS)	PFHxS	7/15/2024	ND	0 ng/L		0.94 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorohexanesulfonic acid (PFHxS)	PFHxS	7/15/2024	2.34	2.34 ng/L		0.93 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	7/15/2024	ND	0 ng/L		0.94 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	7/15/2024	6.45	6.45 ng/L		0.93 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	7/15/2024	ND	0 ng/L		0.94 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	7/15/2024	1.17	1.17 ng/L		0.93 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	7/15/2024	ND	0 ng/L		0.94	10 ng/L
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	7/15/2024	14.6	14.6 ng/L		0.93	10 ng/L
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	7/15/2024	ND	0 ng/L		0.94	10 ng/L
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	7/15/2024	11.9	11.9 ng/L		0.93	10 ng/L
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	7/15/2024	ND	0 ng/L		0.94 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	7/15/2024	ND	0 ng/L		0.93 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	7/15/2024	ND	0 ng/L		0.94 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	7/15/2024	6.97	6.97 ng/L		0.93 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorotetradecanoic acid (PFTeDA)	PFTeDA	7/15/2024	ND	0 ng/L		1.89 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorotetradecanoic acid (PFTeDA)	PFTeDA	7/15/2024	ND	0 ng/L		1.83 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorotridecanoic acid (PFTrDA)	PFTrDA	7/15/2024	ND	0 ng/L		1.89 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 537.1	Perfluorotridecanoic acid (PFTrDA)	PFTrDA	7/15/2024	ND	0 ng/L		1.83 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	7/15/2024	ND	0 ng/L		0.94 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	PFAS-DIOXANE	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	7/15/2024	ND	0 ng/L		0.93 NA	ng/L

List of Abbreviations:

MRL = Method Reporting Limit

ppt = parts per trillion

ppb = parts per billion

Analytical results depicted from 9/2020 through 6/2022 are EPA Method 537. Analytical results from 7/2022 to date are EPA Method 533.

EPA Method 537.1 data from 7/2022 to date is also included in the table.

Table has been sorted by sample date

\*Beginning Q2 2023, Veolia Water New York made the following changes to its PFAS sampling protocol. Method 533 is used to analyze all 25 unique PFAS compounds covered by this Method as indicated on the US EPA, Office of Water, table number MS-140 dated December 2019. Method 537.1 is used to analyze only the 4 additional PFAS compounds not addressed by Method 533 as presented in the same above reference EPA table. Supplemental reports will also reflect this change beginning Q2 2023.

\*\* As systems are placed into service, the locations of samples/analysis are modified from individual well results to the following locations per DOH requirement.

Locations include "Combine Raw", "Discharge from Lead Vessel(s)" and "Effluent"

All Rockland locations have been added to this supplemental report per NYSDOH Request following Q3 2022

Not all wells sampled within the quarter were operational for that quarter

\*Beginning Q2 2023, Veolia Water New York made the following changes to its PFAS sampling protocol. Method 533 is used to analyze all 25 unique PFAS compounds covered by this Method as indicated on the US EPA, Office of Water, table number MS-140 dated December 2019. Method 537.1 is used to analyze only the 4 additional PFAS compounds not addressed by Method 533 as presented in the same above reference EPA table. Supplemental reports also reflects this change beginning Q2 2023.