

VWNY - Supplemental Sample Test Results Putnam County - Chateau -Q1 2026

April 14, 2026 (V1)

Site	System	Type	Method	Analyte	Analyte Acronym	Sample Date	Final	Final	Units	MRL	MCL
CHATEAU WELL 1	Chateau	Compliance	EPA 537.1	N-ethylperfluorooctanesulfonamidoacetic acid	NEtFOSAA	4/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 537.1	N-methylperfluorooctanesulfonamidoacetic acid	NMeFOSAA	4/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 537.1	Perfluorotetradecanoic acid	PFTA	4/25/2023		0	ppt	2	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 537.1	Perfluorotridecanoic acid	PFTDA	4/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 537.1	N-ethylperfluorooctanesulfonamidoacetic acid	NEtFOSAA	4/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 537.1	N-methylperfluorooctanesulfonamidoacetic acid	NMeFOSAA	4/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 537.1	Perfluorotetradecanoic acid	PFTA	4/25/2023		0	ppt	2	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 537.1	Perfluorotridecanoic acid	PFTDA	4/25/2023		0	ppt	2	NA
CHATEAU RAW COMBO	Chateau		EPA 533	11-chloroicosafluoro-3-oxaundecane-1-sulfonic acid	11Cl-PF3OUdS	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau		EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau		EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau		EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau		EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid	9Cl-PF3ONS	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau		EPA 533	4,8-dioxo-3H-perfluorononanoic acid (ADONA)	ADONA	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau		EPA 533	Hexafluoropropylene oxide dimer acid	HFPO-DA/GenX	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau		EPA 533	Nonafluoro-3,6-dioxaheptanoic acid	NFDHA	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau		EPA 533	Perfluorobutanoic acid	PFBA	08/31/2023 11:45		3.58	ng/L		NA
CHATEAU RAW COMBO	Chateau		EPA 533	Perfluorobutanesulfonic acid	PFBS	08/31/2023 11:45		4.03	ng/L		NA
CHATEAU RAW COMBO	Chateau		EPA 533	Perfluorodecanoic acid	PFDA	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau		EPA 533	Perfluorododecanoic acid	PFDaA	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau		EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid	PFEESA	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau		EPA 533	Perfluoroheptanoic acid	PFHPA	08/31/2023 11:45		1.89	ng/L		NA
CHATEAU RAW COMBO	Chateau		EPA 533	Perfluoroheptanesulfonic acid	PFHPs	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau		EPA 533	Perfluoroheptanoic acid	PFHxA	08/31/2023 11:45		4.48	ng/L		NA
CHATEAU RAW COMBO	Chateau		EPA 533	Perfluorohexanesulfonic acid	PFHxS	08/31/2023 11:45		1.46	ng/L		NA
CHATEAU RAW COMBO	Chateau		EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBA	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau		EPA 533	Perfluoro-3-methoxypropanoic acid	PFMPA	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau		EPA 533	Perfluorononanoic acid	PFNA	08/31/2023 11:45		0.528	ng/L		NA
CHATEAU RAW COMBO	Chateau		EPA 533	Perfluorooctanesulfonic acid	PFOS	08/31/2023 11:45		8.92	ng/L		10
CHATEAU RAW COMBO	Chateau		EPA 533	Perfluoropentanoic acid	PFPeA	08/31/2023 11:45		5.04	ng/L		NA
CHATEAU RAW COMBO	Chateau		EPA 533	Perfluoropentanesulfonic acid	PFPeS	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau		EPA 533	Perfluoroundecanoic acid	PFUnA	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau		EPA 537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid	NEtFOSAA	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau		EPA 537.1	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau		EPA 537.1	Perfluorotetradecanoic acid	PFTA	08/31/2023 11:45		0	ng/L		NA
CHATEAU RAW COMBO	Chateau		EPA 537.1	Perfluorotridecanoic acid	PFTDA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau		EPA 537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid	NEtFOSAA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau		EPA 537.1	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau		EPA 537.1	Perfluorotetradecanoic acid	PFTA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau		EPA 537.1	Perfluorotridecanoic acid	PFTDA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau		EPA 533	11-chloroicosafluoro-3-oxaundecane-1-sulfonic acid	11Cl-PF3OUdS	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau		EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau		EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau		EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau		EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid	9Cl-PF3ONS	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau		EPA 533	4,8-dioxo-3H-perfluorononanoic acid (ADONA)	ADONA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau		EPA 533	Hexafluoropropylene oxide dimer acid	HFPO-DA/GenX	08/31/2023 11:45		0.611	ng/L		NA
CHATEAU POE	Chateau		EPA 533	Nonafluoro-3,6-dioxaheptanoic acid	NFDHA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau		EPA 533	Perfluorobutanoic acid	PFBA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau		EPA 533	Perfluorobutanesulfonic acid	PFBS	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau		EPA 533	Perfluorodecanoic acid	PFDA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau		EPA 533	Perfluorododecanoic acid	PFDaA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau		EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid	PFEESA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau		EPA 533	Perfluoroheptanoic acid	PFHPA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau		EPA 533	Perfluoroheptanesulfonic acid	PFHPs	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau		EPA 533	Perfluoroheptanoic acid	PFHxA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau		EPA 533	Perfluorohexanesulfonic acid	PFHxS	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau		EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau		EPA 533	Perfluoro-3-methoxypropanoic acid	PFMPA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau		EPA 533	Perfluorononanoic acid	PFNA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau		EPA 533	Perfluorooctanesulfonic acid	PFOS	08/31/2023 11:45		0	ng/L		10
CHATEAU POE	Chateau		EPA 533	Perfluoropentanoic acid	PFPeA	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau		EPA 533	Perfluoropentanesulfonic acid	PFPeS	08/31/2023 11:45		0	ng/L		NA
CHATEAU POE	Chateau		EPA 533	Perfluoroundecanoic acid	PFUnA	08/31/2023 11:45		0	ng/L		NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	11-chloroicosafluoro-3-oxaundecane-1-sulfonic acid	11Cl-PF3OUdS	10/20/2023 9:00	ND	0	ng/L	0.45	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	10/20/2023 9:00	ND	0	ng/L	0.89	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	10/20/2023 9:00	ND	0	ng/L	0.45	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	10/20/2023 9:00	2.13	2.13	ng/L	1.79	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	4,8-dioxo-3H-perfluorononanoic acid	ADONA	10/20/2023 9:00	ND	0	ng/L	0.45	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid	9Cl-PF3ONS	10/20/2023 9:00	ND	0	ng/L	0.45	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid	HFPO-DA/GenX	10/20/2023 9:00	ND	0	ng/L	0.45	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxaheptanoic acid	NFDHA	10/20/2023 9:00	ND	0	ng/L	0.45	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid	PFEESA	10/20/2023 9:00	ND	0	ng/L	0.45	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid	PFMPA	10/20/2023 9:00	ND	0	ng/L	0.45	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBA	10/20/2023 9:00	ND	0	ng/L	0.45	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid	PFBS	10/20/2023 9:00	4.73	4.73	ng/L	0.45	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid	PFBA	10/20/2023 9:00	4.17	4.17	ng/L	0.45	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid	PFDA	10/20/2023 9:00	ND	0	ng/L	0.45	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid	PFDaA	10/20/2023 9:00	ND	0	ng/L	0.45	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid	PFHPs	10/20/2023 9:00	ND	0	ng/L	0.89	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid	PFHPA	10/20/2023 9:00	2.11	2.11	ng/L	0.45	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid	PFHxS	10/20/2023 9:00	1.79	1.79	ng/L	0.45	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid	PFHxA	10/20/2023 9:00	4.7	4.7	ng/L	0.45	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid	PFNA	10/20/2023 9:00	0.57	0.57	ng/L	0.45	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid	PFOS	10/20/2023 9:00	7.64	7.64	ng/L	0.45	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid	PFPeS	10/20/2023 9:00	ND	0	ng/L	0.45	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid	PFPeA	10/20/2023 9:00	4.82	4.82	ng/L	0.45	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid	PFUnA	10/20/2023 9:00	ND	0	ng/L	0.45	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid	NEtFOSAA	10/20/2023 9:00	ND	0	ng/L	0.91	NA

VWNY - Supplemental Sample Test Results Putnam County - Chateau -Q1 2026

April 14, 2026 (V1)

Site	System	Type	Method	Analyte	Analyte Acronym	Sample Date	Final	Final	Units	MRL	MCL
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	N-methyl Perfluorooctanesulfonamidoacetic acid	NMEFOSAA	10/20/2023 9:00	ND		0 ng/L	0.91 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	Perfluorotetradecanoic acid	PFTeDA	10/20/2023 9:00	ND		0 ng/L	0.91 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	Perfluorotridecanoic acid	PFTrDA	10/20/2023 9:00	ND		0 ng/L	0.91 NA	
Chateau POE	NY-Chateau	Compliance	EPA 533	11-chloroicosafuoro-3-oxaundecane-1-sulfonic acid	11CI-PF30UdS	10/20/2023 9:09	ND		0 ng/L	0.42 NA	
Chateau POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	10/20/2023 9:09	ND		0 ng/L	0.83 NA	
Chateau POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	10/20/2023 9:09	ND		0 ng/L	0.42 NA	
Chateau POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	10/20/2023 9:09	ND		0 ng/L	1.67 NA	
Chateau POE	NY-Chateau	Compliance	EPA 533	4,8-dioxa-3H-perfluorononanoic acid	ADONA	10/20/2023 9:09	ND		0 ng/L	0.42 NA	
Chateau POE	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid	9CI-PF30NS	10/20/2023 9:09	ND		0 ng/L	0.42 NA	
Chateau POE	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid	HFPO-DA/GenX	10/20/2023 9:09	ND		0 ng/L	0.42	10
Chateau POE	NY-Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxaheptanoic acid	NFDHA	10/20/2023 9:09	ND		0 ng/L	0.42 NA	
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid	PFEESA	10/20/2023 9:09	ND		0 ng/L	0.42 NA	
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid	PFMPA	10/20/2023 9:09	ND		0 ng/L	0.42 NA	
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBA	10/20/2023 9:09	ND		0 ng/L	0.42 NA	
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid	PFBS	10/20/2023 9:09	ND		0 ng/L	0.42 NA	
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid	PFBA	10/20/2023 9:09	0.82	0.82	ng/L	0.42 NA	
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid	PFDA	10/20/2023 9:09	ND		0 ng/L	0.42	10
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid	PFDoA	10/20/2023 9:09	ND		0 ng/L	0.42 NA	
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid	PFHpS	10/20/2023 9:09	ND		0 ng/L	0.83 NA	
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid	PFHpA	10/20/2023 9:09	ND		0 ng/L	0.42	10
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid	PFHxS	10/20/2023 9:09	ND		0 ng/L	0.42	10
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid	PFHxA	10/20/2023 9:09	ND		0 ng/L	0.42 NA	
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid	PFNA	10/20/2023 9:09	ND		0 ng/L	0.42	10
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid	PFOS	10/20/2023 9:09	ND		0 ng/L	0.42	10
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid	PFPeS	10/20/2023 9:09	ND		0 ng/L	0.42 NA	
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid	PFPeA	10/20/2023 9:09	ND		0 ng/L	0.42 NA	
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid	PFUnA	10/20/2023 9:09	ND		0 ng/L	0.42 NA	
Chateau POE	NY-Chateau	Compliance	EPA 537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid	NETFOSAA	10/20/2023 9:09	ND		0 ng/L	0.89 NA	
Chateau POE	NY-Chateau	Compliance	EPA 537.1	N-methyl Perfluorooctanesulfonamidoacetic acid	NMEFOSAA	10/20/2023 9:09	ND		0 ng/L	0.89 NA	
Chateau POE	NY-Chateau	Compliance	EPA 537.1	Perfluorotetradecanoic acid	PFTeDA	10/20/2023 9:09	ND		0 ng/L	0.89 NA	
Chateau POE	NY-Chateau	Compliance	EPA 537.1	Perfluorotridecanoic acid	PFTrDA	10/20/2023 9:09	ND		0 ng/L	0.89 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	11-chloroicosafuoro-3-oxaundecane-1-sulfonic acid	11CI-PF30UdS	11/10/2023 9:40	ND		0 ng/L	0.86 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	11/10/2023 9:40	ND		0 ng/L	1.72 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	11/10/2023 9:40	ND		0 ng/L	0.86 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	11/10/2023 9:40	ND		0 ng/L	1.72 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	4,8-dioxa-3H-perfluorononanoic acid	ADONA	11/10/2023 9:40	ND		0 ng/L	0.86 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid	9CI-PF30NS	11/10/2023 9:40	ND		0 ng/L	0.86 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid	HFPO-DA/GenX	11/10/2023 9:40	ND		0 ng/L	0.86	10
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxaheptanoic acid	NFDHA	11/10/2023 9:40	ND		0 ng/L	0.86 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid	PFEESA	11/10/2023 9:40	ND		0 ng/L	0.86 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid	PFMPA	11/10/2023 9:40	ND		0 ng/L	0.86 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBA	11/10/2023 9:40	ND		0 ng/L	0.86 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid	PFBS	11/10/2023 9:40	6.56	6.56	ng/L	0.86 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid	PFBA	11/10/2023 9:40	9.83	9.83	ng/L	0.86 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid	PFDA	11/10/2023 9:40	ND		0 ng/L	0.86	10
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid	PFDoA	11/10/2023 9:40	ND		0 ng/L	0.86 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid	PFHpS	11/10/2023 9:40	ND		0 ng/L	1.72 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid	PFHpA	11/10/2023 9:40	3.95	3.95	ng/L	0.86	10
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid	PFHxS	11/10/2023 9:40	2.09	2.09	ng/L	0.86	10
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid	PFHxA	11/10/2023 9:40	7.58	7.58	ng/L	0.86 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid	PFNA	11/10/2023 9:40	0.92	0.92	ng/L	0.86	10
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid	PFOS	11/10/2023 9:40	8.9	8.9	ng/L	0.86	10
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid	PFPeS	11/10/2023 9:40	ND		0 ng/L	0.86 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid	PFPeA	11/10/2023 9:40	8.87	8.87	ng/L	0.86 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid	PFUnA	11/10/2023 9:40	ND		0 ng/L	0.86 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid	NETFOSAA	11/10/2023 9:40	ND		0 ng/L	0.93 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 537.1	N-methyl Perfluorooctanesulfonamidoacetic acid	NMEFOSAA	11/10/2023 9:40	ND		0 ng/L	0.93 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 537.1	Perfluorotetradecanoic acid	PFTeDA	11/10/2023 9:40	ND		0 ng/L	0.93 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 537.1	Perfluorotridecanoic acid	PFTrDA	11/10/2023 9:40	ND		0 ng/L	0.93 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 522	1,4-Dioxane	1,4-Dioxane	1/16/2024	ND		0 ug/L	0.2	1
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	11-chloroicosafuoro-3-oxaundecane-1-sulfonic acid	11CI-PF30UdS	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	8:2 FTS	1/18/2024	ND		0 ng/L	1.85 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	4:2 FTS	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	6:2 FTS	1/18/2024	ND		0 ng/L	1.85 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	4,8-dioxa-3H-perfluorononanoic acid (ADONA)	ADONA	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9CI-9CI-PF30NS)	9CI-9CI-PF30NS	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid (HFPO-DA)(Ge HFPO-DA/GenX)	HFPO-DA/GenX	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid (NETF)	NETFOSAA	1/18/2024	ND		0 ng/L	0.893 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	N-methyl Perfluorooctanesulfonamidoacetic acid (NM NMEFOSAA)	NMEFOSAA	1/18/2024	ND		0 ng/L	0.893 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	NFDHA	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	PFEESA	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBA)	PFMBA	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	1/18/2024	7.08	7.08	ng/L	0.926 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	1/18/2024	5.35	5.35	ng/L	0.926 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid (PFDoA)	PFDoA	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	1/18/2024	ND		0 ng/L	1.85 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	1/18/2024	2.58	2.58	ng/L	0.926 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid (PFHxS)	PFHxS	1/18/2024	2.06	2.06	ng/L	0.926 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid (PFHxA)	PFHxA	1/18/2024	6.47	6.47	ng/L	0.926 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	1/18/2024	0.988	0.988	ng/L	0.926 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	1/18/2024	14.9	14.9	ng/L	0.926	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	1/18/2024	10.6	10.6	ng/L	0.926	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	1/18/2024	7	7	ng/L	0.926 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	Perfluorotetradecanoic acid (PFTeDA)	PFTeDA	1/18/2024	ND		0 ng/L	0.893 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	Perfluorotridecanoic acid (PFTrDA)	PFTrDA	1/18/2024	ND		0 ng/L	0.893 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	1/18/2024	ND		0 ng/L	0.926 NA	

Site	System	Type	Method	Analyte	Analyte Acronym	Sample Date	Final	Final	Units	MRL	MCL
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	11-chloroicosafuoro-3-oxaundecane-1-sulfonic acid	11Cl-PF3OUdS	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	8:2 FTS	1/18/2024	ND		0 ng/L	1.85 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	4:2 FTS	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	6:2 FTS	1/18/2024	ND		0 ng/L	1.85 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	4,8-dioxia-3H-perfluorononanoic acid (ADONA)	ADONA	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9Cl-9Cl-PF3ONS)		1/18/2024	ND		0 ng/L	0.926 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid (HFPO-DA)(Ge)	HFPO-DA/GenX	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid (NETF)	NETF/NETFOSAA	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	N-methyl Perfluorooctanesulfonamidoacetic acid (NMMeFOSAA)		1/18/2024	ND		0 ng/L	0.926 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	NFDHA	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	PFEEESA	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBA)	PFMBA	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid (PFDoA)	PFDoA	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	1/18/2024	ND		0 ng/L	1.85 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid (PFHxS)	PFHxS	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	1/18/2024	ND		0 ng/L	0.926	10
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	1/18/2024	ND		0 ng/L	0.926	10
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	Perfluorotetradecanoic acid (PFTeDA)	PFTeDA	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	Perfluorotridecanoic acid (PFTrDA)	PFTrDA	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	1/18/2024	ND		0 ng/L	0.926 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	11-chloroicosafuoro-3-oxaundecane-1-sulfonic acid	11Cl-PF3OUdS	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	11-chloroicosafuoro-3-oxaundecane-1-sulfonic acid	11Cl-PF3OUdS	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	8:2 FTS	4/16/2024	ND		0 ng/L	1.7 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	8:2 FTS	4/16/2024	ND		0 ng/L	1.8 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	4:2 FTS	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	4:2 FTS	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	6:2 FTS	4/16/2024	ND		0 ng/L	1.7 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	6:2 FTS	4/16/2024	ND		0 ng/L	1.8 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	4,8-dioxia-3H-perfluorononanoic acid (ADONA)	ADONA	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	4,8-dioxia-3H-perfluorononanoic acid (ADONA)	ADONA	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9Cl-9Cl-PF3ONS)		4/16/2024	ND		0 ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9Cl-9Cl-PF3ONS)		4/16/2024	ND		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid (HFPO-DA)(Ge)	HFPO-DA/GenX	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid (HFPO-DA)(Ge)	HFPO-DA/GenX	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid (NETF)	NETF/NETFOSAA	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid (NETF)	NETF/NETFOSAA	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	N-methyl Perfluorooctanesulfonamidoacetic acid (NMMeFOSAA)		4/16/2024	ND		0 ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	N-methyl Perfluorooctanesulfonamidoacetic acid (NMMeFOSAA)		4/16/2024	ND		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	NFDHA	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	NFDHA	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	PFEEESA	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	PFEEESA	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBA)	PFMBA	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBA)	PFMBA	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	4/16/2024	5.9	5.9	ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	4/16/2024	4.85	4.85	ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid (PFDoA)	PFDoA	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid (PFDoA)	PFDoA	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	4/16/2024	ND		0 ng/L	1.7 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	4/16/2024	ND		0 ng/L	1.8 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	4/16/2024	3.12	3.12	ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid (PFHxS)	PFHxS	4/16/2024	2.12	2.12	ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid (PFHxS)	PFHxS	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	4/16/2024	4.8	4.8	ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	4/16/2024	0.88	0.88	ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	4/16/2024	10.7	10.7	ng/L	0.9	10
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	4/16/2024	ND		0 ng/L	0.9	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	4/16/2024	9.38	9.38	ng/L	0.9	10
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	4/16/2024	ND		0 ng/L	0.9	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	4/16/2024	5.92	5.92	ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	Perfluorotetradecanoic acid (PFTeDA)	PFTeDA	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	Perfluorotetradecanoic acid (PFTeDA)	PFTeDA	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	Perfluorotridecanoic acid (PFTrDA)	PFTrDA	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	Perfluorotridecanoic acid (PFTrDA)	PFTrDA	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	4/16/2024	ND		0 ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	11-chloroicosafuoro-3-oxaundecane-1-sulfonic acid	11Cl-PF3OUdS	7/15/2024	ND		0 ng/L	0.94 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	11-chloroicosafuoro-3-oxaundecane-1-sulfonic acid	11Cl-PF3OUdS	7/15/2024	ND		0 ng/L	0.93 NA	

Site	System	Type	Method	Analyte	Analyte Acronym	Sample Date	Final	Final	Units	MRL	MCL	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	8:2 FTS	7/15/2024	ND		0 ng/L	1.88	NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	8:2 FTS	7/15/2024	ND		0 ng/L	1.85	NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	4:2 FTS	7/15/2024	ND		0 ng/L	0.94	NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	4:2 FTS	7/15/2024	ND		0 ng/L	0.93	NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	6:2 FTS	7/15/2024	ND		0 ng/L	1.88	NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	6:2 FTS	7/15/2024	ND		0 ng/L	1.85	NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	4,8-dioxo-3H-perfluorononanoic acid (ADONA)	ADONA	7/15/2024	ND		0 ng/L	0.94	NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	4,8-dioxo-3H-perfluorononanoic acid (ADONA)	ADONA	7/15/2024	ND		0 ng/L	0.93	NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9CI-9CI-PF30NS)		7/15/2024	ND		0 ng/L	0.94	NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9CI-9CI-PF30NS)		7/15/2024	ND		0 ng/L	0.93	NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	Hazard Index	9CI-PF30NS	7/15/2024	ND		0 ng/L		NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	Hazard Index	9CI-PF30NS	7/15/2024	ND		0 ng/L		NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	Hazard Index	9CI-PF30NS	7/15/2024	0.38	0.38	ng/L		NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	Hazard Index	9CI-PF30NS	7/15/2024	0.21	0.21	ng/L		NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid (HFPO-DA)(Ge HFPO-DA)(GenX)		7/15/2024	ND		0 ng/L	0.94	NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid (HFPO-DA)(Ge HFPO-DA)(GenX)		7/15/2024	ND		0 ng/L	0.93	NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid (NETF) NETFOSAA		7/15/2024	ND		0 ng/L	1.89	NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid (NETF) NETFOSAA		7/15/2024	ND		0 ng/L	1.83	NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	N-methyl Perfluorooctanesulfonamidoacetic acid (NM MeFOSAA)		7/15/2024	ND		0 ng/L	1.89	NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	N-methyl Perfluorooctanesulfonamidoacetic acid (NM MeFOSAA)		7/15/2024	ND		0 ng/L	1.83	NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxahexanoic acid (NFDHA)	NFDHA	7/15/2024	ND		0 ng/L	0.94	NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxahexanoic acid (NFDHA)	NFDHA	7/15/2024	ND		0 ng/L	0.93	NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	PFEEESA	7/15/2024	ND		0 ng/L	0.94	NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	PFEEESA	7/15/2024	ND		0 ng/L	0.93	NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	7/15/2024	ND		0 ng/L	0.94	NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	7/15/2024	ND		0 ng/L	0.93	NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBA)	PFMBA	7/15/2024	ND		0 ng/L	0.94	NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBA)	PFMBA	7/15/2024	ND		0 ng/L	0.93	NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	7/15/2024	ND		0 ng/L	0.94	NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	7/15/2024	5.63	5.63	ng/L	0.93	NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	7/15/2024	ND		0 ng/L	0.94	NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	7/15/2024	5.14	5.14	ng/L	0.93	NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	7/15/2024	ND		0 ng/L	0.94	NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	7/15/2024	ND		0 ng/L	0.93	NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid (PFDoA)	PFDoA	7/15/2024	ND		0 ng/L	0.94	NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid (PFDoA)	PFDoA	7/15/2024	ND		0 ng/L	0.93	NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	7/15/2024	ND		0 ng/L	1.88	NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	7/15/2024	ND		0 ng/L	1.85	NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	7/15/2024	ND		0 ng/L	0.94	NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	7/15/2024	3.44	3.44	ng/L	0.93	NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid (PFHxS)	PFHxS	7/15/2024	ND		0 ng/L	0.94	NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid (PFHxS)	PFHxS	7/15/2024	2.34	2.34	ng/L	0.93	NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	7/15/2024	ND		0 ng/L	0.94	NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	7/15/2024	6.45	6.45	ng/L	0.93	NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	7/15/2024	ND		0 ng/L	0.94	NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	7/15/2024	1.17	1.17	ng/L	0.93	NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	7/15/2024	ND		0 ng/L	0.94	10	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	7/15/2024	14.6	14.6	ng/L	0.93	10	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	7/15/2024	ND		0 ng/L	0.94	10	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	7/15/2024	11.9	11.9	ng/L	0.93	10	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	7/15/2024	ND		0 ng/L	0.94	NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	7/15/2024	ND		0 ng/L	0.93	NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	7/15/2024	ND		0 ng/L	0.94	NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	7/15/2024	6.97	6.97	ng/L	0.93	NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	Perfluorotetradecanoic acid (PFTeDA)	PFTeDA	7/15/2024	ND		0 ng/L	1.89	NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	Perfluorotetradecanoic acid (PFTeDA)	PFTeDA	7/15/2024	ND		0 ng/L	1.83	NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	Perfluorotridecanoic acid (PFTrDA)	PFTrDA	7/15/2024	ND		0 ng/L	1.89	NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	Perfluorotridecanoic acid (PFTrDA)	PFTrDA	7/15/2024	ND		0 ng/L	1.83	NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	7/15/2024	ND		0 ng/L	0.94	NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	7/15/2024	ND		0 ng/L	0.93	NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	11-chloroicosadecafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF30UdS	10/28/2024	0		ND	ng/L	1.85	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	8:2 FTS	10/28/2024	0		ND	ng/L	1.85	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	4:2 FTS	10/28/2024	0		ND	ng/L	1.85	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	6:2 FTS	10/28/2024	2.06		2.06	ng/L	1.85	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	4,8-dioxo-3H-perfluorononanoic acid (ADONA)	ADONA	10/28/2024	0		ND	ng/L	1.85	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9CI-9CI-PF30NS)		10/28/2024	0		ND	ng/L	1.85	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid (HFPO-DA)(Ge HFPO-DA)(GenX)		10/28/2024	0		ND	ng/L	1.85	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid (NETF) NETFOSAA		10/28/2024	0		ND	ng/L	1.84	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	N-methyl Perfluorooctanesulfonamidoacetic acid (NM MeFOSAA)		10/28/2024	0		ND	ng/L	1.84	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxahexanoic acid (NFDHA)	NFDHA	10/28/2024	0		ND	ng/L	1.85	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	PFEEESA	10/28/2024	0		ND	ng/L	1.85	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	10/28/2024	0		ND	ng/L	1.85	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBA)	PFMBA	10/28/2024	0		ND	ng/L	1.85	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	10/28/2024	5.24		5.24	ng/L	1.85	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	10/28/2024	6.99		6.99	ng/L	1.85	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	10/28/2024	0		ND	ng/L	1.85	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid (PFDoA)	PFDoA	10/28/2024	0		ND	ng/L	1.85	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	10/28/2024	0		ND	ng/L	1.85	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	10/28/2024	2.97		2.97	ng/L	1.85	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid (PFHxS)	PFHxS	10/28/2024	1.97		1.97	ng/L	1.85	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	10/28/2024	10.7		10.7	ng/L	1.85	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	10/28/2024	0		ND	ng/L	1.85	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	10/28/2024	12.4		12.4	ng/L	1.85	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	10/28/2024	17.7		17.7	ng/L	1.85	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	10/28/2024	0		ND	ng/L	1.85	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	10/28/2024	10.2		10.2	ng/L	1.85	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	Perfluorotetradecanoic acid (PFTeDA)	PFTeDA	10/28/2024	0		ND	ng/L	1.84	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	Perfluorotridecanoic acid (PFTrDA)	PFTrDA	10/28/2024	0		ND	ng/L	1.84	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	10/28/2024	0		ND	ng/L	1.85	NA





Site	System	Type	Method	Analyte	Analyte Acronym	Sample Date	Final	Final	Units	MRL	MCL
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	7/10/2025	8.74	8.74	ng/L	1.95	10
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	7/10/2025	0 ND		ng/L	2.01	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	7/10/2025	0 ND		ng/L	1.95	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	7/10/2025	0 ND		ng/L	2.01	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	7/10/2025	5.89	5.89	ng/L	1.95	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	7/10/2025	0 ND		ng/L	2.01	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	7/10/2025	0 ND		ng/L	1.95	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	11-chloroicosafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	10/23/2025	0 ND		ng/L	1.99	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	11-chloroicosafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	10/23/2025	0 ND		ng/L	1.8	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	8:2 FTS	10/23/2025	0 ND		ng/L	1.99	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	8:2 FTS	10/23/2025	0 ND		ng/L	1.8	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	4:2 FTS	10/23/2025	0 ND		ng/L	1.99	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	4:2 FTS	10/23/2025	0 ND		ng/L	1.8	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	6:2 FTS	10/23/2025	0 ND		ng/L	1.99	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	6:2 FTS	10/23/2025	0 ND		ng/L	1.8	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	4,8-dioxo-3H-perfluorononanoic acid (ADONA)	ADONA	10/23/2025	0 ND		ng/L	1.99	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	4,8-dioxo-3H-perfluorononanoic acid (ADONA)	ADONA	10/23/2025	0 ND		ng/L	1.8	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9CI-9CI-PF3ONS)	9CI-9CI-PF3ONS	10/23/2025	0 ND		ng/L	1.99	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9CI-9CI-PF3ONS)	9CI-9CI-PF3ONS	10/23/2025	0 ND		ng/L	1.8	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid (HFPO-DA)(Ge)	HFPO-DA)(GenX	10/23/2025	0 ND		ng/L	1.99	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid (HFPO-DA)(Ge)	HFPO-DA)(GenX	10/23/2025	0 ND		ng/L	1.8	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxahexanoic acid (NFDHA)	NFDHA	10/23/2025	0 ND		ng/L	1.99	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxahexanoic acid (NFDHA)	NFDHA	10/23/2025	0 ND		ng/L	1.8	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	PFEESA	10/23/2025	0 ND		ng/L	1.99	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	PFEESA	10/23/2025	0 ND		ng/L	1.8	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	10/23/2025	0 ND		ng/L	1.99	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	10/23/2025	0 ND		ng/L	1.8	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBA)	PFMBA	10/23/2025	0 ND		#N/A	1.99	#N/A
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBA)	PFMBA	10/23/2025	0 ND		#N/A	1.8	#N/A
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	10/23/2025	7.2	7.2	ng/L	1.99	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	10/23/2025	0 ND		ng/L	1.8	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	10/23/2025	8.76	8.76	ng/L	1.99	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	10/23/2025	0 ND		ng/L	1.8	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	10/23/2025	0 ND		ng/L	1.99	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	10/23/2025	0 ND		ng/L	1.8	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid (PFDOa)	PFDOa	10/23/2025	0 ND		ng/L	1.99	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid (PFDOa)	PFDOa	10/23/2025	0 ND		ng/L	1.8	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	10/23/2025	0 ND		ng/L	1.99	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	10/23/2025	0 ND		ng/L	1.8	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	10/23/2025	5.29	5.29	ng/L	1.99	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	10/23/2025	0 ND		ng/L	1.8	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid (PFHxS)	PFHxS	10/23/2025	1.91	1.91	ng/L	1.99	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid (PFHxS)	PFHxS	10/23/2025	0 ND		ng/L	1.8	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	10/23/2025	11.4	11.4	ng/L	1.99	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	10/23/2025	0 ND		ng/L	1.8	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	10/23/2025	2.15	2.15	ng/L	1.99	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	10/23/2025	0 ND		ng/L	1.8	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	10/23/2025	15.4	15.4	ng/L	1.99	10
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	10/23/2025	0 ND		ng/L	1.8	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	10/23/2025	17.5	17.5	ng/L	1.99	10
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	10/23/2025	0 ND		ng/L	1.8	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	10/23/2025	0 ND		ng/L	1.99	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	10/23/2025	0 ND		ng/L	1.8	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	10/23/2025	13.8	13.8	ng/L	1.99	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	10/23/2025	0 ND		ng/L	1.8	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	10/23/2025	0 ND		ng/L	1.99	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	10/23/2025	0 ND		ng/L	1.8	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	11-chloroicosafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	2/6/2026	0 ND		ng/L	2	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	8:2 FTS	2/6/2026	0 ND		ng/L	2	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	4:2 FTS	2/6/2026	0 ND		ng/L	2	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	6:2 FTS	2/6/2026	0 ND		ng/L	2	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	4,8-dioxo-3H-perfluorononanoic acid (ADONA)	ADONA	2/6/2026	0 ND		ng/L	2	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9CI-9CI-PF3ONS)	9CI-9CI-PF3ONS	2/6/2026	0 ND		ng/L	2	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid (HFPO-DA)(Ge)	HFPO-DA)(GenX	2/6/2026	0 ND		ng/L	2	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxahexanoic acid (NFDHA)	NFDHA	2/6/2026	0 ND		ng/L	2	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	PFEESA	2/6/2026	0 ND		ng/L	2	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	2/6/2026	0 ND		ng/L	2	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBA)	PFMBA	2/6/2026	0 ND		ng/L	2	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	2/6/2026	5.58	5.58	ng/L	2	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	2/6/2026	6.07	6.07	ng/L	2	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	2/6/2026	0 ND		ng/L	2	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid (PFDOa)	PFDOa	2/6/2026	0 ND		ng/L	2	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	2/6/2026	0 ND		ng/L	2	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	2/6/2026	2.97	2.97	ng/L	2	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid (PFHxS)	PFHxS	2/6/2026	0 ND		ng/L	2	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	2/6/2026	6.21	6.21	ng/L	2	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	2/6/2026	6.21	6.21	ng/L	2	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	2/6/2026	0 ND		ng/L	2	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	2/6/2026	11.8	11.8	ng/L	2	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	2/6/2026	9.94	9.94	ng/L	2	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	2/6/2026	0 ND		ng/L	2	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	2/6/2026	6.98	6.98	ng/L	2	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	2/6/2026	0 ND		ng/L	2	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	11-chloroicosafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	2/6/2026	0 ND		ng/L	2	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	8:2 FTS	2/6/2026	0 ND		ng/L	2	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	4:2 FTS	2/6/2026	0 ND		ng/L	2	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	6:2 FTS	2/6/2026	0 ND		ng/L	2	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	4,8-dioxo-3H-perfluorononanoic acid (ADONA)	ADONA	2/6/2026	0 ND		ng/L	2	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9CI-9CI-PF3ONS)	9CI-9CI-PF3ONS	2/6/2026	0 ND		ng/L	2	NA

Site	System	Type	Method	Analyte	Analyte Acronym	Sample Date	Final	Final	Units	MRL	MCL
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid (HFPO-DA)(Ge	HFPO-DA)(GenX	2/6/2026	0	ND	ng/L		2 NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Nonfluoro-3,6-dioxahexanoic acid (NFDHA)	NFDHA	2/6/2026	0	ND	ng/L		2 NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEEESA)	PFEEESA	2/6/2026	0	ND	ng/L		2 NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	2/6/2026	0	ND	ng/L		2 NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBA)	PFMBA	2/6/2026	0	ND	ng/L		2 NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	2/6/2026	0	ND	ng/L		2 NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	2/6/2026	0	ND	ng/L		2 NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	2/6/2026	0	ND	ng/L		2 NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid (PFDoA)	PFDoA	2/6/2026	0	ND	ng/L		2 NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	2/6/2026	0	ND	ng/L		2 NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	2/6/2026	0	ND	ng/L		2 NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid (PFHxS)	PFHxS	2/6/2026	0	ND	ng/L		2 NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	2/6/2026	0	ND	ng/L		2 NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	2/6/2026	0	ND	ng/L		2 NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	2/6/2026	0	ND	ng/L		2 NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	2/6/2026	0	ND	ng/L		2 10
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	2/6/2026	0	ND	ng/L		2 10
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	2/6/2026	0	ND	ng/L		2 NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	2/6/2026	0	ND	ng/L		2 NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	2/6/2026	0	ND	ng/L		2 NA

List of Abbreviations:

MRL = Method Reporting Limit

ppt = parts per trillion

ppb = parts per billion

Analytical results depicted from 9/2020 through 6/2022 are EPA Method 537. Analytical results from 7/2022 to date are EPA Method 533.

EPA Method 537.1 data from 7/2022 to date is also included in the table.

Table has been sorted by sample date

\*Beginning Q2 2023, Veolia Water New York made the following changes to its PFAS sampling protocol. Method 533 is used to analyze all 25 unique PFAS compounds covered by this Method as indicated on the US EPA, Office of Water, table number MS-140 dated December 2019. Method 537.1 is used to analyze only the 4 additional PFAS compounds not addressed by Method 533 as presented in the same above reference

EPA table. Supplemental reports will also reflect this change beginning Q2 2023.

\*\* As systems are placed into service, the locations of samples/analysis are modified from individual well results to the following locations per DOH requirement.

Locations include "Combine Raw", "Discharge from Lead Vessel(s)" and "Effluent"

All Rockland locations have been added to this supplemental report per NYSDOH Request following Q3 2022

Not all wells sampled within the quarter were operational for that quarter

\*Beginning Q2 2023, Veolia Water New York made the following changes to its PFAS sampling protocol. Method 533 is used to analyze all 25 unique PFAS compounds covered by this Method as indicated on the US EPA, Office of Water, table number MS-140 dated Decem Supplemental reports also reflects this change beginning Q2 2023.