

July 13, 2026 (V1)

2

July 13, 2026 (V1)

3

Site	System	Type	Method	Analyte	Analyte Acronym	Sample Date	Final	Units	MRL	MCL
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorotetradecanoic acid	PFTeDA	4/21/2022	0	ppt	2.0	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorotridecanoic acid	PFTrDA	4/21/2022	0	ppt	2.0	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluoroundecanoic acid	PFUnA	4/21/2022	0	ppt	2.0	NA
Chateau Well 2	Forest Park	Compliance	EPA 522	1,4-Dioxane		6/7/2022	0	ppb	1.0	1
Chateau Well 2	Forest Park	Compliance	EPA 537	N-ethylperfluorooctanesulfonamidoacetic acid		6/7/2022	0	ppt	2.0	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	N-methylperfluorooctanesulfonamidoacetic acid		6/7/2022	0	ppt	2.0	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorobutanesulfonic acid	PFBS	6/7/2022	4.6	ppt	2.0	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorodecanoic acid	PFDA	6/7/2022	0	ppt	2.0	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorododecanoic acid	PFDoA	6/7/2022	0	ppt	2.0	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluoroheptanoic acid	PFHpA	6/7/2022	2.8	ppt	2.0	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorohexanoic acid	PFHxA	6/7/2022	4.2	ppt	2.0	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorohexanesulfonic acid	PFHxS	6/7/2022	2	ppt	2.0	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorononanoic acid	PFNA	6/7/2022	0	ppt	2.0	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorooctanoic acid	PFOA	6/7/2022	8.8	ppt	2.0	10
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorooctanesulfonic acid	PFOS	6/7/2022	8.4	ppt	2.0	10
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorotetradecanoic acid	PFTeDA	6/7/2022	0	ppt	2.0	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluorotridecanoic acid	PFTrDA	6/7/2022	0	ppt	2.0	NA
Chateau Well 2	Forest Park	Compliance	EPA 537	Perfluoroundecanoic acid	PFUnA	6/7/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 522	1,4-Dioxane		8/16/2022	0	ug/L	0.1	1
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	11-Chloroicosafafluoro-3-oxaundecane-1-sulfonic acid	11Cl-PF3OUdS	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9Cl-PF3ONS	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	N-ethylperfluorooctanesulfonamidoacetic acid	NetFOSAA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	N-methylperfluorooctanesulfonamidoacetic acid	NMeFOSAA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorobutanesulfonic acid	PFBS	8/16/2022	6	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorodecanoic acid	PFDA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorododecanoic acid	PFDoA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluoroheptanoic acid	PFHpA	8/16/2022	4.6	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorohexanoic acid	PFHxA	8/16/2022	8.3	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorohexanesulfonic acid	PFHxS	8/16/2022	2.4	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorononanoic acid	PFNA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorooctanoic acid	PFOA	8/16/2022	17	ppt	1.9	10
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorooctanesulfonic acid	PFOS	8/16/2022	16	ppt	1.9	10
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorotetradecanoic acid	PFTeDA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorotridecanoic acid	PFTrDA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluoroundecanoic acid	PFUnA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 522	1,4-Dioxane		8/16/2022	0	ug/L	0.1	1
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	11-Chloroicosafafluoro-3-oxaundecane-1-sulfonic acid	11Cl-PF3OUdS	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9Cl-PF3ONS	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	N-ethylperfluorooctanesulfonamidoacetic acid	NetFOSAA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	N-methylperfluorooctanesulfonamidoacetic acid	NMeFOSAA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorobutanesulfonic acid	PFBS	8/16/2022	5.1	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorodecanoic acid	PFDA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorododecanoic acid	PFDoA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluoroheptanoic acid	PFHpA	8/16/2022	3	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorohexanoic acid	PFHxA	8/16/2022	4.4	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorohexanesulfonic acid	PFHxS	8/16/2022	2.1	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorononanoic acid	PFNA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorooctanoic acid	PFOA	8/16/2022	12	ppt	1.9	10
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorooctanesulfonic acid	PFOS	8/16/2022	11	ppt	1.9	10
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorotetradecanoic acid	PFTeDA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorotridecanoic acid	PFTrDA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluoroundecanoic acid	PFUnA	8/16/2022	0	ppt	1.9	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	11-Chloroicosafafluoro-3-oxaundecane-1-sulfonic acid	11Cl-PF3OUdS	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9Cl-PF3ONS	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Nonafluoro-3,6-dioxaheptanoic acid	NFDHA	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorobutanoic acid	PFBA	9/14/2022	7.3	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorobutanesulfonic acid	PFBS	9/14/2022	5.4	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorodecanoic acid	PFDA	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorododecanoic acid	PFDoA	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoro(2-ethoxyethane)sulfonic acid	PFEESA	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoroheptanoic acid	PFHpA	9/14/2022	4.4	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoroheptanesulfonic acid	PFHpS	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorohexanoic acid	PFHxA	9/14/2022	8	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorohexanesulfonic acid	PFHxS	9/14/2022	2.2	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBA	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid	PFMPA	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorononanoic acid	PFNA	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorooctanoic acid	PFOA	9/14/2022	13	ppt	2.0	10
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorooctanesulfonic acid	PFOS	9/14/2022	14	ppt	2.0	10
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoropentanoic acid	PFPeA	9/14/2022	9.4	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoropentanesulfonic acid	PFPeS	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoroundecanoic acid	PFUnA	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	11-Chloroicosafafluoro-3-oxaundecane-1-sulfonic acid	11Cl-PF3OUdS	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	9/14/2022	0	ppt	2.0	NA

Site	System	Type	Method	Analyte	Analyte Acronym	Sample Date	Final	Units	MRL	MCL
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9CI-PF3ONS	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Nonafluoro-3,6-dioxaheptanoic acid	NFDHA	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorobutanoic acid	PFBA	9/14/2022	5	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorobutanesulfonic acid	PFBS	9/14/2022	4.7	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorodecanoic acid	PFDA	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorododecanoic acid	PFDoA	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoro(2-ethoxyethane)sulfonic acid	PFEEsA	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoroheptanoic acid	PFHpA	9/14/2022	2.9	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoroheptanesulfonic acid	PFHpS	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorohexanoic acid	PFHxA	9/14/2022	3.5	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorohexanesulfonic acid	PFHxS	9/14/2022	2	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBA	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid	PFMPA	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorononanoic acid	PFNA	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorooctanoic acid	PFOA	9/14/2022	8.4	ppt	2.0	10
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorooctanesulfonic acid	PFOS	9/14/2022	9	ppt	2.0	10
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoropentanoic acid	PFPeA	9/14/2022	4.8	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoropentanesulfonic acid	PFPeS	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoroundecanoic acid	PFUnA	9/14/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 522	1,4-Dioxane		10/24/2022	0	ug/L	0.1	1
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	11-Chloroicosafafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9CI-PF3ONS	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Nonafluoro-3,6-dioxaheptanoic acid	NFDHA	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorobutanoic acid	PFBA	10/24/2022	5	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorobutanesulfonic acid	PFBS	10/24/2022	4.3	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorodecanoic acid	PFDA	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorododecanoic acid	PFDoA	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoro(2-ethoxyethane)sulfonic acid	PFEEsA	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoroheptanoic acid	PFHpA	10/24/2022	2.4	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoroheptanesulfonic acid	PFHpS	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorohexanoic acid	PFHxA	10/24/2022	3.5	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorohexanesulfonic acid	PFHxS	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBA	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid	PFMPA	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorononanoic acid	PFNA	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorooctanoic acid	PFOA	10/24/2022	8.3	ppt	2.0	10
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorooctanesulfonic acid	PFOS	10/24/2022	8.5	ppt	2.0	10
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoropentanoic acid	PFPeA	10/24/2022	5.1	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoropentanesulfonic acid	PFPeS	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoroundecanoic acid	PFUnA	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	11-Chloroicosafafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9CI-PF3ONS	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	N-ethylperfluorooctanesulfonamidoacetic acid	NEtFOSAA	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	N-methylperfluorooctanesulfonamidoacetic acid	NMeFOSAA	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorobutanesulfonic acid	PFBS	10/24/2022	5.3	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorodecanoic acid	PFDA	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorododecanoic acid	PFDoA	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluoroheptanoic acid	PFHpA	10/24/2022	4.5	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorohexanoic acid	PFHxA	10/24/2022	8.8	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorohexanesulfonic acid	PFHxS	10/24/2022	2.3	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorononanoic acid	PFNA	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorooctanoic acid	PFOA	10/24/2022	14	ppt	2.0	10
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorooctanesulfonic acid	PFOS	10/24/2022	12	ppt	2.0	10
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorotetradecanoic acid	PFTA	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorotridecanoic acid	PFTrDA	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluoroundecanoic acid	PFUnA	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 522	1,4-Dioxane		10/24/2022	0.069	ug/L	0.1	1
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	11-Chloroicosafafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9CI-PF3ONS	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	N-ethylperfluorooctanesulfonamidoacetic acid	NEtFOSAA	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	N-methylperfluorooctanesulfonamidoacetic acid	NMeFOSAA	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorobutanesulfonic acid	PFBS	10/24/2022	4.6	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorodecanoic acid	PFDA	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorododecanoic acid	PFDoA	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluoroheptanoic acid	PFHpA	10/24/2022	2.6	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorohexanoic acid	PFHxA	10/24/2022	4.6	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorohexanesulfonic acid	PFHxS	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorononanoic acid	PFNA	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorooctanoic acid	PFOA	10/24/2022	9.1	ppt	2.0	10
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorooctanesulfonic acid	PFOS	10/24/2022	7.7	ppt	2.0	10
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorotetradecanoic acid	PFTA	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorotridecanoic acid	PFTTrDA	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluoroundecanoic acid	PFUnA	10/24/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	11-Chloroicosafafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	11/22/2022	0	ppt	2.0	NA

Site	System	Type	Method	Analyte	Analyte Acronym	Sample Date	Final	Units	MRL	MCL
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	11/22/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	11/22/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	11/22/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9CI-PF3ONS	11/22/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	11/22/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	11/22/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Nonafluoro-3,6-dioxaheptanoic acid	NFDHA	11/22/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorobutanoic acid	PFBA	11/22/2022	6	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorobutanesulfonic acid	PFBS	11/22/2022	4.7	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorodecanoic acid	PFDA	11/22/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorododecanoic acid	PFDoA	11/22/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoro(2-ethoxyethane)sulfonic acid	PFEEsA	11/22/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoroheptanoic acid	PFHpA	11/22/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoroheptanesulfonic acid	PFHpS	11/22/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorohexanoic acid	PFHxA	11/22/2022	2.9	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorohexanesulfonic acid	PFHxS	11/22/2022	2	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBA	11/22/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid	PFMPA	11/22/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorononanoic acid	PFNA	11/22/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorooctanoic acid	PFOA	11/22/2022	7.7	ppt	2.0	10
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorooctanesulfonic acid	PFOS	11/22/2022	8.2	ppt	2.0	10
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoropentanoic acid	PFPeA	11/22/2022	4.3	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoropentanesulfonic acid	PFPeS	11/22/2022	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoroundecanoic acid	PFUnA	11/22/2022	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 522	1,4-Dioxane		1/25/2023	0	ug/L	0.1	1
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	11-Chloroicosafafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9CI-PF3ONS	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Nonafluoro-3,6-dioxaheptanoic acid	NFDHA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorobutanoic acid	PFBA	1/25/2023	6.5	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorobutanesulfonic acid	PFBS	1/25/2023	5.2	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorodecanoic acid	PFDA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorododecanoic acid	PFDoA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoro(2-ethoxyethane)sulfonic acid	PFEEsA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoroheptanoic acid	PFHpA	1/25/2023	4.3	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoroheptanesulfonic acid	PFHpS	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorohexanoic acid	PFHxA	1/25/2023	8.4	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorohexanesulfonic acid	PFHxS	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid	PFMPA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorononanoic acid	PFNA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorooctanoic acid	PFOA	1/25/2023	12	ppt	2.0	10
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluorooctanesulfonic acid	PFOS	1/25/2023	12	ppt	2.0	10
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoropentanoic acid	PFPeA	1/25/2023	10	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoropentanesulfonic acid	PFPeS	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 533	Perfluoroundecanoic acid	PFUnA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	11-Chloroicosafafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9CI-PF3ONS	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	N-ethylperfluorooctanesulfonamidoacetic acid	NEtFOSAA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	N-methylperfluorooctanesulfonamidoacetic acid	NMeFOSAA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorobutanesulfonic acid	PFBS	1/25/2023	6	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorodecanoic acid	PFDA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorododecanoic acid	PFDoA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluoroheptanoic acid	PFHpA	1/25/2023	5.1	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorohexanoic acid	PFHxA	1/25/2023	9	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorohexanesulfonic acid	PFHxS	1/25/2023	2.3	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorononanoic acid	PFNA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorooctanoic acid	PFOA	1/25/2023	14	ppt	2.0	10
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorooctanesulfonic acid	PFOS	1/25/2023	13	ppt	2.0	10
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorotetradecanoic acid	PFTA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluorotridecanoic acid	PFTrDA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Forest Park	Compliance	EPA 537.1	Perfluoroundecanoic acid	PFUnA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 522	1,4-Dioxane		1/25/2023	0	ug/L	0.1	1
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	11-Chloroicosafafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9CI-PF3ONS	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Nonafluoro-3,6-dioxaheptanoic acid	NFDHA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorobutanoic acid	PFBA	1/25/2023	4.3	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorobutanesulfonic acid	PFBS	1/25/2023	3.9	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorodecanoic acid	PFDA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorododecanoic acid	PFDoA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoro(2-ethoxyethane)sulfonic acid	PFEEsA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoroheptanoic acid	PFHpA	1/25/2023	2	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoroheptanesulfonic acid	PFHpS	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorohexanoic acid	PFHxA	1/25/2023	3.3	ppt	2.0	NA

Site	System	Type	Method	Analyte	Analyte Acronym	Sample Date	Final	Units	MRL	MCL
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorohexanesulfonic acid	PFHxS	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid	PFMPA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorononanoic acid	PFNA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorooctanoic acid	PFOA	1/25/2023	6.9	ppt	2.0	10
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluorooctanesulfonic acid	PFOS	1/25/2023	7.1	ppt	2.0	10
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoropentanoic acid	PFPeA	1/25/2023	3.4	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoropentanesulfonic acid	PFPeS	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 533	Perfluoroundecanoic acid	PFUnA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	11-Chloroicosafafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9CI-PF3ONS	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	4,8-Dioxo-3H-perfluorononanoic acid	ADONA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Hexafluoropropylene Oxide Dimer Acid	HFPO-DA/GenX	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	N-ethylperfluorooctanesulfonamidoacetic acid	NEtFOSAA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	N-methylperfluorooctanesulfonamidoacetic acid	NMeFOSAA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorobutanesulfonic acid	PFBS	1/25/2023	4.6	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorodecanoic acid	PFDA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorododecanoic acid	PFDoA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluoroheptanoic acid	PFHpA	1/25/2023	2.3	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorohexanoic acid	PFHxA	1/25/2023	3.3	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorohexanesulfonic acid	PFHxS	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorononanoic acid	PFNA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorooctanoic acid	PFOA	1/25/2023	7.8	ppt	2.0	10
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorooctanesulfonic acid	PFOS	1/25/2023	6.9	ppt	2.0	10
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorotetradecanoic acid	PFTA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluorotridecanoic acid	PFTtDA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance	EPA 537.1	Perfluoroundecanoic acid	PFUnA	1/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 537.1	N-ethylperfluorooctanesulfonamidoacetic acid	NEtFOSAA	4/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 537.1	N-methylperfluorooctanesulfonamidoacetic acid	NMeFOSAA	4/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 537.1	Perfluorotetradecanoic acid	PFTA	4/25/2023	0	ppt	2.0	NA
CHATEAU WELL 1	Chateau	Compliance	EPA 537.1	Perfluorotridecanoic acid	PFTtDA	4/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 537.1	N-ethylperfluorooctanesulfonamidoacetic acid	NEtFOSAA	4/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 537.1	N-methylperfluorooctanesulfonamidoacetic acid	NMeFOSAA	4/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 537.1	Perfluorotetradecanoic acid	PFTA	4/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Chateau	Compliance	EPA 537.1	Perfluorotridecanoic acid	PFTtDA	4/25/2023	0	ppt	2.0	NA
CHATEAU WELL 2	Forest Park	Compliance		533 Perfluorooctanoic acid	PFOA	6/1/2023 8:25	7.8	ng/L		10
CHATEAU WELL 2	Forest Park	Compliance		533 Perfluorooctanesulfonic acid	PFOS	6/1/2023 8:25	8.2	ng/L		10
CHATEAU WELL 1	Forest Park	Compliance		533 Perfluorooctanoic acid	PFOA	6/1/2023 8:37	12	ng/L		10
CHATEAU WELL 1	Forest Park	Compliance		533 Perfluorooctanesulfonic acid	PFOS	6/1/2023 8:37	11	ng/L		10
CHATEAU RAW COMBO	Forest Park	Compliance	EPA 533	Perfluorooctanoic acid	PFOA	08/31/2023 11:45	7.69	ng/L		10
CHATEAU POE	Forest Park	Compliance	EPA 533	Perfluorooctanoic acid	PFOA	08/31/2023 11:45	0	ng/L		10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	11-chloroelicosafafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	10/20/2023 9:00	0	ng/L	0.5	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	10/20/2023 9:00	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	10/20/2023 9:00	0	ng/L	0.5	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	10/20/2023 9:00	2.13	ng/L	1.8	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	4,8-dioxo-3H-perfluorononanoic acid	ADONA	10/20/2023 9:00	0	ng/L	0.5	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid	9CI-PF3ONS	10/20/2023 9:00	0	ng/L	0.5	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid	HFPO-DA/GenX	10/20/2023 9:00	0	ng/L	0.5	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxahexanoic acid	NFDHA	10/20/2023 9:00	0	ng/L	0.5	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid	PFEEA	10/20/2023 9:00	0	ng/L	0.5	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid	PFMPA	10/20/2023 9:00	0	ng/L	0.5	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBA	10/20/2023 9:00	0	ng/L	0.5	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid	PFBS	10/20/2023 9:00	4.73	ng/L	0.5	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid	PFBA	10/20/2023 9:00	4.17	ng/L	0.5	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid	PFDA	10/20/2023 9:00	0	ng/L	0.5	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid	PFDoA	10/20/2023 9:00	0	ng/L	0.5	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid	PFHpS	10/20/2023 9:00	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid	PFHpA	10/20/2023 9:00	2.11	ng/L	0.5	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid	PFHxS	10/20/2023 9:00	1.79	ng/L	0.5	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid	PFHxA	10/20/2023 9:00	4.7	ng/L	0.5	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid	PFNA	10/20/2023 9:00	0.57	ng/L	0.5	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid	PFOS	10/20/2023 9:00	7.64	ng/L	0.5	10
Chateau Raw Combined	Forest Park	Compliance	EPA 533	Perfluorooctanoic acid	PFOA	10/20/2023 9:00	8.19	ng/L	0.5	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid	PFPeS	10/20/2023 9:00	0	ng/L	0.5	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid	PFPeA	10/20/2023 9:00	4.82	ng/L	0.5	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid	PFUnA	10/20/2023 9:00	0	ng/L	0.5	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid	NEtFOSAA	10/20/2023 9:00	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	N-methyl Perfluorooctanesulfonamidoacetic acid	NMeFOSAA	10/20/2023 9:00	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	Perfluorotetradecanoic acid	PFTeDA	10/20/2023 9:00	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	Perfluorotridecanoic acid	PFTtDA	10/20/2023 9:00	0	ng/L	0.9	NA
Chateau POE	NY-Chateau	Compliance	EPA 533	11-chloroelicosafafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	10/20/2023 9:09	0	ng/L	0.4	NA
Chateau POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	10/20/2023 9:09	0	ng/L	0.8	NA
Chateau POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	10/20/2023 9:09	0	ng/L	0.4	NA
Chateau POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	10/20/2023 9:09	0	ng/L	1.7	NA
Chateau POE	NY-Chateau	Compliance	EPA 533	4,8-dioxo-3H-perfluorononanoic acid	ADONA	10/20/2023 9:09	0	ng/L	0.4	NA
Chateau POE	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid	9CI-PF3ONS	10/20/2023 9:09	0	ng/L	0.4	NA
Chateau POE	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid	HFPO-DA/GenX	10/20/2023 9:09	0	ng/L	0.4	10
Chateau POE	NY-Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxahexanoic acid	NFDHA	10/20/2023 9:09	0	ng/L	0.4	NA
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid	PFEEA	10/20/2023 9:09	0	ng/L	0.4	NA
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid	PFMPA	10/20/2023 9:09	0	ng/L	0.4	NA
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBA	10/20/2023 9:09	0	ng/L	0.4	NA
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid	PFBS	10/20/2023 9:09	0	ng/L	0.4	NA
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid	PFBA	10/20/2023 9:09	0.82	ng/L	0.4	NA
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid	PFDA	10/20/2023 9:09	0	ng/L	0.4	10
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid	PFDoA	10/20/2023 9:09	0	ng/L	0.4	NA

Site	System	Type	Method	Analyte	Analyte Acronym	Sample Date	Final	Units	MRL	MCL
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid	PFHpS	10/20/2023 9:09		0 ng/L	0.8 NA	
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid	PFHpA	10/20/2023 9:09		0 ng/L	0.4	10
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid	PFHxS	10/20/2023 9:09		0 ng/L	0.4	10
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid	PFHxA	10/20/2023 9:09		0 ng/L	0.4 NA	
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid	PFNA	10/20/2023 9:09		0 ng/L	0.4	10
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid	PFOS	10/20/2023 9:09		0 ng/L	0.4	10
Chateau POE	Forest Park	Compliance	EPA 533	Perfluorooctanoic acid	PFOA	10/20/2023 9:09		0 ng/L	0.4	10
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid	PFPeS	10/20/2023 9:09		0 ng/L	0.4 NA	
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid	PFPeA	10/20/2023 9:09		0 ng/L	0.4 NA	
Chateau POE	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid	PFUnA	10/20/2023 9:09		0 ng/L	0.4 NA	
Chateau POE	NY-Chateau	Compliance	EPA 537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid	NETFOSAA	10/20/2023 9:09		0 ng/L	0.9 NA	
Chateau POE	NY-Chateau	Compliance	EPA 537.1	N-methyl Perfluorooctanesulfonamidoacetic acid	NMEFOSAA	10/20/2023 9:09		0 ng/L	0.9 NA	
Chateau POE	NY-Chateau	Compliance	EPA 537.1	Perfluorotetradecanoic acid	PFTeDA	10/20/2023 9:09		0 ng/L	0.9 NA	
Chateau POE	NY-Chateau	Compliance	EPA 537.1	Perfluorotridecanoic acid	PFTrDA	10/20/2023 9:09		0 ng/L	0.9 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	11-chloroicosafafluoro-3-oxaundecane-1-sulfonic acid	11Cl-PF3OUdS	11/10/2023 9:40		0 ng/L	0.9 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid	8:2 FTS	11/10/2023 9:40		0 ng/L	1.7 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid	4:2 FTS	11/10/2023 9:40		0 ng/L	0.9 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid	6:2 FTS	11/10/2023 9:40		0 ng/L	1.7 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	4,8-dioxo-3H-perfluorononanoic acid	ADONA	11/10/2023 9:40		0 ng/L	0.9 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid	9Cl-PF3ONS	11/10/2023 9:40		0 ng/L	0.9 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid	HFPO-DA/GenX	11/10/2023 9:40		0 ng/L	0.9	10
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxahexanoic acid	NFDHA	11/10/2023 9:40		0 ng/L	0.9 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid	PFEESA	11/10/2023 9:40		0 ng/L	0.9 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid	PFMPA	11/10/2023 9:40		0 ng/L	0.9 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid	PFMBa	11/10/2023 9:40		0 ng/L	0.9 NA	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid	PFBS	11/10/2023 9:40	6.56 ng/L	0.9 NA		
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid	PFBA	11/10/2023 9:40	9.83 ng/L	0.9 NA		
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid	PFDA	11/10/2023 9:40	0 ng/L	0.9	10	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid	PFDoA	11/10/2023 9:40	0 ng/L	0.9 NA		
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid	PFHpS	11/10/2023 9:40	0 ng/L	1.7 NA		
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid	PFHpA	11/10/2023 9:40	3.95 ng/L	0.9	10	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid	PFHxS	11/10/2023 9:40	2.09 ng/L	0.9	10	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid	PFHxA	11/10/2023 9:40	7.58 ng/L	0.9 NA		
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid	PFNA	11/10/2023 9:40	0.92 ng/L	0.9	10	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid	PFOS	11/10/2023 9:40	8.9 ng/L	0.9	10	
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid	PFPeS	11/10/2023 9:40	0 ng/L	0.9 NA		
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid	PFPeA	11/10/2023 9:40	8.87 ng/L	0.9 NA		
Chateau Well 3	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid	PFUnA	11/10/2023 9:40	0 ng/L	0.9 NA		
Chateau Well 3	NY-Chateau	Compliance	EPA 537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid	NETFOSAA	11/10/2023 9:40	0 ng/L	0.9 NA		
Chateau Well 3	NY-Chateau	Compliance	EPA 537.1	N-methyl Perfluorooctanesulfonamidoacetic acid	NMEFOSAA	11/10/2023 9:40	0 ng/L	0.9 NA		
Chateau Well 3	NY-Chateau	Compliance	EPA 537.1	Perfluorotetradecanoic acid	PFTeDA	11/10/2023 9:40	0 ng/L	0.9 NA		
Chateau Well 3	NY-Chateau	Compliance	EPA 537.1	Perfluorotridecanoic acid	PFTrDA	11/10/2023 9:40	0 ng/L	0.9 NA		
Chateau WTP POE	NY-Chateau	Compliance	EPA 522	1,4-Dioxane	1,4-Dioxane	1/16/2024		0 ug/L	0.2	1
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	11-chloroicosafafluoro-3-oxaundecane-1-sulfonic acid	11Cl-PF3OUdS	1/18/2024		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	8:2 FTS	1/18/2024		0 ng/L	1.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	4:2 FTS	1/18/2024		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	6:2 FTS	1/18/2024		0 ng/L	1.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	4,8-dioxo-3H-perfluorononanoic acid (ADONA)	ADONA	1/18/2024		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9Cl- 9Cl-PF3ONS		1/18/2024		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid (HFPO-DA)(Ge HFPO-DA/GenX		1/18/2024		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid (NETF NETFOSAA		1/18/2024		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	N-methyl Perfluorooctanesulfonamidoacetic acid (Nm NMEFOSAA		1/18/2024		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxahexanoic acid (NFDHA)	NFDHA	1/18/2024		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	PFEESA	1/18/2024		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	1/18/2024		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBa)	PFMBa	1/18/2024		0 ng/L	0.9 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	1/18/2024	7.08 ng/L	0.9 NA		
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	1/18/2024	5.35 ng/L	0.9 NA		
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	1/18/2024	0 ng/L	0.9 NA		
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid (PFDoA)	PFDoA	1/18/2024	0 ng/L	0.9 NA		
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	1/18/2024	0 ng/L	1.9 NA		
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	1/18/2024	2.58 ng/L	0.9 NA		
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid (PFHxS)	PFHxS	1/18/2024	2.06 ng/L	0.9 NA		
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	1/18/2024	6.47 ng/L	0.9 NA		
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	1/18/2024	0.988 ng/L	0.9 NA		
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	1/18/2024	14.9 ng/L	0.9	10	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	1/18/2024	10.6 ng/L	0.9	10	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	1/18/2024	0 ng/L	0.9 NA		
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	1/18/2024	7 ng/L	0.9 NA		
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	Perfluorotetradecanoic acid (PFTeDA)	PFTeDA	1/18/2024	0 ng/L	0.9 NA		
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	Perfluorotridecanoic acid (PFTrDA)	PFTrDA	1/18/2024	0 ng/L	0.9 NA		
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	1/18/2024	0 ng/L	0.9 NA		
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	11-chloroicosafafluoro-3-oxaundecane-1-sulfonic acid	11Cl-PF3OUdS	1/18/2024		0 ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	8:2 FTS	1/18/2024		0 ng/L	1.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	4:2 FTS	1/18/2024		0 ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	6:2 FTS	1/18/2024		0 ng/L	1.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	4,8-dioxo-3H-perfluorononanoic acid (ADONA)	ADONA	1/18/2024		0 ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9Cl- 9Cl-PF3ONS		1/18/2024		0 ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid (HFPO-DA)(Ge HFPO-DA/GenX		1/18/2024		0 ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid (NETF NETFOSAA		1/18/2024		0 ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	N-methyl Perfluorooctanesulfonamidoacetic acid (Nm NMEFOSAA		1/18/2024		0 ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxahexanoic acid (NFDHA)	NFDHA	1/18/2024		0 ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	PFEESA	1/18/2024		0 ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	1/18/2024		0 ng/L	0.9 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBa)	PFMBa	1/18/2024		0 ng/L	0.9 NA	

Site	System	Type	Method	Analyte	Analyte Acronym	Sample Date	Final	Units	MRL	MCL
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	1/18/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	1/18/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	1/18/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid (PFDoA)	PFDoA	1/18/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	1/18/2024	0	ng/L	1.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	1/18/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid (PFHxS)	PFHxS	1/18/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	1/18/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	1/18/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	1/18/2024	0	ng/L	0.9	10
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	1/18/2024	0	ng/L	0.9	10
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	1/18/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	1/18/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	Perfluorotetradecanoic acid (PFTeDA)	PFTeDA	1/18/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	Perfluorotridecanoic acid (PFTrDA)	PFTrDA	1/18/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	1/18/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	11-chloroicosafafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF30UdS	4/16/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	11-chloroicosafafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF30UdS	4/16/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	8:2 FTS	4/16/2024	0	ng/L	1.7	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	8:2 FTS	4/16/2024	0	ng/L	1.8	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	4:2 FTS	4/16/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	4:2 FTS	4/16/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	6:2 FTS	4/16/2024	0	ng/L	1.7	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	6:2 FTS	4/16/2024	0	ng/L	1.8	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	4,8-dioxo-3H-perfluorononanoic acid (ADONA)	ADONA	4/16/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	4,8-dioxo-3H-perfluorononanoic acid (ADONA)	ADONA	4/16/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9CI- PF30NS)	9CI- PF30NS	4/16/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9CI- PF30NS)	9CI- PF30NS	4/16/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid (HFPO-DA)(Ge HFPO-DA)(GenX)	HFPO-DA)(Ge HFPO-DA)(GenX	4/16/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid (HFPO-DA)(Ge HFPO-DA)(GenX)	HFPO-DA)(Ge HFPO-DA)(GenX	4/16/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid (NETF- NETFOSAA)	NETF- NETFOSAA	4/16/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid (NETF- NETFOSAA)	NETF- NETFOSAA	4/16/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	N-methyl Perfluorooctanesulfonamidoacetic acid (NM- NMefOSAA)	NM- NMefOSAA	4/16/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	N-methyl Perfluorooctanesulfonamidoacetic acid (NM- NMefOSAA)	NM- NMefOSAA	4/16/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	NFDHA	4/16/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	NFDHA	4/16/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEEA)	PFEEA	4/16/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEEA)	PFEEA	4/16/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	4/16/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	4/16/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBA)	PFMBA	4/16/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBA)	PFMBA	4/16/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	4/16/2024	5.9	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	4/16/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	4/16/2024	4.85	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	4/16/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	4/16/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	4/16/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid (PFDoA)	PFDoA	4/16/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid (PFDoA)	PFDoA	4/16/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	4/16/2024	0	ng/L	1.7	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	4/16/2024	0	ng/L	1.8	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	4/16/2024	3.12	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	4/16/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid (PFHxS)	PFHxS	4/16/2024	2.12	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid (PFHxS)	PFHxS	4/16/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	4/16/2024	4.8	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	4/16/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	4/16/2024	0.88	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	4/16/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	4/16/2024	10.7	ng/L	0.9	10
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	4/16/2024	0	ng/L	0.9	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	4/16/2024	9.38	ng/L	0.9	10
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	4/16/2024	0	ng/L	0.9	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	4/16/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	4/16/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	4/16/2024	5.92	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	4/16/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	Perfluorotetradecanoic acid (PFTeDA)	PFTeDA	4/16/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	Perfluorotetradecanoic acid (PFTeDA)	PFTeDA	4/16/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	Perfluorotridecanoic acid (PFTrDA)	PFTrDA	4/16/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	Perfluorotridecanoic acid (PFTrDA)	PFTrDA	4/16/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	4/16/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	4/16/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	11-chloroicosafafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF30UdS	7/15/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	11-chloroicosafafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF30UdS	7/15/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	8:2 FTS	7/15/2024	0	ng/L	1.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	8:2 FTS	7/15/2024	0	ng/L	1.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	4:2 FTS	7/15/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	4:2 FTS	7/15/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	6:2 FTS	7/15/2024	0	ng/L	1.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	6:2 FTS	7/15/2024	0	ng/L	1.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	4,8-dioxo-3H-perfluorononanoic acid (ADONA)	ADONA	7/15/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	4,8-dioxo-3H-perfluorononanoic acid (ADONA)	ADONA	7/15/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9CI- PF30NS)	9CI- PF30NS	7/15/2024	0	ng/L	0.9	NA

Site	System	Type	Method	Analyte	Analyte Acronym	Sample Date	Final	Units	MRL	MCL
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9CI-9CI-PF3ONS		7/15/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	Hazard Index	9CI-PF3ONS	7/15/2024	0	ng/L		NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	Hazard Index	9CI-PF3ONS	7/15/2024	0	ng/L		NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	Hazard Index	9CI-PF3ONS	7/15/2024	0.38	ng/L		NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	Hazard Index	9CI-PF3ONS	7/15/2024	0.21	ng/L		NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid (HFPO-DA)(Ge	HFPO-DA)(GenX	7/15/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid (HFPO-DA)(Ge	HFPO-DA)(GenX	7/15/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid (NETF	NETFOSAA	7/15/2024	0	ng/L	1.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid (NETF	NETFOSAA	7/15/2024	0	ng/L	1.8	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	N-methyl Perfluorooctanesulfonamidoacetic acid (NM	NMeFOSAA	7/15/2024	0	ng/L	1.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	N-methyl Perfluorooctanesulfonamidoacetic acid (NM	NMeFOSAA	7/15/2024	0	ng/L	1.8	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxahexanoic acid (NFDHA)	NFDHA	7/15/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxahexanoic acid (NFDHA)	NFDHA	7/15/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEEA)	PFEEA	7/15/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEEA)	PFEEA	7/15/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	7/15/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	7/15/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBA)	PFMBA	7/15/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBA)	PFMBA	7/15/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	7/15/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	7/15/2024	5.63	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	7/15/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	7/15/2024	5.14	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	7/15/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	7/15/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid (PFDoA)	PFDoA	7/15/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid (PFDoA)	PFDoA	7/15/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	7/15/2024	0	ng/L	1.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	7/15/2024	0	ng/L	1.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	7/15/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	7/15/2024	3.44	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid (PFHxS)	PFHxS	7/15/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid (PFHxS)	PFHxS	7/15/2024	2.34	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	7/15/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	7/15/2024	6.45	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	7/15/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	7/15/2024	1.17	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	7/15/2024	0	ng/L	0.9	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	7/15/2024	14.6	ng/L	0.9	10
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	7/15/2024	0	ng/L	0.9	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	7/15/2024	11.9	ng/L	0.9	10
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	7/15/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	7/15/2024	0	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	7/15/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	7/15/2024	6.97	ng/L	0.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	Perfluorotetradecanoic acid (PFTeDA)	PFTeDA	7/15/2024	0	ng/L	1.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	Perfluorotetradecanoic acid (PFTeDA)	PFTeDA	7/15/2024	0	ng/L	1.8	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	Perfluorotridecanoic acid (PFTrDA)	PFTrDA	7/15/2024	0	ng/L	1.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	Perfluorotridecanoic acid (PFTrDA)	PFTrDA	7/15/2024	0	ng/L	1.8	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	7/15/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	7/15/2024	0	ng/L	0.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	11-chloroicosadecafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUs	10/28/2024	ND	ng/L	1.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	8:2 FTS	10/28/2024	ND	ng/L	1.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	4:2 FTS	10/28/2024	ND	ng/L	1.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	6:2 FTS	10/28/2024	2.06	ng/L	1.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	4,8-dioxo-3H-perfluorononanoic acid (ADONA)	ADONA	10/28/2024	ND	ng/L	1.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9CI-9CI-PF3ONS		10/28/2024	ND	ng/L	1.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid (HFPO-DA)(Ge	HFPO-DA)(GenX	10/28/2024	ND	ng/L	1.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid (NETF	NETFOSAA	10/28/2024	ND	ng/L	1.8	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	N-methyl Perfluorooctanesulfonamidoacetic acid (NM	NMeFOSAA	10/28/2024	ND	ng/L	1.8	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxahexanoic acid (NFDHA)	NFDHA	10/28/2024	ND	ng/L	1.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEEA)	PFEEA	10/28/2024	ND	ng/L	1.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	10/28/2024	ND	ng/L	1.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBA)	PFMBA	10/28/2024	ND	ng/L	1.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	10/28/2024	5.24	ng/L	1.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	10/28/2024	6.99	ng/L	1.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	10/28/2024	ND	ng/L	1.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid (PFDoA)	PFDoA	10/28/2024	ND	ng/L	1.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	10/28/2024	ND	ng/L	1.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	10/28/2024	2.97	ng/L	1.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid (PFHxS)	PFHxS	10/28/2024	1.97	ng/L	1.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	10/28/2024	10.7	ng/L	1.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	10/28/2024	ND	ng/L	1.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	10/28/2024	12.4	ng/L	1.9	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	10/28/2024	17.7	ng/L	1.9	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	10/28/2024	ND	ng/L	1.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	10/28/2024	10.2	ng/L	1.9	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	Perfluorotetradecanoic acid (PFTeDA)	PFTeDA	10/28/2024	ND	ng/L	1.8	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	Perfluorotridecanoic acid (PFTrDA)	PFTrDA	10/28/2024	ND	ng/L	1.8	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	10/28/2024	ND	ng/L	1.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	11-chloroicosadecafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUs	10/28/2024	ND	ng/L	1.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	8:2 FTS	10/28/2024	ND	ng/L	1.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	4:2 FTS	10/28/2024	ND	ng/L	1.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	6:2 FTS	10/28/2024	ND	ng/L	1.9	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	4,8-dioxo-3H-perfluorononanoic acid (ADONA)	ADONA	10/28/2024	ND	ng/L	1.9	NA

July 13, 2026 (V1)

	System	Type	Method	Analyte	Analyte Acronym	Sample Date	Final	Units	MRL	MCL
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9CI- 9CI-PF3ONS		10/28/2024	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid (HFPO-DA)(Ge HFPO-DA)(GenX		10/28/2024	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid (NetF NetFOSAA		10/28/2024	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	N-methyl Perfluorooctanesulfonamidoacetic acid (NM NMefOSAA		10/28/2024	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	NFDHA	10/28/2024	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	PFEESA	10/28/2024	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	10/28/2024	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBA)	PFMBA	10/28/2024	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	10/28/2024	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	10/28/2024	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	10/28/2024	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid (PFDoA)	PFDoA	10/28/2024	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	10/28/2024	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	10/28/2024	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid (PFHxS)	PFHxS	10/28/2024	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	10/28/2024	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	10/28/2024	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	10/28/2024	ND	ng/L	1.9	10 ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	10/28/2024	ND	ng/L	1.9	10 ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	10/28/2024	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	10/28/2024	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	Perfluorotetradecanoic acid (PFTeDA)	PFTeDA	10/28/2024	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	Perfluorotridecanoic acid (PFTrDA)	PFTrDA	10/28/2024	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	10/28/2024	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	11-chloroicosafafluoro-3-oxaundecane-1-sulfonic acid 11CI-PF3OUdS		1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	11-chloroicoesafluoro-3-oxaundecane-1-sulfonic acid 11CI-PF3OUdS		1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	8:2 FTS	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	8:2 FTS	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	4:2 FTS	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	4:2 FTS	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	6:2 FTS	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	6:2 FTS	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	4,8-dioxia-3H-perfluorononanoic acid (ADONA)	ADONA	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	4,8-dioxia-3H-perfluorononanoic acid (ADONA)	ADONA	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9CI- 9CI-PF3ONS		1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9CI- 9CI-PF3ONS		1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid (HFPO-DA)(Ge HFPO-DA (GenX)		1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid (HFPO-DA)(Ge HFPO-DA (GenX)		1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid (NetF NetFOSAA		1/21/2025 ND	ND	ng/L	1.8 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	N-ethyl Perfluorooctanesulfonamidoacetic acid (NetF NetFOSAA		1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	N-methyl Perfluorooctanesulfonamidoacetic acid (NM NMefOSAA		1/21/2025 ND	ND	ng/L	1.8 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	N-methyl Perfluorooctanesulfonamidoacetic acid (NM NMefOSAA		1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	NFDHA	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	NFDHA	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	PFEESA	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEESA)	PFEESA	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBA)	PFMBA	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBA)	PFMBA	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	1/21/2025	5.5	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	1/21/2025	5.9	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid (PFDoA)	PFDoA	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid (PFDoA)	PFDoA	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	1/21/2025	2.65	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid (PFHxS)	PFHxS	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid (PFHxS)	PFHxS	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	1/21/2025	6.52	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	1/21/2025 ND	ND	ng/L	1.9	10 ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	1/21/2025	12	ng/L	1.9	10 ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	1/21/2025 ND	ND	ng/L	1.9	10 ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	1/21/2025	9.67	ng/L	1.9	10 ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	1/21/2025	7.92	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	Perfluorotetradecanoic acid (PFTeDA)	PFTeDA	1/21/2025 ND	ND	ng/L	1.8 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	Perfluorotetradecanoic acid (PFTeDA)	PFTeDA	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 537.1	Perfluorotridecanoic acid (PFTrDA)	PFTrDA	1/21/2025 ND	ND	ng/L	1.8 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 537.1	Perfluorotridecanoic acid (PFTrDA)	PFTrDA	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	1/21/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	11-chloroicoesafluoro-3-oxaundecane-1-sulfonic acid 11CI-PF3OUdS		4/9/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	11-chloroicoesafluoro-3-oxaundecane-1-sulfonic acid 11CI-PF3OUdS		4/9/2025 ND	ND	ng/L	1.9 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	8:2 FTS	4/9/2025 ND	ND	ng/L	1.9 NA	ng/L

[illegible]

Site	System	Type	Method	Analyte	Analyte Acronym	Sample Date	Final	Units	MRL	MCL
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	7/10/2025	ND	ng/L	2.0	10 ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	7/10/2025		9.29 ng/L	2.0	10 ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	7/10/2025	ND	ng/L	2.0	10 ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	7/10/2025		8.74 ng/L	2.0	10 ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	7/10/2025	ND	ng/L	2.0 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	7/10/2025	ND	ng/L	2.0 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	7/10/2025	ND	ng/L	2.0 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	7/10/2025		5.89 ng/L	2.0 NA	ng/L
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	7/10/2025	ND	ng/L	2.0 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	7/10/2025	ND	ng/L	2.0 NA	ng/L
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	11-chloroheptafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	10/23/2025	ND	ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	11-chloroheptafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	10/23/2025	ND	ng/L	1.8 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	8:2 FTS	10/23/2025	ND	ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	8:2 FTS	10/23/2025	ND	ng/L	1.8 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	4:2 FTS	10/23/2025	ND	ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	4:2 FTS	10/23/2025	ND	ng/L	1.8 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	6:2 FTS	10/23/2025	ND	ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	6:2 FTS	10/23/2025	ND	ng/L	1.8 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	4,8-dioxo-3H-perfluorononanoic acid (ADONA)	ADONA	10/23/2025	ND	ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	4,8-dioxo-3H-perfluorononanoic acid (ADONA)	ADONA	10/23/2025	ND	ng/L	1.8 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9CI- 9CI-PF3ONS	9CI- 9CI-PF3ONS	10/23/2025	ND	ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9CI- 9CI-PF3ONS	9CI- 9CI-PF3ONS	10/23/2025	ND	ng/L	1.8 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid (HFPO-DA)(Ge HFPO-DA)(GenX	HFPO-DA)(GenX	10/23/2025	ND	ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid (HFPO-DA)(Ge HFPO-DA)(GenX	HFPO-DA)(GenX	10/23/2025	ND	ng/L	1.8 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxahexanoic acid (NFDHA)	NFDHA	10/23/2025	ND	ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxahexanoic acid (NFDHA)	NFDHA	10/23/2025	ND	ng/L	1.8 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEEA)	PFEEA	10/23/2025	ND	ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEEA)	PFEEA	10/23/2025	ND	ng/L	1.8 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	10/23/2025	ND	ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	10/23/2025	ND	ng/L	1.8 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBA)	PFMBA	10/23/2025	ND	#N/A	2.0	#N/A
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBA)	PFMBA	10/23/2025	ND	#N/A	1.8	#N/A
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	10/23/2025		7.2 ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	10/23/2025	ND	ng/L	1.8 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	10/23/2025		8.76 ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	10/23/2025	ND	ng/L	1.8 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	10/23/2025	ND	ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	10/23/2025	ND	ng/L	1.8 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid (PFDoA)	PFDoA	10/23/2025	ND	ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid (PFDoA)	PFDoA	10/23/2025	ND	ng/L	1.8 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	10/23/2025	ND	ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	10/23/2025	ND	ng/L	1.8 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	10/23/2025		5.29 ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	10/23/2025	ND	ng/L	1.8 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid (PFHxS)	PFHxS	10/23/2025		1.91 ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid (PFHxS)	PFHxS	10/23/2025	ND	ng/L	1.8 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	10/23/2025		11.4 ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	10/23/2025	ND	ng/L	1.8 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	10/23/2025		2.15 ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	10/23/2025	ND	ng/L	1.8 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	10/23/2025		15.4 ng/L	2.0	10
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	10/23/2025	ND	ng/L	1.8	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	10/23/2025		17.5 ng/L	2.0	10
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	10/23/2025	ND	ng/L	1.8	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	10/23/2025	ND	ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	10/23/2025	ND	ng/L	1.8 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	10/23/2025		13.8 ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	10/23/2025	ND	ng/L	1.8 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	10/23/2025	ND	ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	10/23/2025	ND	ng/L	1.8 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	11-chloroheptafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF3OUdS	2/6/2026	ND	ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	8:2 FTS	2/6/2026	ND	ng/L	2.0 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	4:2 FTS	2/6/2026	ND	ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	6:2 FTS	2/6/2026	ND	ng/L	2.0 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	4,8-dioxo-3H-perfluorononanoic acid (ADONA)	ADONA	2/6/2026	ND	ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9CI- 9CI-PF3ONS	9CI- 9CI-PF3ONS	2/6/2026	ND	ng/L	2.0 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid (HFPO-DA)(Ge HFPO-DA)(GenX	HFPO-DA)(GenX	2/6/2026	ND	ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Nonafluoro-3,6-dioxahexanoic acid (NFDHA)	NFDHA	2/6/2026	ND	ng/L	2.0 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEEA)	PFEEA	2/6/2026	ND	ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	2/6/2026	ND	ng/L	2.0 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBA)	PFMBA	2/6/2026	ND	ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	2/6/2026		5.58 ng/L	2.0 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	2/6/2026		6.07 ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	2/6/2026	ND	ng/L	2.0 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid (PFDoA)	PFDoA	2/6/2026	ND	ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	2/6/2026	ND	ng/L	2.0 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	2/6/2026		2.97 ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid (PFHxS)	PFHxS	2/6/2026	ND	ng/L	2.0 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	2/6/2026		6.21 ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	2/6/2026	ND	ng/L	2.0 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	2/6/2026	ND	ng/L	2.0 NA	
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	2/6/2026		11.8 ng/L	2.0	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	2/6/2026		9.94 ng/L	2.0	10
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	2/6/2026	ND	ng/L	2.0 NA	
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	2/6/2026		6.98 ng/L	2.0 NA	

Site	System	Type	Method	Analyte	Analyte Acronym	Sample Date	Final	Units	MRL	MCL
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	2/6/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	11-chloroicosafafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF30UDs	2/6/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	8:2 FTS	2/6/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	4:2 FTS	2/6/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	6:2 FTS	2/6/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	4,8-dioxo-3H-perfluorononanoic acid (ADONA)	ADONA	2/6/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9CI-9CI-PF30NS)	9CI-9CI-PF30NS	2/6/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid (HFPO-DA)(Ge	HFPO-DA)(GenX	2/6/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Nonafafluoro-3,6-dioxahexanoic acid (NFDHA)	NFDHA	2/6/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEEA)	PFEEA	2/6/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	2/6/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBA)	PFMBA	2/6/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	2/6/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	2/6/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	2/6/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid (PFDoA)	PFDoA	2/6/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	2/6/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	2/6/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid (PFHxS)	PFHxS	2/6/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	2/6/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	2/6/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	2/6/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	2/6/2026	ND	ng/L	2.0	10
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	2/6/2026	ND	ng/L	2.0	10
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	2/6/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	2/6/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	2/6/2026	ND	ng/L	2.0	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	11-chloroicosafafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF30UDs	4/29/2026	ND	ng/L	2.0	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	8:2 FTS	4/29/2026	ND	ng/L	2.0	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	4:2 FTS	4/29/2026	ND	ng/L	2.0	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	6:2 FTS	4/29/2026	ND	ng/L	2.0	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	4,8-dioxo-3H-perfluorononanoic acid (ADONA)	ADONA	4/29/2026	ND	ng/L	2.0	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9CI-9CI-PF30NS)	9CI-9CI-PF30NS	4/29/2026	ND	ng/L	2.0	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid (HFPO-DA)(Ge	HFPO-DA)(GenX	4/29/2026	ND	ng/L	2.0	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Nonafafluoro-3,6-dioxahexanoic acid (NFDHA)	NFDHA	4/29/2026	ND	ng/L	2.0	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEEA)	PFEEA	4/29/2026	ND	ng/L	2.0	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	4/29/2026	ND	ng/L	2.0	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBA)	PFMBA	4/29/2026	ND	ng/L	2.0	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	4/29/2026	5.84	ng/L	2.0	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	4/29/2026	5.43	ng/L	2.0	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	4/29/2026	ND	ng/L	2.0	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid (PFDoA)	PFDoA	4/29/2026	ND	ng/L	2.0	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	4/29/2026	ND	ng/L	2.0	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	4/29/2026	2.65	ng/L	2.0	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid (PFHxS)	PFHxS	4/29/2026	2.23	ng/L	2.0	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	4/29/2026	5.31	ng/L	2.0	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	4/29/2026	ND	ng/L	2.0	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	4/29/2026	10.5	ng/L	2.0	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	4/29/2026	9.62	ng/L	2.0	10
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	4/29/2026	ND	ng/L	2.0	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	4/29/2026	5.29	ng/L	2.0	NA
Chateau Raw Combined	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	4/29/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	11-chloroicosafafluoro-3-oxaundecane-1-sulfonic acid	11CI-PF30UDs	4/29/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2 FTS)	8:2 FTS	4/29/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2 FTS)	4:2 FTS	4/29/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2 FTS)	6:2 FTS	4/29/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	4,8-dioxo-3H-perfluorononanoic acid (ADONA)	ADONA	4/29/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9CI-9CI-PF30NS)	9CI-9CI-PF30NS	4/29/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Hexafluoropropylene oxide dimer acid (HFPO-DA)(Ge	HFPO-DA)(GenX	4/29/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Nonafafluoro-3,6-dioxahexanoic acid (NFDHA)	NFDHA	4/29/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro (2-ethoxyethane) sulfonic acid (PFEEA)	PFEEA	4/29/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro-3-methoxypropanoic acid (PFMPA)	PFMPA	4/29/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoro-4-methoxybutanoic acid (PFMBA)	PFMBA	4/29/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanesulfonic acid (PFBS)	PFBS	4/29/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorobutanoic acid (PFBA)	PFBA	4/29/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorodecanoic acid (PFDA)	PFDA	4/29/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorododecanoic acid (PFDoA)	PFDoA	4/29/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanesulfonic acid (PFHpS)	PFHpS	4/29/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroheptanoic acid (PFHpA)	PFHpA	4/29/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanesulfonic acid (PFHxS)	PFHxS	4/29/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorohexanoic acid (PFHxA)	PFHxA	4/29/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorononanoic acid (PFNA)	PFNA	4/29/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanesulfonic acid (PFOS)	PFOS	4/29/2026	ND	ng/L	2.0	10
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluorooctanoic acid (PFOA)	PFOA	4/29/2026	ND	ng/L	2.0	10
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanesulfonic acid (PFPeS)	PFPeS	4/29/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoropentanoic acid (PFPeA)	PFPeA	4/29/2026	ND	ng/L	2.0	NA
Chateau WTP POE	NY-Chateau	Compliance	EPA 533	Perfluoroundecanoic acid (PFUnA)	PFUnA	4/29/2026	ND	ng/L	2.0	NA

List of Abbreviations:

MRL = Method Reporting Limit

ppt = parts per trillion

ppb = parts per billion

Analytical results depicted from 9/2020 through 6/2022 are EPA Method 537. Analytical results from 7/2022 to date are EPA Method 533.

Site	System	Type	Method	Analyte	Analyte Acronym	Sample Date	Final	Units	MRL	MCL
EPA Method 537.1 data from 7/2022 to date is also included in the table.										
Table has been sorted by sample date										
*Beginning Q2 2023, Veolia Water New York made the following changes to its PFAS sampling protocol. Method 533 is used to analyze all 25 unique PFAS compounds covered by this Method as indicated on the US EPA, Office of Water, table number MS-140 dated December 2019. Method 537.1 is used to analyze only the 4 additional PFAS compounds not addressed by Method 533 as presented in the same above reference										
EPA table. Supplemental reports will also reflect this change beginning Q2 2023.										
** As systems are placed into service, the locations of samples/analysis are modified from individual well results to the following locations per DOH requirement.										
Locations include "Combine Raw", "Discharge from Lead Vessel(s)" and "Effluent"										
All Rockland locations have been added to this supplemental report per NYSDOH Request following Q3 2022										
Not all wells sampled within the quarter were operational for that quarter										
*Beginning Q2 2023, Veolia Water New York made the following changes to its PFAS sampling protocol. Method 533 is used to analyze all 25 unique PFAS compounds covered by this Method as indicated on the US EPA, Office of Water, table number MS-140 dated December 2019. Method 537.1 is used to analyze only the 4 additional PFAS compounds not addressed by Method 533 as presented in the same above reference										
Supplemental reports also reflect this change beginning Q2 2023.										